

APR 12 1983

Docket Nos. 50-315  
and 50-316

Mr. John Dolan, Vice President  
Indiana and Michigan Electric Company  
Post Office Box 18  
Bowling Green Station  
New York, New York 10004

Dear Mr. Dolan:

By letter dated February 7, 1983, we transmitted to you our Amendment No. 69 to Facility Operating License No. DPR-58 and Amendment No. 51 to Facility Operating License No. DPR-74 for the D. C. Cook Nuclear Plant, Unit Nos. 1 and 2, respectively. Those amendments approved the radiological environmental Technical Specifications and among other things, referenced the use of approved process control procedures (PCP) for Unit Nos. 1 and 2. On March 4, 1983, Indiana and Michigan Electric Company submitted the PCP and requested our approval.

We have reviewed your PCP and find that it uses documented and approved methods that are consistent with NRC guidelines and, therefore, is acceptable for use as required by Technical Specification 6.14. We did find that clarification should be made on shipping containers which use cement to contain the waste. In your next revision of the PCP, you are requested to add a statement that the cement must be solidified before the containers are closed.

If you have any questions on this matter, please let us know.

Sincerely,

Original signed by:  
S. A. Varga

Steven A. Varga, Chief  
Operating Reactors Branch #1  
Division of Licensing

cc: See next page

8304200345 830412  
PDR ADDCK 05000315  
P PDR

OFFICE	ORR #1: DL	ETSR	AD/RR	ORR #1: DL	AD/OP: DL		
SURNAME	Wigginton: dm	Nichols/Gammill	Muller	S. Varga	GLainas		
DATE	04/12/83	04/12/83	04/12/83	04/12/83	04/12/83		

DISTRIBUTION  
Dockets WMienke  
NRC PDR CWillis  
L PDR  
NSIC  
ORB #1 Rdg  
DEisenhut  
OELD  
ELJordan  
JMTaylor  
ACRS-10  
DWigginton  
CParrish  
DMuller  
CNichols  
WGammill  
Gray

Mr. John Dolan  
Indiana and Michigan Electric Company

cc: Mr. M. P. Alexich  
Assistant Vice President  
for Nuclear Engineering  
American Electric Power  
Service Corporation  
2 Broadway  
New York, New York 10004

Gerald Charnoff, Esquire  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, N.W.  
Washington, D. C. 20036

W. G. Smith Jr., Plant Manager  
Donald C. Cook Nuclear Plant  
P. O. Box 458  
Bridgman, Michigan 49106

U. S. Nuclear Regulatory Commission  
Resident Inspectors Office  
7700 Red Arrow Highway  
Stevensville, Michigan 49127

William J. Scanlon, Esquire  
2034 Pauline Boulevard  
Ann Arbor, Michigan 48103

The Honorable Tom Corcoran  
United States House of Representatives  
Washington, D. C. 20515

James G. Keppler  
Regional Administrator - Region III  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137