



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555

0 5 JUN 1986

MEMORANDUM FOR: Sholly Coordinator

FROM: B. J. Youngblood, Director  
PWR Project Directorate #4  
Division of PWR Licensing-A, NRR

SUBJECT: REQUEST FOR PUBLICATION IN BI-WEEKLY FR NOTICE -  
NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT  
TO FACILITY OPERATING LICENSE AND PROPOSED NO  
SIGNIFICANT HAZARDS CONSIDERATION DETERMINATION  
AND OPPORTUNITY FOR A HEARING

Indiana and Michigan Electric Company, Docket Nos. 50-315 and 50-316,

Donald C. Cook Nuclear Plant, Unit Nos. 1 and 2, Berrien County, Michigan

Date of amendment request: May 19, 1986

Description of amendment request: The proposed amendment would revise the Technical Specifications by adding requirements for the containment sump level and flow monitoring system for both Units and to correct a duplication of surveillance requirements on the reactor coolant leakage detection system for Unit 1.

Basis for proposed no significant hazards consideration determination:

The Commission has provided guidance concerning the applications of the standards for making a no significant hazards determination by providing certain examples (48 FR 14870). One of the examples (ii) is a change that constitutes an additional limitation, restriction, or control not presently included in the technical specifications. The change to add requirements for the containment sump level and flow monitoring system for both units is directly related to this example. This system was required as part of the TMI Action Plan, NUREG-0737. Another example (i) is a purely administrative change to the technical specifications. Surveillance Requirement 4.4.6.1 is now on page 3/4 4-14 for Unit 1 and is exactly repeated on page 3/4 4-15.

8606110544 860605  
PDR ADOCK 05000315  
P PDR

0 5 JUN 1986

Sholly Coordinator

- 2 -

The removal of the duplication is purely administrative and directly related to the example. Therefore, the Commission proposes to find that the changes do not involve a significant hazards consideration.

Local Public Document Room location: Maude Preston Palenske Memorial Library, 500 Market Street, St. Joseph, Michigan 49085

Attorney for licensee: Gerald Charnoff, Esquire, Shaw, Pittman, Potts and Trowbridge, 1800 M Street, N.W., Washington, D.C. 20036

NRC Project Director: B. J. Youngblood

151

B. J. Youngblood, Director  
PWR Project Directorate #4  
Division of PWR Licensing-A, NRR

DISTRIBUTION:

Docket File ←  
NRC PDR  
Local PDR  
PWR#4 Rdg  
MDuncan  
DWigginton  
BJYoungblood Rdg

*SW*  
PWR#4/DPWR-A  
DWigginton/mac  
06/4/86

*MD*  
PWR#4/DPWR-A  
MDuncan  
06/4/86

*PWOC*  
PWR#4/DPWR-A  
for BJYoungblood  
06/4/86