



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

MEMORANDUM FOR: Sholly Coordinator

FROM: B. J. Youngblood, Director  
PWR Project Directorate #4  
Division of PWR Licensing-A, NRR

SUBJECT: REQUEST FOR PUBLICATION IN BI-WEEKLY FR NOTICE - NOTICE OF  
ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE

Indiana and Michigan Electric Company, Docket Nos. 50-315 and 50-316, Donald C.  
Cook Nuclear Plant, Unit Nos. 1 and 2, Berrien County, Michigan.

Date of application for amendments: October 19, 1984 as supplemented by letter  
dated May 31, 1985, October 18, 1985, and February 7, 1986.

Brief description of amendments: The amendments (1) allow locked, sealed or  
secured valves, flanges and deactivated automatic valves, including some inside  
containment, to be verified as closed during cold shutdown on Unit 1; (2)  
delete a specific reference to a requirement for a cycling test every 92 days  
on containment isolation valves on Unit 1 and substitute a reference to  
measuring isolation times on containment isolation valves in accordance with  
applicable ASME Section XI requirements on Unit 1; (3) remove the column  
"Testable During Plant Operation" from Table 3.6-1 for Unit 1; (4) allow valves  
SM-8 and SM-10 (upper containment Grab Samples) to be opened intermittently  
under administrative controls during power operation on Unit 2; (5) correct  
valve designations in Table 3.6-1 inadvertently overlooked in Amendment 47 on  
Unit 2; and (6) remove a footnote on Table 3.6-1 which is no longer applicable  
for Units 1 and 2.

Date of issuance: April 23, 1986

Effective date: April 23, 1986

Amendment Nos.: 95 and 81

Facility Operating License Nos. DPR-58 and DPR-74. Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: December 31, 1984 (49 FR 50805)

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated April 23, 1986.

No significant hazards consideration comments received: No

Local Public Document Room location: Maude Reston Palenske Memorial Library,  
500 Market Street, St. Joseph, Michigan 49085.

*for Paul W O'Connor*  
B. J. Youngblood, Director  
PWR Project Directorate #4  
Division of PWR Licensing-A, NRR

Facility Operating License Nos. DPR-58 and DPR-74. Amendments revised the Technical Specifications.

Date of initial notice in Federal Register: December 31, 1984 (49 FR 50805)

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated 23 APR 1986

No significant hazards consideration comments received: No Yes

Local Public Document Room location: Maude Reston Palenske Memorial Library, 500 Market Street, St. Joseph, Michigan 49085.

151

B. J. Youngblood, Director  
PWR Project Directorate #4  
Division of PWR Licensing-A, NRR

DISTRIBUTION:

Docket File  
NRC PDR  
Local PDR  
PRC System  
NSIC  
PWR#4 Rdg  
MDuncan  
DWigginton  
BJYoungblood Rdg  
OELD

*MD*  
PWR#4/DPWR-A  
DWigginton/mac  
04/16/86

*MD*  
PWR#4/DPWR-A  
MDuncan  
04/16/86

*DSH*  
PWR#4/DPWR-A  
BJYoungblood  
04/16/86