

September 10, 1985

Docket Nos. 50-315
and 50-316

Mr. John Dolan, Vice President
Indiana and Michigan Electric Company
c/o American Electric Power Service Corporation
1 Riverside Plaza
Columbus, Ohio 43216

Dear Mr. Dolan:

On August 19, 1985, license Amendment Nos. 89 and 74 were issued for the Donald C. Cook Unit Nos. 1 and 2 to delete redundant requirements for environmental qualification. The Technical Specification pages contain an oversight in wording that had been previously approved by separate license amendment. The corrected pages are attached. Please excuse any inconvenience this may have caused.

Sincerely,

/s/DWigginton

David L. Wigginton, Project Manager
Operating Reactors Branch #1
Division of Licensing

Enclosure:
As stated

cc:
See next page

DISTRIBUTION

Docket File
ORB#1 Rdg
L PDR
PDR
Gray File
HThompson
OELD RBallard
DWigginton RDiggs
CParrish CMiles
XHarmon ACRS 10
EJordan MVirgilio
BGrimes WJones
JPartlow TBarnhart 8

*SEE PREVIOUS WHITE FOR CONCURRENCE

ORB#1:DL*
CParrish
9/9/85

ORB#1:DL*
DWigginton;ps
9/10/85

BC-ORB#1:DL
SVarga
9/10/85

8509170451 850910
PDR ADDOCK 05000315
P PDR

Docket Nos. 50-315
and 50-316

Mr. John Dolan, Vice President
Indiana and Michigan Electric Company
c/o American Electric Power Service Corporation
1 Riverside Plaza
Columbus, Ohio 43216

Dear Mr. Dolan:

On August 19, 1984, license Amendment Nos. 89 and 74 were issued for the Donald C. Cook Unit Nos. 1 and 2 to delete redundant requirements for environmental qualification. The affected Technical Specification pages contain an oversight in wording that was corrected by separate license amendment. The corrected pages are attached. Please excuse any inconvenience this may have caused.

Sincerely,

David L. Wigginton, Project Manager
Operating Reactors Branch #1
Division of Licensing

Enclosure:
As stated

cc:
See next page

DISTRIBUTION

Docket File

ORB#1 Rdg

L PDR

PDR

Gray File

HThompson

OELD

RBallard

DWigginton

RDiggs

CParrish

CMiles

LHarmon

ACRS 10

EJordan

MVirgilio

BGrimes

WJones

JPartlow

TBarnhart 8

ORB#1:DL
CParrish
9/2/85

DL
ORB#1:DL
DWigginton;ps
9/10/85

BC-ORB#1:DL
SVarga
9/ /85

Mr. John Dolan
Indiana and Michigan Electric Company

Donald C. Cook Nuclear Plant

cc:

Mr. M. P. Alexich
Vice President
Nuclear Operations
American Electric Power Service
Corporation
1 Riverside Plaza
Columbus, Ohio 43215

The Honorable John E. Grotberg
United States House of Representatives
Washington, DC 20515

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Attorney General
Department of Attorney General
525 West Ottawa Street
Lansing, Michigan 48913

J. Feinstein
American Electric Power
Service Corporation
1 Riverside Plaza
Columbus, Ohio 43216

Township Supervisor
Lake Township Hall
Post Office Box 818
Bridgman, Michigan 49106

W. G. Smith, Jr., Plant Manager
Donald C. Cook Nuclear Plant
Post Office Box 458
Bridgman, Michigan 49106

U.S. Nuclear Regulatory Commission
Resident Inspectors Office
7700 Red Arrow Highway
Stevensville, Michigan 49127

Gerald Charnoff, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, DC 20036

Mayor, City of Bridgeman
Post Office Box 366
Bridgman, Michigan 49106

Special Assistant to the Governor
Room 1 - State Capitol
Lansing, Michigan 48909

Nuclear Facilities and Environmental
Monitoring Section Office
Division of Radiological Health
Department of Public Health
3500 N. Logan Street
Post Office Box 30035
Lansing, Michigan 48909

ADMINISTRATIVE CONTROLS

6.10 RECORD RETENTION

6.10.1 The following records shall be retained for at least five years:

- a. Records and logs of unit operation covering time interval at each power level.
- b. Records and logs of principal maintenance activities, inspections, repair and replacement of principal items of equipment related to nuclear safety.
- c. All REPORTABLE EVENTS submitted to the Commission.
- d. Records of surveillance activities, inspections and calibrations required by these Technical Specifications.
- e. Records of changes made to the procedures required by Specification 6.8.1.
- f. Records of sealed source and fission detection leak tests and results.
- g. Records of annual physical inventory of all sealed source material on record.

6.10.2 The following records shall be retained for the duration of the Facility Operating License:

- a. Records and drawing changes reflecting unit design modifications made to systems and equipment described in the Final Safety Analysis Report.
- b. Records of new and irradiated fuel inventory, fuel transfer and assembly burnup histories.
- c. Records of radiation exposure for all individuals entering radiation control areas.
- d. Records of gaseous and liquid radioactive material released to the environs.
- e. Records of transient or operational cycles for those facility components identified in Table 5.9-1.
- f. Records of reactor tests and experiments.
- g. Records of training and qualification for current members of the Plant staff.
- h. Records of in-service inspections performed pursuant to these Technical Specifications.
- i. Records of Quality Assurance activities required by the QA Manual.
- j. Records of reviews performed for changes made to procedures or equipment or review of tests and experiments pursuant to 10 CFR 50.59.
- k. Records of meetings of the PNSRC and the NSDRC.
- l. Records of radioactive shipments.
- m. Records of the service lives of hydraulic snubbers listed on Table 3.7-4 including the date at which service life commences and associated installation and maintenance records.

B509170453 B50910
PDR ADOCK 05000315
P PDR

ADMINISTRATIVE CONTROLS

6.10 RECORD RETENTION

6.10.1 The following records shall be retained for at least five years:

- a. Records and logs of unit operation covering time interval at each power level.
- b. Records and logs of principal maintenance activities, inspections, repair and replacement of principal items of equipment related to nuclear safety.
- c. All REPORTABLE EVENTS submitted to the Commission.
- d. Records of surveillance activities, inspections and calibrations required by these Technical Specifications.
- e. Records of changes made to the procedures required by Specification 6.8.1.
- f. Records of sealed source and fission detection leak tests and results.
- g. Records of annual physical inventory of all sealed source material on record.

6.10.2 The following records shall be retained for the duration of the Facility Operating License:

- a. Records and drawing changes reflecting unit design modifications made to systems and equipment described in the Final Safety Analysis Report.
- b. Records of new and irradiated fuel inventory, fuel transfer and assembly burnup histories.
- c. Records of radiation exposure for all individuals entering radiation control areas.
- d. Records of gaseous and liquid radioactive material released to the environs.
- e. Records of transient or operational cycles for those facility components identified in Table 5.7-1.
- f. Records of reactor tests and experiments.
- g. Records of training and qualification for current members of the Plant staff.
- h. Records of in-service inspections performed pursuant to these Technical Specifications.
- i. Records of Quality Assurance activities required by the QA Manual.
- j. Records of reviews performed for changes made to procedures or equipment or review of tests and experiments pursuant to 10 CFR 50.59.
- k. Records of meetings of the PNSRC and the NSDRC.
- l. Records of radioactive shipments.
- m. Records of the service lives of hydraulic snubbers listed on Table 3.7-9 including the date at which service life commences and associated installation and maintenance records.