

JUN 02 1987

Docket Nos. 50-315
and 50-316

Mr. John Dolan, Vice President
Indiana and Michigan Electric Company
c/o American Electric Power Service Corporation
1 Riverside Plaza
Columbus, Ohio 43216

Dear Mr. Dolan:

SUBJECT: WITHDRAWAL OF TECHNICAL SPECIFICATION CHANGE REQUEST

The Indiana and Michigan Electric Company, by letter dated May 15, 1987, withdrew its application for changes to the Technical Specifications for the Donald C. Cook Nuclear Plant, Unit Nos. 1 and 2. The amendment would have revised the Technical Specifications by adding a provision to allow two-plant operation with three out of four Essential Service Water (ESW) pumps operational and the two plants' ESW systems aligned in the cross-tie mode.

We concur in the withdrawal of this request. A copy of the Notice of Withdrawal is enclosed. The notice has been forwarded to the Office of the Federal Register for publication.

Sincerely,

/s/

David L. Wigginton, Project Manager
Project Directorate III-3
Division of Reactor Projects

Enclosure:
As stated

cc: See next page

Office: LA/PDIII-3
Surname: *PK* Preutzer
Date: *05/1* /87

DLW
PD/PDIII-3
DWigginton/tg
05/2 /87

8706120241 870602
PDR ADDOCK 05000315
P PDR

Mr. John Dolan
Indiana and Michigan Electric Company

Donald C. Cook Nuclear Plant

cc:

Mr. M. P. Alexich
Vice President
Nuclear Operations
American Electric Power Service
Corporation
1 Riverside Plaza
Columbus, Ohio 43215

Region Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

J. Feinstein
American Electric Power
Service Corporation
1 Riverside Plaza
Columbus, Ohio 43216

Attorney General
Department of Attorney General
525 West Ottawa Street
Lansing, Michigan 48913

Township Supervisor
Lake Township Hall
Post Office Box 818
Bridgeman, Michigan 49106

W. G. Smith, Jr., Plant Manager
Donald C. Cook Nuclear Plant
Post Office Box 458
Bridgman, Michigan 49106

U.S. Nuclear Regulatory Commission
Resident Inspectors Office
7700 Red Arrow Highway
Stevensville, Michigan 49127

Gerald Charnoff, Esquire
Shaw, Pittman, Potts and Trowbridge
2300 N Street, N.W.
Washington, DC 20037

Mayor, City of Bridgeman
Post Office Box 366
Bridgeman, Michigan 49106

Special Assistant to the Governor
Room 1 - State Capitol
Lansing, Michigan 48909

Nuclear Facilities and Environmental
Monitoring Section Office
Division of Radiological Health
Department of Public Health
3500 N. Logan Street
Post Office Box 30035
Lansing, Michigan 48909

UNITED STATES NUCLEAR REGULATORY COMMISSION
INDIANA AND MICHIGAN ELECTRIC COMPANY
DOCKET NOS. 50-315 AND 50-316
NOTICE OF WITHDRAWAL OF APPLICATION FOR
AMENDMENTS TO FACILITY OPERATING LICENSES

The U. S. Nuclear Regulatory Commission (the Commission) has granted the request of Indiana and Michigan Electric Company for withdrawal of an application for amendment to Facility Operating License Nos. DPR-58 and DPR-74 for the Donald C. Cook Nuclear Plant, Unit Nos. 1 and 2, located in Berrien County, Michigan. The Commission issued a notice of consideration of issuance of amendment which was published in the FEDERAL REGISTER on February 12, 1986 (51 FR 5274). The amendment would have revised the Technical Specifications by adding a provision to allow two-plant operation with three out of four Essential Service Water (ESW) pumps operational and the two plants' ESW systems aligned in the cross-tie mode. By letter dated May 15, 1987, the licensee withdrew its application for the proposed amendment.

For further details with respect to this action, see (1) the application for amendment dated January 17, 1986, (2) the licensee's letter dated May 15, 1987 withdrawing the application for amendment, and (3) the Commission's letter granting the withdrawal dated June 2, 1987. All of the above documents are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C. and at the Maude Preston Palenske Memorial Library, 500 Market Street, St. Joseph, Michigan 49085.

Dated at Bethesda, Maryland, this 2nd day of June, 1987.

FOR THE NUCLEAR REGULATORY COMMISSION


David L. Wigginton, Project Manager
Project Directorate III-3
Division of Reactor Projects

8706120150XA

Distribution Copies:

Docket Files

NRC PDR

Local PDR

PDIII-3 r/f

PDIII-3 p/f

GHolahan

PKreutzer

DWigginton

OGC-Bethesda

DHagan

EJordan

JPartlow

TBarnhart (4)

WandaJones

EButcher

ACRS (10)

GPA/PA

ARM/LFMB