

December 30 1994

MEMORANDUM TO: Sholly Coordinator

FROM: John B. Hickman, Project Manager
Project Directorate III-1
Division of Reactor Projects - III/IV

SUBJECT: REQUEST FOR PUBLICATION IN BIWEEKLY FR NOTICE - NOTICE OF
ISSUANCE OF AMENDMENTS TO FACILITY OPERATING LICENSES
(TAC NOS. M88266 AND M88267)

Indiana Michigan Power Company, Docket Nos. 50-315 and 50-316, Donald C.

Cook Nuclear Plant, Unit Nos. 1 and 2, Berrien County, Michigan

Date of application for amendments: November 15, 1993

Brief description of amendments: The amendments make various
administrative and editorial changes to the Technical Specifications.

Date of issuance: December 30, 1994

Effective date: December 30, 1994

Amendment Nos.: 186 and 172

Facility Operating License Nos. DPR-58 and DPR-74. Amendments revised the
Technical Specifications.

Date of initial notice in FEDERAL REGISTER: December 22, 1993 (58 FR
67849)

The Commission's related evaluation of the amendments is contained in a
Safety Evaluation dated December 30, 1994.

No significant hazards consideration comments received: No.

Local Public Document Room location: Maud Preston Palenske Memorial
Library, 500 Market Street, St. Joseph, Michigan 49085.

DISTRIBUTION

Docket File
PD31 Rdg File
JHickman

CJamerson
OGC
Sholly Coord.

FILENAME: G:\WPDOCS\DCCOOK\C088266.BWI

OFFICE	LA:PD31	PM:PD31	OGC	D:PD31
NAME	CJamerson	JHickman	JNHannon	
DATE	12/11/94	12/11/94	12/12/94	12/12/94

OFFICIAL RECORD COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 186 TO FACILITY OPERATING LICENSE NO. DPR-58
AND AMENDMENT NO. 172 TO FACILITY OPERATING LICENSE NO. DPR-74

INDIANA MICHIGAN POWER COMPANY

DONALD C. COOK NUCLEAR PLANT, UNIT NOS. 1 AND 2

DOCKET NOS. 50-315 AND 50-316

1.0 INTRODUCTION

By letter dated November 15, 1993, the Indiana Michigan Power Company (the licensee) requested amendments to the Technical Specifications (TS) appended to Facility Operating License Nos. DPR-58 and DPR-74 for the Donald C. Cook Nuclear Plant, Unit Nos. 1 and 2. The proposed amendments would make various administrative or editorial changes. The changes are intended to correct various oversights or errors in the TS, or to update the TS to reflect current plant conditions.

2.0 EVALUATION

The TS changes requested by the licensee address 13 separate items, each of which is evaluated below.

2.01 ERRONEOUS DESCRIPTION OF OPERATOR ACTION FOR ROLLUP DOORS

In Amendment Numbers 124 and 111, for D.C. Cook Units 1 and 2, respectively, dated May 19, 1989, a footnote was added to TS 3.9.12 to allow the crane bay roll-up door and the drumming room roll-up door to be opened under administrative control during movement of fuel within the storage pool or crane operation with loads over the storage pool. As part of this change, an example of appropriate administrative controls was added to the bases. However, this example states that an individual could be stationed at the door to open it in the event of an emergency. This wording is contrary to the actual intended function of stationing an individual for compensatory action. As stated in the Safety Evaluation for Amendments 124 and 111, "... the person stationed at the crane bay door would be in communication with personnel in the spent fuel pool area so that he would be readily informed of an emergency and, if needed, actuate the door closure mechanism." Since the purpose of stationing an individual at the door would be to close the door to prevent radioactive gases from escaping through the door, the licensee has proposed to revise the wording in the bases to correctly reflect that. Based on the above, the proposed change is acceptable.

10055
9501090349

10055 10055 COPY

2001 1/1

December 30, 1994

Mr. E. E. Fitzpatrick, Vice President
Indiana Michigan Power Company
c/o American Electric Power Service Corporation
1 Riverside Plaza
Columbus, Ohio 43215

SUBJECT: DONALD C. COOK NUCLEAR PLANT, UNIT NOS. 1 AND 2 - ISSUANCE OF
AMENDMENT RE: ADMINISTRATIVE AND EDITORIAL CHANGES (TAC NOS. M88266
AND M88267)

Dear Mr. Fitzpatrick:

The Commission has issued the enclosed Amendment No. 186 to Facility Operating License No. DPR-58 and Amendment No. 172 to Facility Operating License No. DPR-74 for the Donald C. Cook Nuclear Plant, Unit Nos. 1 and 2. The amendments consist of changes to the Technical Specifications in response to your application dated November 15, 1993.

The amendments make various administrative and editorial changes to the Technical Specifications.

A copy of our related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Original signed by

John B. Hickman, Project Manager
Project Directorate III-1
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Docket Nos. 50-315
and 50-316

Enclosures: 1. Amendment No. 186 to DPR-58
2. Amendment No. 172 to DPR-74
3. Safety Evaluation

cc w/encl: See next page

DOCUMENT NAME: G:\WPDOCS\DCCOOK\C088266.AMD

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	LA:PD31	PM:PD31	BC:SPLB	BC:SRXB	OGC	D:PD31
NAME	CJamerson	JHickman	CMcCracken	RJones	R.Bachman	JHannon
DATE	12/1/94	12/1/94	12/6/94	12/6/94	12/10/94	12/12/94

OFFICIAL RECORD COPY

9501090343

DATED: December 30, 1994

AMENDMENT NO. 186 TO FACILITY OPERATING LICENSE NO. DPR-58-D. C. COOK-UNIT 1
AMENDMENT NO. 172 TO FACILITY OPERATING LICENSE NO. DPR-74-D. C. COOK-UNIT 2

Docket File

PUBLIC

PDIII-1 Reading

J. Roe

C. Jamerson

J. Hannon

J. Hickman (2)

C. McCracken

R. Jones

OGC-WF

G. Hill (4)

C. Grimes, O-11F23

ACRS (4)

OPA

OC/LFDCB

W. Kropp, RIII

SEDB

PLEASE NOTE:

THE FOLLOWING PAGES ARE BEING REISSUED
TO CORRECT THE UNIT 1 AMENDMENT NUMBER.
PLEASE REPLACE THE PREVIOUS PAGES
WITH THE CORRECTED PAGES. SORRY FOR
ANY INCONVENIENCE.

THANK YOU!

cc: Plant Service list