

August 3, 1990

Docket Nos. 50-315
and 50-316

DISTRIBUTION:

Docket Files	DHagan
NRC PDR	EJordan
Local PDR	PD31 R/F
GHill(8)	OGC
Wanda Jones	ARM/LFMB
JZwolinski	EButcher
TColburn	GPA/PA
MRSuttleworth	ACRS(10)

Mr. Milton P. Alexich, Vice President
Indiana Michigan Power Company
c/o American Electric Power Service Corporation
1 Riverside Plaza
Columbus, Ohio 43216

Dear Mr. Alexich:

SUBJECT: AMENDMENT NOS.143 AND 130 TO FACILITY OPERATING LICENSE NOS. DPR-58
AND DPR-74: (TAC NOS. 75979 AND 75980)

The Commission has issued the enclosed Amendment No.143 to Facility Operating License No. DPR-58 and Amendment No.130 to Facility Operating License No. DPR-74 for the Donald C. Cook Nuclear Plant, Unit Nos. 1 and 2. The amendments consist of changes to the Technical Specifications in response to your application dated February 7, 1990.

These amendments modify Technical Specification (TS) 4.0.2 in accordance with guidance provided in Generic Letter 89-14, "Line Item Improvements in Technical Specifications - Removal of the 3.25 Limit on Extending Surveillance Intervals." The amendments remove the 3.25 limit for the extension of 3 consecutive surveillance intervals. The surveillance intervals will still be constrained by the 25 percent interval extension criteria of TS 4.0.2.

A copy of our related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

/s/

Timothy Colburn, Project Manager
Project Directorate III-1
Division of Reactor Projects - III,
IV, V & Special Projects
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 143 to DPR-58
2. Amendment No. 130 to DPR-74
3. Safety Evaluation

cc w/enclosures:
See next page

See previous concurrence* *TC*

LA/PD31:DRSP*
MRShuttleworth
06/18/90

PM/PD31:DRSP
TColburn
08/2/90

(A)D/PD31:DRSP
RPierson
06/19/90

OGC
06/20/90

CP-1

DF
11



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

August 3, 1990

Docket Nos. 50-315
and 50-316

Mr. Milton P. Alexich, Vice President
Indiana Michigan Power Company
c/o American Electric Power Service Corporation
1 Riverside Plaza
Columbus, Ohio 43216

Dear Mr. Alexich:

SUBJECT: AMENDMENT NOS. 143 AND 130 TO FACILITY OPERATING LICENSE NOS. DPR-58
AND DPR-74: (TAC NOS. 75979 AND 75980)

The Commission has issued the enclosed Amendment No. 143 to Facility Operating License No. DPR-58 and Amendment No. 130 to Facility Operating License No. DPR-74 for the Donald C. Cook Nuclear Plant, Unit Nos. 1 and 2. The amendments consist of changes to the Technical Specifications in response to your application dated February 7, 1990.

These amendments modify Technical Specification (TS) 4.0.2 in accordance with guidance provided in Generic Letter 89-14, "Line Item Improvements in Technical Specifications - Removal of the 3.25 Limit on Extending Surveillance Intervals." The amendments remove the 3.25 limit for the extension of 3 consecutive surveillance intervals. The surveillance intervals will still be constrained by the 25 percent interval extension criteria of TS 4.0.2.

A copy of our related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Timothy A. Colburn
Timothy Colburn, Project Manager
Project Directorate III-1
Division of Reactor Projects - III,
IV, V & Special Projects
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 143 to DPR-58
2. Amendment No. 130 to DPR-74
3. Safety Evaluation

cc w/enclosures:
See next page

Mr. Milton Alexich
Indiana Michigan Power Company

Donald C. Cook Nuclear Plant

CC:
Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Mr. S. Brewer
American Electric Power
Service Corporation
1 Riverside Plaza
Columbus, Ohio 43216

Attorney General
Department of Attorney General
525 West Ottawa Street
Lansing, Michigan 48913

Township Supervisor
Lake Township Hall
Post Office Box 818
Bridgman, Michigan 49106

Al Blind, Plant Manager
Donald C. Cook Nuclear Plant
Post Office Box 458
Bridgman, Michigan 49106

U.S. Nuclear Regulatory Commission
Resident Inspectors Office
7700 Red Arrow Highway
Stevensville, Michigan 49127

Gerald Charnoff, Esquire
Shaw, Pittman, Potts and Trowbridge
2300 N Street, N.W.
Washington, DC 20037

Mayor, City of Bridgman
Post Office Box 366
Bridgman, Michigan 49106

Special Assistant to the Governor
Room 1 - State Capitol
Lansing, Michigan 48909

Nuclear Facilities and Environmental
Monitoring Section Office
Division of Radiological Health
Department of Public Health
3500 N. Logan Street
Post Office Box 30035
Lansing, Michigan 48909



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

INDIANA MICHIGAN POWER COMPANY

DOCKET NO. 50-315

DONALD C. COOK NUCLEAR PLANT, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 143
License No. DPR-58

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Indiana Michigan Power Company (the licensee) dated February 7, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-74 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 143, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Timothy H. Colburn

Robert Pierson, Director *for*
Project Directorate III-1
Division of Reactor Projects - III,
IV, V & Special Projects
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 3, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 143

FACILITY OPERATING LICENSE NO. DPR-58

DOCKET NO. 50-315

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the attached pages. The revised pages are identified by amendment number and contain marginal lines indicating the area of change.

REMOVE

3/4 0-2

B 3/4 0-4

INSERT

3/4 0-2

B 3/4 0-4

3/4.0 APPLICABILITY

SURVEILLANCE REQUIREMENTS

4.0.1 Surveillance requirements shall be applicable during the OPERATIONAL MODES or other conditions specified for individual Limiting Conditions for Operation unless otherwise stated in an individual Surveillance Requirement.

4.0.2 Each Surveillance Requirement shall be performed within the specified time interval with a maximum allowable extension not to exceed 25% of the specified surveillance interval.

4.0.3 Performance of a Surveillance Requirement within the specified time interval shall constitute compliance with OPERABILITY requirements for a Limiting Condition for Operation and associated ACTION statements unless otherwise required by the specification. Surveillance requirements do not have to be performed on inoperable equipment.

4.0.4 Entry into an OPERATIONAL MODE or other specified applicability condition shall not be made unless the Surveillance Requirement(s) associated with the Limiting Condition for Operation have been performed within the stated surveillance interval or as otherwise specified.

4.0.5 Surveillance Requirements for inservice inspection and testing of ASME Code Class 1, 2, and 3 components shall be applicable as follows:

- a. Inservice inspection of ASME Code Class 1, 2, and 3 components and inservice testing of ASME Code Class 1, 2 and 3 pumps and valves shall be performed in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR 50, Section 50.55a(g), except where specific written relief has been granted by the Commission pursuant to 10 CFR 50, Section 50.55a(g)(6)(1).

APPLICABILITY
BASES

4.0.1 This specification provides that surveillance activities necessary to insure the Limiting Conditions for Operation are met and will be performed during the OPERATIONAL MODES or other conditions for which the Limiting Conditions for Operation are applicable. Provisions for additional surveillance activities to be performed without regard to the applicable OPERATIONAL MODES or other conditions are provided in the individual Surveillance Requirements.

4.0.2 This specification establishes the limit for which the specified time interval for Surveillance Requirements may be extended. It permits an allowable extension of the normal surveillance interval to facilitate surveillance scheduling and consideration of plant operating conditions that may not be suitable for conducting the surveillance, e.g., transient conditions or other ongoing surveillance or maintenance activities. It also provides flexibility to accommodate the length of a fuel cycle for surveillances that are performed at each refueling outage and are specified with an 18-month surveillance interval. It is not intended that this provision be used repeatedly as a convenience to extend surveillance intervals beyond that specified for surveillances that are not performed during refueling outages. The limitation of Specification 4.0.2 is based on engineering judgment and the recognition that the most probable result of any particular surveillance being performed is the verification of conformance with the Surveillance Requirements. This provision is sufficient to ensure that the reliability ensured through surveillance activities is not significantly degraded beyond that obtained from the specified surveillance interval.

4.0.3 The provisions of this specification set forth the criteria for determination of compliance with the OPERABILITY requirements of the Limiting Conditions for Operation. Under this criteria, equipment, systems or components are assumed to be OPERABLE if the associated surveillance activities have been satisfactorily performed within the specified time interval. Nothing in this provision is to be construed as defining equipment, systems or components OPERABLE, when such items are found or known to be inoperable although still meeting the Surveillance Requirements.

4.0.4 This specification ensures that the surveillance activities associated with a Limiting Condition for Operation have been performed within the specified time interval prior to entry into an OPERATIONAL MODE or other applicable condition. The intent of this provision is to ensure that surveillance activities have been satisfactorily demonstrated on a current basis as required to meet the OPERABILITY requirements of the Limiting Condition for Operation.

Under the terms of this specification, for example, during initial plant startup or following extended plant outages, the applicable surveillance activities must be performed within the stated surveillance interval prior to placing or returning the system or equipment into OPERABLE status.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

INDIANA MICHIGAN POWER COMPANY

DOCKET NO. 50-316

DONALD C. COOK NUCLEAR PLANT, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 130
License No. DPR-74

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Indiana Michigan Power Company (the licensee) dated February 7, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-58 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 130, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Robert Pierson, Director *for*
Project Directorate III-1
Division of Reactor Projects - III,
IV, V & Special Projects
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 3, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 130

FACILITY OPERATING LICENSE NO. DPR-74

DOCKET NO. 50-316

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the attached pages. The revised pages are identified by amendment number and contain marginal lines indicating the area of change.

REMOVE

3/4 0-2

B 3/4 0-3

INSERT

3/4 0-2

B 3/4 0-3

3/4.0 APPLICABILITY

SURVEILLANCE REQUIREMENTS

4.0.1 Surveillance Requirements shall be applicable during the OPERATIONAL MODES or other conditions specified for individual Limiting Conditions for Operation unless otherwise stated in an individual Surveillance Requirement.

4.0.2 Each Surveillance Requirement shall be performed within the specified time interval with a maximum allowable extension not to exceed 25% of the specified surveillance interval.

4.0.3 Performance of a Surveillance Requirement within the specified time interval shall constitute compliance with OPERABILITY requirements for a Limiting Condition for Operation and associated ACTION statements unless otherwise required by the specification. Surveillance requirements do not have to be performed on inoperable equipment.

4.0.4 Entry into an OPERATIONAL MODE or other specified applicability condition shall not be made unless the Surveillance Requirement(s) associated with the Limiting Condition for Operation have been performed within the stated surveillance interval or as otherwise specified.

4.0.5 Surveillance Requirements for inservice inspection and testing of ASME Code Class 1, 2, and 3 components shall be applicable as follows:

- a. Inservice inspection of ASME Code Class 1, 2, and 3 components and inservice testing of ASME Code Class 1, 2 and 3 pumps and valves shall be performed in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR 50, Section 50.55a(g), except where specific written relief has been granted by the Commission pursuant to 10 CFR 50, Section 50.55a(g)(6)(i).

APPLICABILITY

BASES

3.0.5 (Continued)

consistent with the ACTION statement for the inoperable normal power sources instead, provided the other specified conditions are satisfied. In this case, this would mean that for one division the emergency power source must be OPERABLE (as must be the components supplied by the emergency power source) and all redundant systems, subsystems, trains, components and devices in the other division must be OPERABLE, or likewise satisfy Specification 3.0.5 (i.e., be capable of performing their design functions and have an emergency power source OPERABLE). In other words, both emergency power sources must be OPERABLE and all redundant systems, subsystems, trains, components and devices in both divisions must also be OPERABLE. If these conditions are not satisfied, action is required in accordance with this specification.

In MODES 5 or 6, Specification 3.0.5 is not applicable, and thus the individual ACTION statements for each applicable Limiting Condition for Operation in these MODES must be adhered to.

4.0.1 This specification provides that surveillance activities necessary to insure the Limiting Conditions for Operation are met and will be performed during the OPERATIONAL MODES or other conditions for which the Limiting Conditions for Operation are applicable. Provisions for additional surveillance activities to be performed without regard to the applicable OPERATIONAL MODES or other conditions are provided in the individual Surveillance Requirements.

4.0.2 This specification establishes the limit for which the specified time interval for Surveillance Requirements may be extended. It permits an allowable extension of the normal surveillance interval to facilitate surveillance scheduling and consideration of plant operating conditions that may not be suitable for conducting the surveillance, e.g., transient conditions or other ongoing surveillance or maintenance activities. It also provides flexibility to accommodate the length of a fuel cycle for surveillances that are performed at each refueling outage and are specified with an 18-month surveillance interval. It is not intended that this provision be used repeatedly as a convenience to extend surveillance intervals beyond that specified for surveillances that are not performed during refueling outages. The limitation of Specification 4.0.2 is based on engineering judgment and the recognition that the most probable result of any particular surveillance being performed is the verification of conformance with the Surveillance Requirements. This provision is sufficient to ensure that the reliability ensured through surveillance activities is not significantly degraded beyond that obtained from the specified surveillance interval.

4.0.3 The provisions of this specification set forth the criteria for determination of compliance with the OPERABILITY requirements of the Limiting Conditions for Operation. Under this criteria, equipment, systems or components are assumed to be OPERABLE if the associated surveillance activities have been satisfactorily performed within the specified time interval. Nothing in this provision is to be construed as defining equipment, systems or components OPERABLE, when such items are found or known to be inoperable although still meeting the Surveillance Requirements.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO.143 TO FACILITY OPERATING LICENSE NO. DPR-58
AND AMENDMENT NO.130 TO FACILITY OPERATING LICENSE NO. DPR-74

INDIANA MICHIGAN POWER COMPANY

DONALD C. COOK NUCLEAR PLANT, UNITS NOS. 1 AND 2

DOCKETS NOS. 50-315 AND 50-316

1.0 INTRODUCTION

By letter dated February 7, 1990, Indiana Michigan Power Company (the licensee) proposed changes to the Technical Specifications (TS) for the D. C. Cook Nuclear Plant, Unit Nos. 1 and 2. The proposed change removes the provision of Specification 4.0.2 that limits the combined time interval for three consecutive surveillances to less than 3.25 times the specified interval. Guidance on this proposed change to TS was provided to all power reactor licensees and applicants by Generic Letter 89-14, dated August 21, 1989.

2.0 EVALUATION

Specification 4.0.2 includes the provision that allows a surveillance interval to be extended by 25 percent of the specified time interval. This extension provides flexibility for scheduling the performance of surveillances and to permit consideration of plant operating conditions that may not be suitable for conducting a surveillance at the specified time interval. Such operating conditions include transient plant operation or ongoing surveillance or maintenance activities. Specification 4.0.2 further limits the allowance for extending surveillance intervals by requiring that the combined time interval for any three consecutive surveillances not exceed 3.25 times the specified time interval. The purpose of this provision is to assure that surveillances are not extended repeatedly as an operational convenience to provide an overall increase in the surveillance interval.

Experience has shown that the 18-month surveillance interval, with the provision to extend it by 25 percent, is usually sufficient to accommodate normal variations in the length of a fuel cycle. However, the NRC staff has routinely granted requests for one-time exceptions to the 3.25 limit on extending refueling surveillances because the risk of safety is low in contrast to the alternative of a forced shutdown to perform these surveillances. Therefore, the 3.25 limitation on extending surveillances has not been a practical limit on the use of the 25 percent allowance for extending surveillances that are performed on a refueling outage basis.

Extending surveillance intervals during plant operation can also result in a benefit to safety when a scheduled surveillance is due at a time that is not suitable for conducting the surveillance. This may occur when transient plant operating conditions exist or when safety systems are out of service for maintenance or other surveillance activities. In such cases, the benefit to safety of extending a surveillance interval would exceed any safety benefit derived by limiting the use of the 25 percent allowance to extend a surveillance. Furthermore, there is the administrative burden associated with tracking the use of the 25 percent allowance to ensure compliance with the 3.25 limit.

In view of these findings, the staff concluded that Specification 4.0.2 should be changed to remove the 3.25 limit for all surveillances because its removal will have an overall positive effect on safety. The guidance provided in Generic Letter 89-14 included the following change to this specification and removes the 3.25 limit on three consecutive surveillance with the following statement:

"4.0.2 Each Surveillance Requirement shall be performed within the specified surveillance interval with a maximum allowable extension not to exceed 25 percent of the specified surveillance interval."

In addition, the Bases of this specification were updated to reflect this change and noted that it is not the intent of the allowance for extending surveillance intervals that is to be used repeatedly merely as an operational convenience to extend surveillance intervals beyond that specified.

The licensee has proposed changes to Specification 4.0.2 that are consistent with the guidance provided in Generic Letter 89-14, as noted above. On the basis of its review of this matter, the staff finds that the above changes to the TS for the Donald C. Cook Nuclear Plant Units 1 and 2 are acceptable.

3.0 ENVIRONMENTAL CONSIDERATION

These amendments involve changes in a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and changes in a surveillance requirement. We have determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that these amendments involve no significant hazards consideration and there has been no public comment on such finding. Accordingly, these amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of these amendments.

4.0 CONCLUSION

We have concluded, based on the considerations discussed above, that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Date: August 3, 1990

Principal Contributor: Thomas G. Dunning, OTSB/DOEA