

April 18, 2002

NOTICE OF SIGNIFICANT LICENSEE MEETING

THIS MEETING IS OPEN TO PUBLIC ATTENDANCE

Name of Licensee: Nuclear Management Company, LLC

Name of Facility: Point Beach Nuclear Plant

EA No: EA-02-031

Docket Nos: 50-266; 50-301

Date and Time of Meeting: Monday, April 29, 2002
9:00 a.m. - 12:00 p.m. (CDT)
10:00 a.m. - 1:00 p.m. (EDT)

Location of Meeting: U. S. Nuclear Regulatory Commission
Region III
801 Warrenville Road
Lisle, IL 60532-4351

Video Conference Location: U. S. Nuclear Regulatory Commission
Room O-3B4, One White Flint North
11555 Rockville Pike
Rockville, MD 20852-2738

Purpose of Meeting: To discuss the preliminary Red finding concerning the potential common mode failure of auxiliary feedwater at the Point Beach Nuclear Plant. The finding involved inadequate procedural guidance for addressing loss of instrument air to the auxiliary feedwater pump recirculation valves. NRC inspection findings are evaluated with a four step assessment of their safety significance, ranging from "Green" for a finding of minor significance, through "White" and "Yellow" to "Red," for a finding of high safety significance.

Notice of Significant
Licensee Meeting

-2-

NRC Attendees:

M. Johnson, Chief, Probabilistic Safety Assessment Branch, NRR
C. Carpenter, Chief, Inspection Program Branch, NRR
J. Dyer, Regional Administrator
J. Caldwell, Deputy Regional Administrator
J. Grobe, Director, Division of Reactor Safety
G. Grant, Director, Division of Reactor Projects
J. Jacobson, Chief, Mechanical Engineering Branch
R. Langstaff, Reactor Inspector, Mechanical Engineering Branch
Others as designated

Licensee Attendees:

Roy Anderson, Chief Nuclear Officer
John Paul Cowan, Senior Vice President - Operations
Mark Warner, Site Vice President, Kewaunee
and Point Beach Nuclear Plants

Others as designated

NOTE: Attendance at this meeting by NRC personnel, other than those listed above, should be made known to Ron Langstaff at (630) 829-9747 by COB April 26, 2002.

/RA by Roy Caniano Acting For/

Approved by: _____
John A. Grobe, Director
Division of Reactor Safety

Distribution:

F. Congel, Director, Office of Enforcement
J. Dixon-Herrity, Office of Enforcement
D. Dambly, Assistant General Counsel for Material Litigation and Enforcement, OGC
B. W. Sheron, Associate Director for Projects Licensing and Technical Review, NRR
J. Zwolinski, Director, Division of Licensing and Project Management, NRR
M. Banerjee, NRR
G. Tracy, Chief, Division of Inspection Program Management, IOLB, NRR
H. Nieh, Region III Coordinator, OEDO
S. Bajwa, Project Directorate, Division of Licensing and Project Management, NRR
B. Wetzel, Project Manager, Project Directorate, Division of Licensing and
Project Management, NRR
D. Spaulding, Acting Project Manager, Project Directorate, Division of Licensing and
Project Management, NRR
G. E. Grant, Director, Division of Reactor Projects, RIII
S. A. Reynolds, Deputy Director, Division of Reactor Projects, RIII
J. A. Grobe, Director, Division of Reactor Safety, RIII
R. J. Caniano, Deputy Director, Division of Reactor Safety, RIII
DRP Branch Chief
P. Krohn, SRI, Point Beach
DRS Branch Chiefs (RNG, DEH, JMJ3, WJS2)
B. Clayton, Enforcement/Investigations Officer, RIII
R. M. Lickus, State Liaison Officer, RIII
PMNS
RIII Public Affairs (RJS2; VTM)
J. Kweiser, ORA
P. Buckley, ORA
OEMAIL
OEWEB