

AmerGen Energy Company, LLC 200 Exelon Way Suite 345 Kennett Square, PA 19348

www.exeloncorp.com

An Exelon/British Energy Company

10 CFR 50.90

April 8, 2002 2130-02-20107

U.S. Nuclear Regulatory Commission

Attn: Document Control Desk Washington, DC 20555-0001

Subject:

Additional Information - Technical Specification Change Request No. 294

Cycle-Specific Safety Limit MCPR (TAC No. MB2891)

Oyster Creek Generating Station (Oyster Creek)

Facility Operating License No. DPR-16

NRC Docket No. 50-219

This letter confirms the additional information as discussed in a conference call with NRC technical staff on March 28, 2002.

Technical Specification Change Request No. 294 to delete the cycle-specific footnote for the Safety Limit Minimum Critical Power Ratio (SLMCPR) will apply to the next operating cycle (Cycle 19). A separate Technical Specification Change Request submittal will be provided if a change is required for the Cycle 19 SLMCPR value. The Cycle 19 SLMCPR analysis will be based on the original GETAB approach as referenced in GESTAR II. Oyster Creek is currently operating with GE9 fuel. Cycle 19 will be introducing GE11 fuel and Oyster Creek has no plans to operate Cycle 19 with GE14 fuel.

No new regulatory commitments are established by this submittal. If any additional information is needed, please contact David J. Distel (610) 765-5517.

I declare under penalty of perjury that the foregoing is true and correct.

Very truly yours,

Michael P. Gallagher

Director, Licensing & Regulatory Affairs Mid-Atlantic Regional Operating Group

cc: H. J. Miller, USNRC Administrator, Region I

P. S. Tam, USNRC Senior Project Manager, Oyster Creek

L. A. Dudes, USNRC Senior Resident Inspector, Oyster Creek

File No. 01073