

SEP 10 1982

DISTRIBUTION:

Docket File WJones, QA
LB#2 File BPCotter, ASLBP
ABournia ARosenthal, ASLAP
EHylton
ACRS (16)
I&E
Region III
ASchwencer
Woodhead, OELD
DEisenhut/RPurple

Docket No.: 50-373

Mr. Louis O. DelGeorge
Director of Nuclear Licensing
Commonwealth Edison Company
P. O. Box 767
Chicago, Illinois 60690

JSouder
I&E
MPA
TBarthart (4)
WMiller
IDinitz

Dear Mr. DelGeorge:

Subject: Amendment No. 6 to Facility Operating License No. NPF-11 -
La Salle County Station, Unit 1

By letter dated September 7, 1982, the Commission issued Amendment No. 6 to Facility Operating License No. NPF-11 for La Salle County Station, Unit 1. This Amendment granted the operation of the shared radwaste treatment system to utilize Unit 2 service water system.

In the Amendment, the changed page 3/4 3-82 to the Technical Specifications was inadvertently missing. Enclosed is the missing page 3/4 3-82 to be inserted into the Technical Specifications.

Sincerely,

A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing

Enclosure:
As stated

cc: See next page

B209280158 B20910
PDR ADOCK 05000373
P PDR

OFFICE	DL:LB#2/PM AS	DL:CB#2/BC	DL:LB#2/LA				
SURNAME	ABournia:pt	ASchwencer	ogk				
DATE	9/10/82	9/10/82	9/10/82				

La Salle

Mr. Louis O. DelGeorge
Director of Nuclear Licensing
Commonwealth Edison Company
P. O. Box 767
Chicago, Illinois 60690

cc: Philip P. Steptoe, Esquire
Suite 4200
One First National Plaza
Chicago, Illinois 60603

Dean Hansell, Esquire
Assistant Attorney General
188 West Randolph Street
Suite 2315
Chicago, Illinois 60601

William G. Guldmond, Resident Inspector
La Salle, NPS, U.S.N.R.C.
P. O. Box 224
Marseilles, Illinois 61364

Chairman
La Salle County Board of Supervisors
La Salle County Courthouse
Ottawa, Illinois 61350

Attorney General
500 South 2nd Street
Springfield, Illinois 62701

Department of Public Health
Attn: Chief, Division of Nuclear Safety
535 West Jefferson
Springfield, Illinois 62761

The Honorable Tom Corcoran
United States House of Representatives
Washington, D. C. 20515

Chairman
Illinois Commerce Commission
Leland Building
527 East Capitol Avenue
Springfield, Illinois 62706

TABLE 3.3.7.10-1

RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>ACTION</u>
1. GAMMA SCINTILLATION MONITOR PROVIDING ALARM AND AUTOMATIC TERMINATION OF RELEASE		
a. Liquid Radwaste Effluent Line (OD18-R802)	1	100
2. GAMMA SCINTILLATION MONITORS PROVIDING ALARM BUT NOT PROVIDING AUTOMATIC TERMINATION OF RELEASE		
a. Service Water System Effluent Line (1D18-K608)	1	101
b. RHR Service Water (Line A) Effluent Line (1D18-K604)	1	101
c. RHR Service Water (Line B) Effluent Line (1D18-K605)	1	101
d. Service Water System Effluent Line (2 D18-K608)	1	101
3. FLOW RATE MEASUREMENT DEVICES		
a. Liquid Radwaste Effluent Line (OFIT-WF-017 and 018)	1	102
b. River Discharge - Blowdown Pipe (OFT-WL001)	1	102

LA SALLE - UNIT 1

8209280161 820910
PDR ADDCK 05000373
PDR

3/4 3-82

Amendment 6