


JUNE 7 1982

DISTRIBUTION:

- Document Control (50-373)
- NRC PDR
- L PDR
- NSIC
- PRC
- LB#2 Reading
- EHylton
- ABournia
- ASchwencer
- RLTedesco
- CWoodhead, OELD
- I&E
- ACRS (16)
- Region III

Docket No.: 50-373



Mr. Louis O. DelGeorge
 Director of Nuclear Licensing
 Commonwealth Edison Company
 Post Office Box 767
 Chicago, Illinois 60690

Dear Mr. DelGeorge:

This confirms our telephone authorization of June 3, 1982, with regard to La Salle County Station Unit 1 Technical Specification change as requested by your telecopied letter dated June 1, 1982. On June 3, 1982, we authorized that Specification 3/4.10.7 be modified to include suspension of Specification 3.5.1 for the "B" low pressure coolant injection (LPCI) loop and Specification 3.4.3.2.d isolation valve leakage for the "B" LPCI check valve 1E12-F041B. These changes would permit execution of the confirmatory flow induced vibration test while: (1) "B" LPCI loop is isolated, and (2) prior to "B" LPCI check valve being shown to satisfy the leak rate criterion of 1 gallon per minute.

Facility Operating License No. NPF-11 will be amended by making the enclosed changes to Specification 3/4.10.7.

1. In item e add "and "B" LPCI loop."
2. Add an item f "Specification 3.4.3.2.d, isolation valve leakage for "B" LPCI check valve 1E12 F041B."

Copies of the license amendment, our evaluation and Federal Register Notice for the Technical Specification change will be sent to you when completed.

Sincerely,

Original signed by
 Robert L. Tedesco

Robert L. Tedesco, Assistant Director
 for Licensing
 Division of Licensing

cc: See next page

B206290548 B20607
 PDR ADOCK 05000373
 PDR

*See previous concurrences on next page.

CP

OFFICE	DL:LB#2/PM	DL:LB#2/BC	DL:AD/RL				
SURNAME	ABournia:kw*	ASchwencer*	RLTedesco				
DATE	6/4/82	6/4/82	06/04/82				

DISTRIBUTION:
 Document Control (50-373)
 NRC PDR
 L PDR
 NSIC
 PRC

Docket No.: 50-373

Mr. Louis O. DeGeorge
 Director of Nuclear Licensing
 Commonwealth Edison Company
 Post Office Box 767
 Chicago, Illinois 60690

LB#2 Reading
 EHylton
 ABournia
 ASchwencer
 RLTedesco
 CWoodhead, OELD
 I&E
 ACRS (16)
 Region III

Dear Mr. DeGeorge:

This confirms our telephone authorization of June 3, 1982, with regard to La Salle County Station Unit 1 Technical Specification change as requested by your telecopied letter dated June 1, 1982. On June 3, 1982, we authorized that Specification 3/4.10.7 be modified to include suspension of Specification 3.5.1 for the "B" low pressure coolant injection (LPCI) loop and Specification 3.4.3.2.d isolation valve leakage for the "B" LPCI check valve 1E12-F041B. These changes would permit execution of the confirmatory flow induced vibration test while: (1) "B" LPCI loop is isolated, and (2) prior to "B" LPCI check valve being shown to satisfy the leak rate criterion of 1 gallon per minute.

Facility Operating License No. NPF-11 was amended June 3, 1982 by making the enclosed changes to Specification 3/4.10.7.

1. In item e add "and "B" LPCI loop."
2. Add an item i "Specification 3.4.3.2.d, isolation valve leakage for "B" LPCI check valve 1E12 F041B."

Copies of the license amendment, our evaluation and Federal Register Notice for the Technical Specification change will be sent to you when completed.

Sincerely,

Robert L. Tedesco, Assistant Director
 for Licensing
 Division of Licensing

cc: See next page

OFFICE	DL:LB#2/PM	DL:LA#2/BC	DL:AD/L				
SURNAME	ABournia:kw	ASchwencer	RLTedesco				
DATE	6/04/82	6/6/82	6/ /82				

La Salle

Mr. Louis O. DelGeorge
Director of Nuclear Licensing
Commonwealth Edison Company
P. O. Box 767
Chicago, Illinois 60690

cc: Philip P. Steptoe, Esquire
Suite 4200
One First National Plaza
Chicago, Illinois 60603

Dean Hansell, Esquire
Assistant Attorney General
188 West Randolph Street
Suite 2315
Chicago, Illinois 60601

William G. Guldmond, Resident Inspector
LaSalle NPS, U.S.N.R.C.
P. O. Box 224
Marseilles, Illinois 61364