



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

COMSECY-01-0030

October 29, 2001

REQUEST REPLY BY: 11/6/01

~~NOTE: SENSITIVE
INFORMATION - LIMITED
TO NRC UNLESS THE
COMMISSION DETERMINES
OTHERWISE~~

MEMORANDUM TO: Chairman Meserve
Commissioner Dicus
Commissioner Diaz
Commissioner McGaffigan
Commissioner Merrifield

FROM: William D. Travers
Executive Director for Operations

Carl J. Papenutto for

SUBJECT: GUIDANCE TO THE STAFF ON RELEASE OF INFORMATION TO THE
PUBLIC

As requested, attached for your review is a copy of a draft network announcement and criteria for the staff to use in making discretionary releases of information to the public. The guidance is to be used in the interim, until a long-term, permanent policy is developed.

SECY, please track.

Attachment: As stated

cc:
SECY
OGC
OCA
OPA
CFO

Approved subject to the addition of criteria 7 below:

- Information in any type of document (e.g., plant status report, press release) that provides the current status or configuration of systems and equipment that could be used to determine facility vulnerabilities if used by an adversary. This does not include general conditions such as 100 percent power or shutdown.

Examples of information from actual Plant Status Reports that should NOT be released are attached.

Nils J. Diaz
Nils J. Diaz 10/30/2001

~~NOTE: SENSITIVE
INFORMATION - LIMITED TO
NRC UNLESS THE
COMMISSION DETERMINES
OTHERWISE~~

ORIGINAL

A14

2	SUMMER 1	100	
2	SURRY 1	100	
2	SURRY 2	100	
2	TURKEY POINT 3	100	
2	TURKEY POINT 4	100	
2	VOGTLE 1	100	*
2	VOGTLE 2	100	
2	WATTS BAR 1	100	

NRC OPERATIONS CENTER
PLANT STATUS REPORT FOR 08/31/2001
UNEVALUATED INFORMATION PROVIDED BY THE FACILITY

REG	PLANT NAME	%PWR DOWN	REASON OR COMMENT	* #
3	BRAIDWOOD 1	97	Power Operation 100% OF RATED ELECTRICAL CAPABILITY	
3	BRAIDWOOD 2	97	Power Operation 100% OF RATED ELECTRICAL CAPABILITY	
3	BYRON 1	95	Power Operation HOLDING POWER AT THIS LEVEL TO PERFORM '1C' CIRCULATING WATER PUMP REPAIRS	* <i>example</i>
3	BYRON 2	100		
3	CLINTON 1	100		
3	COOK 1	0	08/27/01 Cold Shutdown MAINTENANCE OUTAGE	
3	COOK 2	0	08/30/01 Hot Standby MAINTENANCE OUTAGE DUE TO ABNORMALLY LOW ESSENTIAL SERVICE WATER FLOWS TO THE DIESEL GENERATORS (Refer to event #38249) - TECH SPEC 3.0.3 ENTRY DUE TO SEVERAL INOPERABLE INDIVIDUAL ROD POSITION INDICATORS DURING UNIT SHUT DOWN (Refer to event #38253)	* <i>example</i>
3	DAVIS BESSE 1	100		
3	DRESDEN 2	88	Power Operation HOLDING POWER AT THIS LEVEL DUE TO MAIN POWER TRANSFORMER GASSING CONCERNS	
3	DRESDEN 3	100		
3	DUANE ARNOLD 1	100		

3	FERMI 2	100		
3	KEWAUNEE 1	96		
3	LASALLE 1	100		
3	LASALLE 2	100		
3	MONTICELLO 1	100		
3	PALISADES 1	0	06/20/01	Cold Shutdown MAINTENANCE OUTAGE
3	PERRY 1	100		
3	POINT BEACH 1	55		Power Operation HOLDING POWER AT THIS LEVEL TO PERFORM 'B' MAIN FEEDWATER PUMP REPAIRS
3	POINT BEACH 2	100		
3	PRAIRIE ISLAND 1	0	08/03/01	Cold Shutdown MAINTENANCE OUTAGE
3	PRAIRIE ISLAND 2	100		
3	QUAD CITIES 1	100		
3	QUAD CITIES 2	100		

example

NRC OPERATIONS CENTER
PLANT STATUS REPORT FOR 08/31/2001
UNEVALUATED INFORMATION PROVIDED BY THE FACILITY

REG	PLANT NAME	%PWR DOWN	REASON OR COMMENT	* #
4	ARKANSAS NUCLEAR 1	100		
4	ARKANSAS NUCLEAR 2	100		
4	CALLAWAY 1	100		
4	COLUMBIA GENERATING	100		
4	COMANCHE PEAK 1	100		*
4	COMANCHE PEAK 2	100		
4	COOPER 1	100		*
4	DIABLO CANYON 1	100		
4	DIABLO CANYON 2	100		
4	FT CALHOUN 1	100		
4	GRAND GULF 1	8	Power Operation MAINTENANCE OUTAGE - OFF LINE - CONTINUING STARTUP	*
4	PALO VERDE 1	99		
4	PALO VERDE 2	99		

Plant Status Report

See Site Location for Plant information.

See Defined Terms for Plant Operational "Modes" and "Conditions."

Ignore "Phone" number, used only by NRC Operations Center Personnel.

NRC OPERATIONS CENTER
PLANT STATUS REPORT FOR 07/09/2001
UNEVALUATED INFORMATION PROVIDED BY THE FACILITY

REG	PLANT NAME	%PWR DOWN	REASON OR COMMENT	* #
1	BEAVER VALLEY 1	100		
1	BEAVER VALLEY 2	100		
1	CALVERT CLIFFS 1	100		
1	CALVERT CLIFFS 2	100		
1	FITZPATRICK 1	100		
1	GINNA 1	100		
1	HOPE CREEK 1	100		
1	INDIAN POINT 2	100		
1	INDIAN POINT 3	100		
1	LIMERICK 1	100		
1	LIMERICK 2	100		
1	MILLSTONE 2	100		
1	MILLSTONE 3	100		
1	NINE MILE POINT 1	100		
1	NINE MILE POINT 2	97		*
1	OYSTER CREEK 1	100		
1	PEACH BOTTOM 2	100		
1	PEACH BOTTOM 3	95	Power Operation COASTDOWN TO REFUELING OUTAGE	
1	PILGRIM 1	100		
1	SALEM 1	85	Power Operation INCREASING POWER. LOST NUMBER ONE STATION POWER TRANSFORMER	* <i>example</i>
1	SALEM 2	84	Power Operation INCREASING POWER. LOST NUMBER ONE STATION POWER TRANSFORMER	*
1	SEABROOK 1	100		
1	SUSQUEHANNA 1	100		