

DISTRIBUTION:
 Document Control (50-373)
 NRC PDR TBarnhart (4)
 L PDR BPCotter, ASLBP
 NSIC ARosenthal, ASLAP
 PRC ACRS (16)
 LB#2 Reading FPagano, I&E
 ABournia Region III, RA
 EHylton
 ASchwencer
 CWoodhead, OELD
 DEisenhut/RPurple
 ELJordan, DEQA:IE
 JMTaylor, DRP:IE
 LJHarmon, IE File (2)
 JSauder
 WMiller, LFMB
 WJones, OA

Docket No. 50-373

Mr. Louis O. DelGeorge
 Director of Nuclear Licensing
 Commonwealth Edison Company
 P. O. Box 767
 Chicago, Illinois 60690

Dear Mr. DelGeorge:

Subject: Amendment No. 11 to Facility Operating License No. NPF-11 - La Salle County Station, Unit No. 1

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 11 to Facility Operating License No. NPF-11 for La Salle County Station, Unit 1. This Amendment is in response to your letter dated December 6, 1982, and authorizes operation at La Salle County Station, Unit 1 with one recirculation loop out of service. This single recirculation loop operation is granted for only the first fuel cycle and only up to 50 percent of rated power. Single loop operation at 50 percent of rated power at Browns Ferry, Unit 1 and several other plants, has shown acceptable flow and power characteristics. Although analyses indicate that operation above 50 percent power with one recirculation loop may be safe, the experience at Browns Ferry Unit 1 has caused concern about flow and power oscillations at such power levels. The staff, therefore, may require additional information in this area of stability for approval for single recirculation loop operation beyond the first cycle. It is important to note that the enclosed Amendment adds a license condition requiring a power level reduction and reduced safety system settings to provide an equivalent level of safety for operation with one recirculation loop out of service.

A copy of the related safety evaluation supporting Amendment No. 11 to Facility Operating License NPF-11 is enclosed. Also enclosed is a copy of a related notice which has been forwarded to the Office of the Federal Register for publication.

Sincerely,

Original signed by:

Darrell G. Eisenhut, Director
 Division of Licensing
 Office of Nuclear Reactor Regulation

8301030284 821215
 PDR ADCK 05000373
 P PDR

- Enclosures:
 1. Amendment No. 11 to NPF-11
 2. Safety Evaluation Report

OFFICE	3. Federal Register notice	DL:LB#2/PM	DL:LB#2/LA	DL:LB#2/BC	DL:ADAL	DL:PIR
SURNAME	cc w/enclosures	ABournia:kw	EHylton	ASchwencer	TMNdjak	DGEisenhut
DATE	See next page	12/15/82	12/15/82	12/15/82	12/15/82	12/15/82

La Salle

Mr. Louis O. DelGeorge
Director of Nuclear Licensing
Commonwealth Edison Company
P. O. Box 767
Chicago, Illinois 60690

cc: Philip P. Steptoe, Esquire
Suite 4200
One First National Plaza
Chicago, Illinois 60603

Dean Hansell, Esquire
Assistant Attorney General
188 West Randolph Street
Suite 2315
Chicago, Illinois 60601

William G. Guldemon, Resident Inspector
La Salle, NPS, U.S.N.R.C.
P. O. Box 224
Marseilles, Illinois 61364

Chairman
La Salle County Board of Supervisors
La Salle County Courthouse
Ottawa, Illinois 61350

Attorney General
500 South 2nd Street
Springfield, Illinois 62701

Department of Public Health
Attn: Chief, Division of Nuclear Safety
535 West Jefferson
Springfield, Illinois 62761

The Honorable Tom Corcoran
United States House of Representatives
Washington, D. C. 20515

Chairman
Illinois Commerce Commission
Leland Building
527 East Capitol Avenue
Springfield, Illinois 62706

COMMONWEALTH EDISON COMPANY

DOCKET NO. 50-373

LA SALLE COUNTY STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

License No. NPF-11
Amendment No. 11

1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
 - A. The application for amendment filed by the Commonwealth Edison Company, dated December 6, 1982, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this Amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations; set forth in 10 CFR Chapter I;
 - D. The issuance of this Amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this Amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by the addition of Paragraph 2.C.(34) to the Facility Operating License No. NPF-11 to read as follows:

(34) Through the First Fuel Cycle of Plant Operation, Technical Specification 3.4.1.1 is Modified for One Recirculation Loop out of Service with Provisions

- (a) The steady-state thermal power level will not exceed 50 percent of rated power.
- (b) The minimum critical power ratio (MCPR) safety limit will be increased by 0.01 to 1.07.

8301030289 821215
PDR ADCK 05000373
PDR

OFFICE							
SURNAME							
DATE							

- (c) The minimum critical power ratio limiting condition for operation (LCO) will be increased by 0.01.
- (d) The maximum average planar linear heat generation (MAPLHGR) limit will be reduced by 0.25.
- (e) Technical Specifications Setpoints shall read as follows:
 - T. S. 2.2.1 $S \leq 0.66W + 45.7$ (Trip Setpoint)
 $S \leq 0.66W + 48.7$ (Allowable)
 - T. S. 3.2.2 $S \leq (0.66W + 45.7) T^*$
 $S \leq (0.66W + 36.7) T^*$
 RB
 T* as defined in T. S. 3.2.2
 - T. S. 3.3.6 APRM Upscale $\leq 0.66W + 36.7$ (Trip Setpoint)
 APRM Upscale $\leq 0.66W + 39.7$ (Allowable)
 RBM Upscale $\leq 0.66W + 34.7$ (Trip Setpoint)
 RBM Upscale $\leq 0.66W + 37.7$ (Allowable)
- (f) The average power range monitor (APRM) flux noise will be measured once per shift; and the recirculation loop flow will be reduced if the flux noise averaged over 1/2 hour exceeds 5 percent peak to peak, as measured by the APRM chart recorder.
- (g) The core plate delta P noise will be measured once per shift, and the recirculation loop flow will be reduced if the noise exceeds one (1) psi peak-to-peak.

3. This Amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Original signed by:

Darrell G. Eisenhut, Director
 Division of Licensing
 Office of Nuclear Reactor Regulation

Date of Issuance: DEC 16 1982

*SEE PREVIOUS CONCURRENCES

OFFICE	DL:LB#2/PM	DL:LB#2/LA	DL:LB#2/BC	DL:AD/L	DL:DIR		
SURNAME	ABournia:kw*	EHylton*	ASchwencer*	TMNovak*	DGEisenhut*		
DATE	12/15/82	12/15/82	12/15/82	12/15/82	12/15/82		

- (c) The minimum critical power ratio limiting condition for operation (LCO) will be increased by 0.01.
- (d) The maximum average planar linear heat generation (MAPLHGR) limit will be reduced by 0.85.
- (e) Technical Specifications Setpoints shall read as follows:
 - T. S. 2.2.1 $S \leq 0.66W + 45.7$ (Trip Setpoint)
 $S \leq 0.66W + 48.7$ (Allowable)
 - T. S. 3.2.2 $S \leq (0.66W + 45.7) T^*$
 $S_{RB} \leq (0.66W + 36.7) T^*$
RB
 T^* as defined in T. S. 3.2.2
 - T. S. 3.3.6 APRM Upscale $\leq 0.66W + 36.7$ (Trip Setpoint)
APRM Upscale $\leq 0.66W + 39.7$ (Allowable)
RBM Upscale $\leq 0.66W + 34.7$ (Trip Setpoint)
RBM Upscale $\leq 0.66W + 37.7$ (Allowable)
- (f) The average power range monitor (APRM) flux noise will be measured once per shift, and the recirculation pump speed will be reduced if the flux noise exceeds one (1) psi peak-to-peak.
- (g) The core plate delta P noise will be measured once per shift, and the recirculation pump speed will be reduced if the noise exceeds one (1) psi peak-to-peak.

3. This Amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

Date of Issuance:

OFFICE	DL:LB#2/PM	DL:LB#2/LA	DL:LB#2/BC	DL:AD/L	DL:DIR		
SURNAME	ABournia:kw	EHorton	ASchwencer	FMNovak	DGEisenhut		
DATE	12/15/82	12/15/82	12/15/82	12/15/82	12/15/82		

SAFETY EVALUATION

AMENDMENT NO. 11 TO LICENSE NPF-11

LA SALLE COUNTY STATION, UNIT NO. 1

DOCKET NO. 50-373

1.0. INTRODUCTION

The current La Salle County Station, Unit 1 Technical Specifications do not allow plant operation beyond 12 hours if an idle recirculation loop cannot be returned to service. The ability to operate at reduced power with a single loop is highly desirable from an availability outage planning standpoint in the event that maintenance or component unavailability rendered one loop inoperable.

By letter dated December 6, 1982, Commonwealth Edison Company (CECo) (the licensee) requested changes to the Technical Specification for Single Loop Operation of La Salle, Unit 1. The requested changes would permit Unit 1 to operate at up to 50 percent of rated power with one recirculation loop out of service for unlimited time. While analyses indicate that it may be safe to operate boiling water reactors on a single loop in the range higher than 50 percent of rated power, the experience (reference letter from L. M. Mills, TVA dated March 17, 1980 to H. Denton, NRC) at Browns Ferry, Unit 1 has caused concern about flow and power oscillations. However, because single loop operation at 50 percent of rated power at several plants, including Browns Ferry, Unit 1, has shown acceptable flow and power characteristics, we will permit La Salle, Unit 1 to operate at power levels up to 50 percent of rated power with one loop out of service during its initial fuel cycle. We will request from the licensee any additional information required for permanent approval for single loop operation. If requested, we will also consider operation at a higher power level for La Salle with one recirculation loop out of service after the staff concerns stemming from Browns Ferry, Unit 1 single loop operation, which showed unexpected variation in jet pump flow and neutron flux at power level of 59 percent but these variations stopped when the power level was reduced, are satisfied.

2.0 EVALUATION

2.1 Accidents (Other than Loss of Coolant Accident (LOCA)) and Transients Affected by One Recirculation Loop out of Service

2.1.1 One Pump Seizure Accidents

The licensee states that the one-pump seizure accident is a relatively mild event during two recirculation pump operations. Analyses were performed to determine the impact this accident would have on one recirculation pump operation. These analyses were performed using NRC staff approved models. The analyses were conservatively conducted from a steady-state operating condition of 78 percent of rated thermal power and 63 percent core flow. Pump seizure was simulated by setting the single operating pump speed to zero instantaneously.

DESIGNATED ORIGINAL

Certified By *K. Witt*

8301030297 821215
PDR ADOCK 05000373
P PDR

Results of the analyses indicate that neither pressure nor cladding thermal limits are exceeded during the event. Peak vessel pressure is calculated to be 1031 psig (ASME code limit is 1375 psig) and minimum critical power ratio (MCPR) is 1.17 (safety limit is 1.06).

2.1.2 Abnormal Operational Transients

The licensee discussed the effects of single loop operation on the course of abnormal operational transients. Pressurization and cold water increase events, as well as rod withdrawal error, were addressed. Flow decrease is covered by the pump seizure accident already described. The results of calculations for the limiting event for each category were also presented. Initial operating conditions were conservatively assumed to be 78 percent of rated thermal power and 63 percent core flow.

2.1.2.1 a) Pressurization Events

The limiting pressurization event is the generator load rejection without bypass transient. For single loop operation, the licensee has calculated that the maximum vessel pressure is 1128 psig and the MCPR is 1.29. Each of the values satisfies its respective safety limit.

b) Cold Water Increase

The limiting cold water increase event is the feedwater controller failure to maximum demand transient. The reactor is assumed to be in single loop operation at conservative initial operating conditions of 78 percent of rated power and 63 percent core flow when failure of the feedwater control system instantaneously increases the feedwater flow to the runout capacity of 160 percent of rated flow. The peak pressure is calculated to be 1126 psig and the MCPR is 1.26, each satisfying its respective safety limit.

c) Rod Withdrawal Error

The rod withdrawal error at rated power is given in the Final Safety Analysis Report for the initial core and in cycle dependent reload supplemental submittals. These analyses are performed to demonstrate that, even if the operator ignores all instrument indications and the alarms which could occur during the course of the transient, the rod block system will stop rod withdrawal at a minimum critical power ratio which is higher than the fuel cladding integrity safety limit. Correction of the rod block equation and lower initial power for single-loop operation in the Technical Specifications (see Section 5 of this safety evaluation) assures that the MCPR safety limit is not violated.

One-pump operation results in backflow through 10 of the 20 jet pumps while flow is being supplied to the lower plenum from the active jet pumps. Because of this backflow through the inactive jet pumps, present rod-block equation and APRM settings must be modified. The licensee has modified the two-pump rod block equation and average power range monitor (APRM) settings that exist in the Technical Specifications for one-pump operation and the staff has found them acceptable.

The staff finds that one loop transients and accidents other than LOCA, which is discussed below, are bounded by the two loop operation analyses and are therefore acceptable.

2.1.3 Minimum Critical Power Ratio (MCPR) Uncertainties

For single-loop operation, the rated condition steady-state MCPR limit is increased by 0.01 to account for increased uncertainties in the core total flow and traversing in-core probe (TIP) readings. The MCPR will vary depending on flow conditions. This leads to the possibility of a large inadvertent flow increase which would cause the MCPR to decrease below the safety limit for a low initial MCPR at reduced flow conditions. Therefore, the required MCPR must be increased at reduced core flow by a flow factor K_f . The K_f factors for two loop operation are derived assuming both recirculation loop controllers fail. This condition of both recirculation loop controllers failing maximizes the power increase and hence bounds the maximum delta MCPR for single loop operation transients. When operating on one loop, the flow and power increase will be less than that associated with two loops at full flow. The K_f factors derived from the two-loop assumptions are therefore conservative for single loop operation.

2.2 Loss of Coolant Accident (LOCA)

The licensee has performed analyses of a spectrum of recirculation suction line breaks under single loop operation conditions. The licensee states that evaluation of these calculations which are performed according to the procedure outlined in NEDO-20556-2, Rev. 1, "General Electric Company Analytical Model for Loss-of-Coolant Analysis in Accordance with 10 CFR 50 Appendix K - Amendment No. 2 One Recirculation Loop out of Service," indicates that a multiplier of 0.87 should be applied to the maximum average planar linear heat generation rate (MAPLHGR) limits for single loop operation of La Salle, Unit 1. Other plants using 8 x 8R fuel have been required to use a reduction factor of 0.85. We require that La Salle, Unit 1 likewise reduce its MAPLHGR by 0.85.

3.0 THERMAL HYDRAULICS

The licensee has confirmed that analysis uncertainties are independent of whether flow is provided by two loops or a single loop. The only exceptions to this are core total flow and TIP reading. The effect of these uncertainties is an increase in the MCPR by .01, which is more than offset by the K_f factor required at low flows. The steady state operating MCPR with single-loop operation will be conservatively established by multiplying the rated flow MCPR limit by the K_f factor.

4.0 STABILITY ANALYSIS

As indicated in the applicant's submittal, operating along the minimum forced recirculation line with one pump running at minimum speed is more stable than operating with both pumps operating at minimum speed.

The licensee will be required to operate in master manual to reduce the effects of instabilities due to controller feedback. The staff has accepted previous stability analyses results as evidence that the core can be operated safely while our generic evaluation of boiling water reactor stability characteristics and analysis methods continues. The previous stability analysis results include natural circulation conditions and thus bound the single loop operation. In addition, the decay ratio (0.50) predicted for initial cycle for Unit 1 shows margin relative to Browns Ferry, Unit 1 (.83) which had the flow noise oscillations during single recirculation loop operation. We conclude that with appropriate limitations to recognize and avoid operating instabilities, that the reactor can be operated safely in the single loop mode. Our evaluation of the flow/power oscillations evidenced in Browns Ferry will continue and any pertinent conclusions resulting from this study will be applied to La Salle, Unit 1.

5.0 SUMMARY ON SINGLE LOOP OPERATION

5.1 Steady State Thermal Power Level will not exceed 50 percent of Rated Power

Operating at 50 percent of rated power with appropriate Technical Specification (TS) changes has been approved on a cycle basis for several operating plants. It is concluded for La Salle, Unit 1 that for operation at 50 percent of rated power, consistent with the provisions of item h below, that transient and accident bounds will not be exceeded.

5.2 Minimum Critical Power Ratio (MCPR) Safety Limit Will Be Increased by 0.01 to 1.07

The MCPR Safety Limit will be increased by 0.01 to account for increased (TIP) readings. The licensee has determined that the change conservatively bounds the uncertainties introduced by single loop operation.

5.3 Minimum Critical Power Ratio (MCPR) Limiting Condition for Operation (LCO) will be increased by 0.01

The staff requires that the operating limit MCPR be increased by 0.01 and multiplied by the appropriate two loop K_f factors that are in the La Salle, Unit 1 TS. This will preclude an inadvertent flow increase from causing the MCPR to drop below the safety limit MCPR.

5.4 The Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) Limits will be Reduced by Appropriate Multipliers

The licensee proposed reducing the TS MAPLHGR by 0.87 for Single Loop Operation. These reductions were based on an analysis method proposed by General Electric in NEDE-20566-2. We require a reduction factor of 0.85 consistent with previous single recirculation loop operation approvals for plants with 8 x 8R fuel. This change has been discussed with and agreed to by licensee.

5.5 The APRM Scram and Rod Block Setpoints will be Reduced

The licensee proposed to modify the two loop APRM Scram, Rod Block and Rod Block Monitor (RBM) setpoints to account for back flow through half the jet pumps. These setpoint equations will be changed in the La Salle, Unit 1 TS. The above changes are similar to other plant TS changes and are acceptable to the staff.

5.6 The Recirculation Control will be in Manual Control

The staff requires that the licensee operate the recirculation system in the manual mode to eliminate the need for control system analyses and to reduce the effects of potential flow instabilities.

5.7 Surveillance Requirements

The staff requires that the licensee perform daily surveillance on the jet pumps to ensure that the pressure drop for one jet pump in a loop does not vary from the mean of all jet pumps in that loop by more than 5 percent.

5.8 Provisions to Allow Operation with One Recirculation Loop Out of Service

- a. The steady-state thermal power level will not exceed 50 percent of rated power.
- b. The Minimum Critical Power Ratio (MCPR) Safety Limit will be increased by .01 to 1.07.

8.0 CONCLUSION

We have concluded, based on the considerations discussed above, that; (1) because the Amendment does not involve a significant increase in the probability or consequences or accidents previously considered, does not create the possibility of an accident of a type different from any evaluated previously, and does not involve a significant decrease in a safety margin, the Amendment does not involve a significant hazards consideration; (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner; and (3) such activities will be conducted in compliance with the Commission's regulations and the issuance of this Amendment will not be inimical to the common defense and security or to the health and safety of the public.

Date: DEC 16 1982

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-373

COMMONWEALTH EDISON COMPANY

NOTICE OF ISSUANCE OF AMENDMENT OF FACILITY OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 11 to Facility Operating License No. NPF-11, issued to Commonwealth Edison Company, which adds License Condition 2.C.(34) for operation of the La Salle County Station, Unit No. 1 (the facility) located in Brookfield Township, La Salle County, Illinois.

The Amendment authorizes the operation of La Salle County Station, Unit 1 with one recirculation loop out of service for the first fuel cycle only. Also, the Amendment adds a license condition limiting a power level to 50 percent of full power or less during the operation with one recirculation loop out of service.

The application for amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this Amendment was not required since the Amendment does not involve a significant hazards consideration.

The Commission has determined that the issuance of this Amendment will not result in any significant environmental impact and that pursuant to 10 CFR Section 51.5(d)(4) an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this Amendment.

s.	8301030299	821215					
	PDR	ADOCK	05000373				
P		PDR					
DATE							

For further details with respect to this action, see (1) the application for amendment dated December 6, 1982; (2) Amendment No. 11 to License No. MPF-11 dated December 16, 1982; and (3) the Commission's related safety evaluation. All of these items are available for public inspection at the Commission's Public Document Room located at 1717 H Street, NW, Washington, DC 20555, and the Public Library of Illinois Valley Community College, Rural Route No. 1, Ogelsby, Illinois 61348. A copy of items (1), (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 16th day of December 1982.

FOR THE NUCLEAR REGULATORY COMMISSION

Original signed by:

A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing

*SEE PREVIOUS CONCURRENCES

OFFICE	DL:LB#2/PM	DL:LB#2/LA	OELD	DL:LB#2/BC			
SURNAME	ABournia:kw*	EHylton*	CWoodhead*	ASchwencer			
DATE	12/15/82	12/15/82	12/15/82	12/15/82			

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-373

COMMONWEALTH EDISON COMPANY

NOTICE OF ISSUANCE OF AMENDMENT OF FACILITY OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. to Facility Operating License No. NPF-11, issued to Commonwealth Edison Company, which adds License Condition 2.C.(34) for operation of the La Salle County Station, Unit No. 1 (the facility) located in Brookfield Township, La Salle County, Illinois.

The Amendment authorizes the operation of La Salle County Station, Unit 1 with one recirculation loop out of service for the first fuel cycle only. Also, the Amendment adds a license condition requiring a power level of safety during the operation with one recirculation loop out of service.

The application for amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this Amendment was not required since the Amendment does not involve a significant hazards consideration.

The Commission has determined that the issuance of this Amendment will not result in any significant environmental impact and that pursuant to 10 CFR Section 51.5(d)(4) an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this Amendment.

OFFICE ▶
SURNAME ▶
DATE ▶

For further details with respect to this action, see (1) the application for amendment dated December 6, 1982 and (2) Amendment No. to License No. NPF-11 dated December , 1982. All of these items are available for public inspection at the Commission's Public Document Room located at 1717 H Street, NW, Washington, DC 20555, and the Public Library of Illinois Valley Community College, Rural Route No. 1, Ogelsby, Illinois 61348. A copy of items (1) and (2) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this th day of December 1982.

FOR THE NUCLEAR REGULATORY COMMISSION

A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing

OFFICE ▶	DL:LB#2/PM	DL:LB#2/LA	OELD/	DL:LB#2/BC			
SURNAME ▶	ABournia:kw	EH	<i>W. Schwencer</i>	ASchwencer			
DATE ▶	12/15/82	12/15/82	12/15/82	12/ /82			



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

DISTRIBUTION:
Docket File
LB#2 File
EHylton
ABournia
FIngram, PA

December 20, 1982

Docket No. 50-373

Docketing and Service Section
Office of the Secretary of the Commission

SUBJECT: NOTICE OF ISSUANCE OF AMENDMENT NO. 11 TO FACILITY OPERATING
LICENSE NO. NPF-11, LA SALLE COUNTY STATION, UNIT 1

Two signed originals of the Federal Register Notice identified below are enclosed for your transmittal to the Office of the Federal Register for publication. Additional conformed copies (6) of the Notice are enclosed for your use.

- Notice of Receipt of Application for Construction Permit(s) and Operating License(s).
- Notice of Receipt of Partial Application for Construction Permit(s) and Facility License(s): Time for Submission of Views on Antitrust Matters.
- Notice of Availability of Applicant's Environmental Report.
- Notice of Proposed Issuance of Amendment to Facility Operating License.
- Notice of Receipt of Application for Facility License(s); Notice of Availability of Applicant's Environmental Report; and Notice of Consideration of Issuance of Facility License(s) and Notice of Opportunity for Hearing.
- Notice of Availability of NRC Draft/Final Environmental Statement.
- Notice of Limited Work Authorization.
- Notice of Availability of Safety Evaluation Report.
- Notice of Issuance of Construction Permit(s).
- Notice of Issuance of Facility Operating License(s) or Amendment(s). No. 11
- Other: _____

Office of Nuclear Reactor Regulation

Enclosure:
As Stated

OFFICE →	DL:LB#2/LA					
SURNAME →	EHylton:pt					
DATE →	12/20/82					