

July 9, 1986

Docket No. 50-373

Mr. Dennis L. Farrar
Director of Nuclear Licensing
Commonwealth Edison Company
P.O. Box 767
Chicago, Illinois 60690

Dear Mr. Farrar:

Subject: Corrected Technical Specification Page in Amendment
No. 44 for La Salle County Station, Unit 1

Our letter, dated June 20, 1986, transmitted Amendment No. 44 for La Salle Unit 1 to add fire detector instrumentation in Zone 2C, 4C2, 3C, 4C3, and 6E in order to satisfy License Condition 2.C.(25)(c). In this package, some additions were made on Technical Specification page 3/4 3-80. In making the additions, the footnote which was on the original Technical Specification page 3/4 3-80 was inadvertently not typed.

Please replace that page with the enclosed page which now includes the footnote.

We regret any inconvenience caused by this omission.

Sincerely,

(S)

Elinor G. Adensam, Director
BWR Project Directorate No. 3
Division of BWR Licensing

Enclosure:
As stated

cc: See next page

8607160198 860709
PDR ADDCK 05000373
P PDR

WB
BWD-3:DBL
ABournia/hmc
7/9/86

LA:BWD-3:DBL
Edensam
7/9/86

EAdensam
D:BWD-3:DBL
EAdensam
7/9/86

Mr. Dennis L. Farrar
Commonwealth Edison Company

La Salle County Nuclear Power Station
Units 1 & 2

cc:
Philip P. Steptoe, Esquire
Suite 4200
One First National Plaza
Chicago, Illinois 60603

John W. McCaffrey
Chief, Public Utilities Division
160 North La Salle Street, Room 900
Chicago, Illinois 60601

Assistant Attorney General
188 West Randolph Street
Suite 2315
Chicago, Illinois 60601

Resident Inspector/LaSalle, NPS
U.S. Nuclear Regulatory Commission
Rural Route No. 1
P. O. Box 224
Marseilles, Illinois 61341

Chairman
La Salle County Board of Supervisors
La Salle County Courthouse
Ottawa, Illinois 61350

Attorney General
500 South 2nd Street
Springfield, Illinois 62701

Chairman
Illinois Commerce Commission
Leland Building
527 East Capitol Avenue
Springfield, Illinois 62706

Mr. Gary N. Wright, Manager
Nuclear Facility Safety
Illinois Department of Nuclear Safety
1035 Outer Park Drive, 5th Floor
Springfield, Illinois 62704

Regional Administrator, Region III
U. S. Nuclear Regulatory Commission
799 Rossevelt Road
Glen Ellyn, Illinois 60137

TABLE 3.3.7.9-1 (Continued)
FIRE DETECTION INSTRUMENTATION

<u>INSTRUMENT LOCATION</u>	<u>MINIMUM INSTRUMENTS OPERABLE*</u>		
	<u>HEAT</u>	<u>FLAME</u>	<u>SMOKE</u>
<u>Unit 2 Fire Detection Instrumentation Required</u>			
<u>For Unit 2 (Continued)</u>			
k. Div. SWGR Room, Zone 2-9 El. 710'6", Fire Hazard Zone 4F2			17
l. Aux. Bldg. Corridor, Zone 2-4 El. 710'6", Fire Hazard Zone 5C11			9
m. Aux. Bldg., Zone 2-39 El. 768', Fire Hazard Zone 4C3			10
5. DG Bldg./DG Bldg. Corridor			
a. DG Bldg., Zone 2-29 El. 736'6", Fire Hazard Zones 8A1, 8A2			14
b. DG Bldg. Corridor, Zone 2-25 El. 710'6", Fire Hazard Zone 5C11			3
c. DG Bldg., Zone 2-28 El. 674', Fire Hazard Zones 8C3, 8C4, 8C5			11
6. Reactor Bldg.			
a. Refuel Floor, Zone 2-26 El. 843'6", Fire Hazard Zone 1		6	
b. Reactor Bldg. East, Zone 2-24 El. 820'6", Fire Hazard Zone 3B1			11
c. Reactor Bldg. West, Zone 2-40 El. 807', Fire Hazard Zone 3C			7

8607160199 860709
PDR ADDCK 05000373
P PDR

*The fire detection instruments located within the primary containment are not required to be OPERABLE during the performance of Type A Containment Leakage Rate Tests.

July 9, 1986

CORRECTION PAGE TO AMENDMENT NO. 44 TO FACILITY OPERATING LICENSE NO. NPF-11
LA SALLE, UNIT 1

DISTRIBUTION:

Docket No. 50-373
NPC PDR
Local PDR
PRC System
NSIC
BWD-3 r/f
ABournia (4)
EHylton (2)
EAdensam
Attorney, OELD
CMiles
RDiggs
JPartlow
RGrimes
EJordan
LHarmon
TBarnhart (4)
FEltawila
Mary Johns, RIII
EButcher