

April 22, 2002

Mr. John T. Conway
Site Vice President
Nine Mile Point Nuclear Station, LLC
P.O. Box 63
Lycoming, NY 13093

SUBJECT: NINE MILE POINT NUCLEAR STATION, UNIT NO. 1 - REQUEST FOR
ADDITIONAL INFORMATION - AMENDMENT APPLICATION RE: INSERVICE
TESTING AND INSPECTION REQUIREMENTS (TAC NO. MB3208)

Dear Mr. Conway:

The U.S. Nuclear Regulatory Commission (NRC) staff is reviewing the subject proposed amendment, requested by your letter dated November 26, 2001. On April 10, 2002, we held a telephone discussion with Mr. A. Abbasi, et al., of your staff. The NRC staff decided to formalize its comments in a request for additional information.

The NRC staff holds the position that inservice testing of Quality Group A, B, and C pumps and valves be performed in accordance with requirements for American Society of Mechanical Engineers (ASME) Code Class 1, 2, and 3 components specified in Section XI of the applicable ASME Boiler and Pressure Vessel Code and Addenda. Your application is lacking such wording. Alternatively, you may consider adopting the proposed requirements described by Section 5.5.7.a of NUREG-1433, "Standard Technical Specifications for General Electric Nuclear Plants, BWR/4 and BWR/6."

Please respond within 45 days of receipt of this letter. If more time is needed, or if you need clarification, please call me at 301-415-1451.

Sincerely,

/RA/

Peter S. Tam, Senior Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-220

cc: See next page

Mr. John T. Conway
Site Vice President
Nine Mile Point Nuclear Station, LLC
P.O. Box 63
Lycoming, NY 13093

SUBJECT: NINE MILE POINT NUCLEAR STATION, UNIT NO. 1 - REQUEST FOR
ADDITIONAL INFORMATION - AMENDMENT APPLICATION RE: INSERVICE
TESTING AND INSPECTION REQUIREMENTS (TAC NO. MB3208)

Dear Mr. Conway:

The U.S. Nuclear Regulatory Commission (NRC) staff is reviewing the subject proposed amendment, requested by your letter dated November 26, 2001. On April 10, 2002, we held a telephone discussion with Mr. A. Abbasi, et al., of your staff. The NRC staff decided to formalize its comments in a request for additional information.

The NRC staff holds the position that inservice testing of Quality Group A, B, and C pumps and valves be performed in accordance with requirements for American Society of Mechanical Engineers (ASME) Code Class 1, 2, and 3 components specified in Section XI of the applicable ASME Boiler and Pressure Vessel Code and Addenda. Your application is lacking such wording. Alternatively, you may consider adopting the proposed requirements described by Section 5.5.7.a of NUREG-1433, "Standard Technical Specifications for General Electric Nuclear Plants, BWR/4 and BWR/6."

Please respond within 45 days of receipt of this letter. If more time is needed, or if you need clarification, please call me at 301-415-1451.

Sincerely,

/RA/

Peter S. Tam, Senior Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-220

cc: See next page

DISTRIBUTION:

PUBLIC	PDI-1 R/F	RLaufer	PTam
OGC	YSHuang	SLittle	PHearn
ACRS	BPlatchek		

Accession Number: **ML021120379**

OFFICE	PDI-1/PM	PDI-1/LA	RORP	RORP/SC	PDI-1/SC
NAME	PTam	SLittle	PHearn	RDennig	RLaufer
DATE	4/18/02	4/18/02	4/19/02	4/19/02	4/22/02

OFFICIAL RECORD COPY

Nine Mile Point Nuclear Station
Unit No. 1

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 126
Lycoming, NY 13093

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Mr. Paul D. Eddy
Electric Division
NYS Department of Public Service
Agency Building 3
Empire State Plaza
Albany, NY 12223

Mr. William M. Flynn, President
New York State Energy, Research,
and Development Authority
Corporate Plaza West
286 Washington Avenue Extension
Albany, NY 12203-6399

Mark J. Wetterhahn, Esquire
Winston & Strawn
1400 L Street, NW
Washington, DC 20005-3502

Supervisor
Town of Scriba
Route 8, Box 382
Oswego, NY 13126

Mr. Robert E. Denton
President
Nine Mile Point Nuclear Station, LLC
1997 Annapolis Exchange Parkway
Suite 500
Annapolis, MD 21401

Mr. Raymond L. Wenderlich
Senior Constellation Nuclear Officer
Responsible for Nine Mile Point
Nine Mile Point Nuclear Station, LLC
P.O. Box 63
Lycoming, NY 13093

Mr. James M. Petro, Jr., Esquire
Counsel
Constellation Power Source, Inc.
111 Market Place
Suite 500
Baltimore, MD 21202