



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

May 6, 1986

Docket Nos: 50-373
and 50-374

Mr. Dennis L. Farrar
Director of Licensing
Commonwealth Edison Company
P.O. Box 767
Chicago, Illinois 60690

Dear Mr. Farrar:

Subject: Issuance of Amendment No. 39 to Facility Operating License
No. NPF-11 and Amendment No. 21 to Facility Operating License
No. NPF-18 - La Salle County Station, Units 1 and 2

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 39 to Facility Operating License No. NPF-11 and Amendment No. 21 to Facility Operating License No. NPF-18 for the La Salle County Station, Units 1 and 2. These amendments are in response to your letters dated August 27, 1985, and April 4, 1986.

The amendments supplement the La Salle, Units 1 and 2 Technical Specifications to change the alarm calibration setpoint to greater than or equal to 940 psig instead of 940 psig +30, -0 psig.

A copy of the related safety evaluation supporting Amendment No. 39 to Facility Operating License No. NPF-11 and Amendment No. 21 to Facility Operating License NPF-18 is enclosed.

Sincerely,


Elinor G. Adensam, Director
BWR Project Directorate No. 3
Division of BWR Licensing

Enclosures:

1. Amendment No. 39 to NPF-11
2. Amendment No. 21 to NPF-18
3. Safety Evaluation

cc w/enclosure:
See next page

DESIGNATED ORIGINAL

Certified By 

8605120169 860506
PDR ADDOCK 05000373
P PDR

Mr. Dennis L. Farrar
Commonwealth Edison Company

La Salle County Nuclear Power Station
Units 1 & 2

cc:

Philip P. Steptoe, Esquire
Suite 4200
One First National Plaza
Chicago, Illinois 60603

John W. McCaffrey
Chief, Public Utilities Division
160 North La Salle Street, Room 900
Chicago, Illinois 60601

Assistant Attorney General
188 West Randolph Street
Suite 2315
Chicago, Illinois 60601

Resident Inspector/LaSalle, NPS
U.S. Nuclear Regulatory Commission
Rural Route No. 1
P.O. Box 224
Marseilles, Illinois 61341

Chairman
La Salle County Board of Supervisors
La Salle County Courthouse
Ottawa, Illinois 61350

Attorney General
500 South 2nd Street
Springfield, Illinois 62701

Chairman
Illinois Commerce Commission
Leland Building
527 East Capitol Avenue
Springfield, Illinois 62706

Mr. Gary N. Wright, Manager
Nuclear Facility Safety
Illinois Department of Nuclear Safety
1035 Outer Park Drive, 5th Floor
Springfield, Illinois 62704

Regional Administrator, Region III
U. S. Nuclear Regulatory Commission
799 Rossevelt Road
Glen Ellyn, Illinois 60137



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

COMMONWEALTH EDISON COMPANY

DOCKET NO. 50-373

LA SALLE COUNTY STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 39
License No. NPF-11

1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
 - A. The applications for amendment filed by the Commonwealth Edison Company (the licensee), dated August 27, 1985, and April 4, 1986, comply with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the enclosure to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-11 is hereby amended to read as follows:


(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 39, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

8605120175 860506
PDR ADOCK 05000373
P PDR

3. This amendment is effective as of date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Elinor G. Adensam, Director
BWR Project Directorate No. 3
Division of BWR Licensing

Enclosure:
Changes to the Technical
Specifications

Date of Issuance: May 6, 1986

ENCLOSURE TO LICENSE AMENDMENT NO. 39

FACILITY OPERATING LICENSE NO. NPF-11

DOCKET NO. 50-373

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains a vertical line indicating the area of change.

REMOVE

3/4 1-10

INSERT

3/4 1-10

REACTIVITY CONTROL SYSTEM

SURVEILLANCE REQUIREMENTS

4.1.3.5 Each control rod scram accumulator shall be determined OPERABLE:

- a. At least once per 7 days by verifying that the indicated pressure is greater than or equal to 940 psig unless the control rod is inserted and disarmed or scrambled.
- b. At least once per 18 months by:
 1. Performance of a:
 - a) CHANNEL FUNCTIONAL TEST of the leak detectors, and
 - b) CHANNEL CALIBRATION of the pressure detectors, with the alarm setpoint \geq 940 psig on decreasing pressure.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

COMMONWEALTH EDISON COMPANY

DOCKET NO. 50-374

LA SALLE COUNTY STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 21
License No. NPF-18


1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
 - A. The applications for amendment filed by the Commonwealth Edison Company (the licensee), dated August 27, 1985, and April 4, 1986, comply with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the enclosure to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-18 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 21, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This amendment is effective upon date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Elinor G. Adensam, Director
BWR Project Directorate No. 3
Division of BWR Licensing

Enclosure:
Changes to the Technical
Specifications

Date of Issuance: May 6, 1986

ENCLOSURE TO LICENSE AMENDMENT NO. 21

FACILITY OPERATING LICENSE NO. NPF-18

DOCKET NO. 50-374

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains a vertical line indicating the area of change.

REMOVE

3/4 1-10

INSERT

3/4 1-10

REACTIVITY CONTROL SYSTEMS

SURVEILLANCE REQUIREMENTS

4.1.3.5 Each control rod scram accumulator shall be determined OPERABLE:

- a. At least once per 7 days by verifying that the indicated pressure is greater than or equal to 940 psig unless the control rod is inserted and disarmed or scrambled.
- b. At least once per 18 months by:
 1. Performance of a:
 - a) CHANNEL FUNCTIONAL TEST of the leak detectors, and
 - b) CHANNEL CALIBRATION of the pressure detectors, with the alarm setpoint \geq 940 psig on decreasing pressure.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
SUPPORTING AMENDMENT NO. 39 TO FACILITY OPERATING LICENSE NO. NPF-11 AND
AMENDMENT NO. 21 TO FACILITY OPERATING LICENSE NO. NPF-18
COMMONWEALTH EDISON COMPANY
LA SALLE COUNTY STATION, UNITS 1 AND 2
DOCKET NOS. 50-373 AND 50-374

1.0 INTRODUCTION

The Control Rod Drive (CRD) System provides high pressure charging water to the CRD mechanism piston to allow reactor scram when required. During normal plant operation, reactor pressure provides the necessary driving force required to insert the control rods during a scram. When the plant is not at full operating pressure, the CRD scram accumulators (one for each control rod) provide the needed motive force for control rod insertion. To ensure that each accumulator has sufficient stored energy, the accumulator gas pressure must be greater than or equal to 940 psig. Accumulator pressure is verified weekly per surveillance requirement (SR) 4.1.3.5.a of the plant Technical Specification (TS) 3.1.3.5, which addresses the CRD scram accumulators. Additionally, an alarm is provided to ensure that between these weekly surveillances, the pressure is maintained at or above 940 psig. The pressure detector is currently set to alarm at 940+30,-0 psig on decreasing pressure per existing SR 4.1.3.5.b.1.b for La Salle Units 1 and 2.

By letter dated August 27, 1985, Commonwealth Edison Company (licensee) proposed changes to the existing plant TS 3.1.3.5 and the corresponding SR 4.1.3.5. Specifically, the licensee proposed to add action statements to TS 3.1.3.5 to address inoperable pressure and level detectors associated with the scram accumulators. Also, the licensee proposed to revise the pressure alarm calibration requirement for pressure detectors (SR 4.1.3.5.b.1.b) to a set point value of greater than or equal to 940 psig. Based on review of the above submittal, the staff requested additional information relative to the proposed change to TS 3.1.3.5. By letter dated April 4, 1986, the licensee provided a second submittal, wherein they withdrew their earlier request for change to TS 3.1.3.5, but retained the request for change in SR 4.1.3.5.b.1.b. The licensee justified their requested revision of the SR by stating that the tolerance band of +30,-0 psig in the existing SR was not required to ensure the operability of either a scram accumulator, or its associated pressure detector, and that the proposed revision to eliminate the upper limit of the pressure detector set point value is conservative and would allow greater operational flexibility than what is currently available.

8605120198 860506
PDR ADOCK 05000373
P PDR

2.0 EVALUATION

The staff has reviewed the April 4th submittal and the associated justification for the requested revision of SR 4.1.3.5.b.1.b in the earlier submittal. Based on the review, the staff agrees that the proposed revision is conservative in the sense that, with the revision, the alarm set point value for the pressure detector could be equal to or higher than the currently existing range of set point values and could consequently give the same or earlier warning of scram accumulator concerns. The staff also finds that while the proposed revision would allow the licensee greater operational flexibility, it would not compromise the operability of either a scram accumulator or its associated pressure detector.

Based on the above findings, the staff concludes that the proposed revisions of SR 4.1.3.5.b.1.b for La Salle Units 1 and 2 relating to the range of alarm set point values for the pressure detectors associated with Control Rod Driving System scram accumulators are acceptable.

3.0 ENVIRONMENTAL CONSIDERATION

These amendments involve changes in the installation or use of facility components located within the restricted area as defined in 10 CFR Part 20 and changes in surveillance requirements. The staff has determined that these amendments involve no significant increase in the amounts, and no significant changes in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that these amendments involve no significant hazards consideration and there has been no public comment on such finding. Accordingly, these amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of these amendments.

4.0 CONCLUSION

The Commission made a proposed determination that these amendments involve no significant hazards consideration which was published in the Federal Register (50 FR 41245) on October 9, 1985, and consulted with the state of Illinois. No public comments were received, and the state of Illinois did not have any comments.

The staff has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of these amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: T. Chandrasekaran, BWPS, NRR

Dated: May 6, 1986