

December 18, 1990

Docket Nos. 50-373
and 50-374

Mr. Thomas J. Kovach
Nuclear Licensing Manager
Commonwealth Edison Company-Suite 300
OPUS West III
1400 OPUS Place
Downers Grove, Illinois 60515

DISTRIBUTION:

<u>Docket Files</u>	BBoger
PDIII-2 r/f	JZwolinski
RBarrett	BPulsifer
CMoore	OGC-WF1
DHagan	EJordan
GHill(8)	WJones
JCalvo	ACRS(10)
GPA/PA	OC/LFMB
PDIII-2 Gray	NRC & Local PDRs

Dear Mr. Kovach:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NOS. 77712 AND 77713)

The Commission has issued the enclosed Amendment No. 76 to Facility Operating License No. NPF-11 and Amendment No. 60 to Facility Operating License No. NPF-18 for the LaSalle County Station, Units 1 and 2, respectively. These amendments are in response to your application dated September 21, 1990.

The amendments would revise the Technical Specification (TS) so that new overcurrent protective devices associated with the new cooling units are added to Table 3.8.3.2-1, so that they will be properly controlled and tested.

A copy of the Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Original Signed By:

Robert M. Pulsifer, Project Manager
Project Directorate III-2
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 76 to NPF-11
2. Amendment No. 60 to NPF-18
3. Safety Evaluation

cc w/enclosure:
See next page

OFFICIAL RECORD COPY
DOCUMENT NAME: [AMENDMENT 77712/13]

Office: LA/PDIII-2
Surname: CMoore
Date: 12/17/90

PM/PDIII-2
BPulsifer
11/21/90

SELB
FRosa
12/4/90

PD/PDIII-2
RBarrett
12/18/90

OGC-WF1
12/17/90

9101040231 901218
PDR ADOCK 05000373
P PDR

[Handwritten signature]
111

Mr. Thomas J. Kovach
Commonwealth Edison Company

LaSalle County Station
Unit Nos. 1 and 2

cc:

Robert J. Vollen, Esquire
109 North Dearborn Street
Chicago, Illinois 60602

Michael I. Miller, Esq.
Sidley and Austin
One First National Plaza
Chicago, Illinois 60690

Dr. Cecil Lue-Hing
Director of Research and Development
Metropolitan Sanitary District
of Greater Chicago
100 East Erie Street
Chicago, Illinois 60611

Phillip Steptoe, Esq.
Sidley and Austin
One First National Plaza
Chicago, Illinois 60603

Mayor of Zion
Zion, Illinois 60099

Illinois Department of Nuclear Safety
Office of Nuclear Facility Safety
1035 Outer Park Drive
Springfield, Illinois 62704

U.S. Nuclear Regulatory Commission
Resident Inspectors Office
105 Shiloh Blvd.
Zion, Illinois 60099

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road, Bldg. #4
Glen Ellyn, Illinois 60137

Robert Neumann
Office of Public Counsel
State of Illinois Center
100 W. Randolph
Suite 11-300
Chicago, Illinois 60601



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

COMMONWEALTH EDISON COMPANY

DOCKET NO. 50-373

LASALLE COUNTY STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 76
License No. NPF-11

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment filed by the Commonwealth Edison Company (the licensee), dated September 21, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the enclosure to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-11 is hereby amended to read as follows:

910104024B 901218
PDR ADDCK 05000373
P PDR

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 76 , and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This amendment is effective upon date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Richard J. Barrett, Director
Project Directorate III-2
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: December 18, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 76

FACILITY OPERATING LICENSE NO. NPF-11

DOCKET NO. 50-373

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain a vertical line indicating the area of change.

REMOVE

3/4 8-25

B 3/4 8-3

INSERT

3/4 8-25

3/4 8-25a

B 3/4 8-3

TABLE 3.8.3.2-1 (Continued)

<u>DEVICE NUMBER AND LOCATION</u>	<u>SYSTEM/COMPONENT POWERED</u>
d) MCC 134X-1 (Compt. B4)	NB/MOV 1B21-F002
e) MCC 136Y-1 (Compt. B-2) (Normal)	RH/MOV 1E12-F009
f) MCC 136Y-2 (Compt. E4)	RI/MOV 1E51-F063
g) MCC 135Y-1 (Compt. A1)	RR/MOV 1B33-F023A
h) MCC 135Y-1 (Compt. A4)	RR/MOV 1B33-F067A
i) MCC 133-1 (Compt. C2)	RT/MOV 1G33-F102
j) MCC-133-1 (Compt. E1)	NB/MOV 1B21-F005
k) MCC-136Y-2 (Compt. B1)	NB/MOV 1B21-F016
l) MCC 136Y-2 (Compt. E1)	RH/MOV 1E12-F099A
m) MCC 136Y-1 (Compt. E4)	RT/MOV 1G33-F001
n) MCC 136Y-2 (Compt. A5)	WR/MOV 1WR180
o) MCC 136Y-2 (Compt. D6)	RH/MOV 1E12-F099B
p) MCC 136Y-1 (Compt. H5)	VP/MOV 1VP113B
q) MCC 136Y-1 (Compt. H4)	VP/MOV 1VP114A
r) MCC 136Y-1 (Compt. H3)	VP/MOV 1VP113A
s) MCC 136Y-1 (Compt. H6)	VP/MOV 1VP114B
t) MCC 136Y-2 (Compt. A4)	WR/MOV 1WR179
u) MCC 135Y-1 (Compt. D3)	RT/MOV 1G33-F101
v) MCC 135Y-1 (Compt. D4)	RT/MOV 1G33-F100
w) MCC 133-1 (Compt. C3)	RT/MOV 1G33-F106
x) MCC 136Y-2 (Compt. D5)	RI/MOV 1E51-F076
y) MCC 135X-1 (Compt. C2/C3) (Emerg)	RH/MOV 1E12-F009
z) MCC 133-2 (Compt. AC1)	VP/Drywell Cooler 1VP15SA
aa) MCC 133-2 (Compt. AB1)	VP/Drywell Cooler 1VP15SE

TABLE 3.8.3.2-1 (continued)

<u>DEVICE NUMBER AND LOCATION</u>	<u>SYSTEM/COMPONENT POWERED</u>
ab) MCC 133-2 (Compt. AB2)	VP/Drywell Cooler 1VP15SD
ac) MCC 134X-2 (Compt. H1)	VP/Drywell Cooler 1VP15SB
ad) MCC 134X-2 (Compt. H2)	VP/Drywell Cooler 1VP15SC
ae) MCC 134X-2 (Compt. J1)	VP/Drywell Cooler 1VP15SF
2. Type K-M Cat # NZ M12V-630/ZM12AV	
a) MCC 135X-2 (Compt. E4)	VP/Pri. Cont. Vent Supply Fan 1A Backup
b) MCC 136X-2 (Compt. G4)	VP/Pri. Cont. Vent Supply Fan 1B Backup

ELECTRICAL POWER SYSTEMS

BASES

A.C. SOURCES AND ONSITE POWER DISTRIBUTION SYSTEMS (Continued)

specific gravity, ensures that the decrease in rating will be less than the safety margin provided in sizing; (3) the allowable value for an individual cell's specific gravity ensures that an individual cell's specific gravity will not be more than 0.040 below the manufacturer's full charge specific gravity and that the overall capability of the battery will be maintained within an acceptable limit; and (4) the allowable value for an individual cell's float voltage, greater than 2.07 volts, ensures the battery's capability to perform its design function.

The battery load profile and battery charger specifications will be maintained and are located in Chapter 8, "Electrical Power", section of the Updated Final Safety Analysis Report, UFSAR.

3/4.8.3 ELECTRICAL EQUIPMENT PROTECTIVE DEVICES

Primary containment medium and high voltage (6.9 kV, 4.16 kV and 480 volt) electrical penetrations and penetration conductors are protected by either de-energizing circuits not required during reactor operation or demonstrating the OPERABILITY of primary and backup overcurrent protection circuit breakers by periodic surveillance.

The surveillance requirements applicable to lower voltage circuit breakers and fuses provides assurance of breaker and fuse reliability by testing at least one representative sample of each manufacturers brand of circuit breaker and/or fuse. Each manufacturer's molded case and metal case circuit breakers and/or fuses are grouped into representative samples which are then tested on a rotating basis to ensure that all breakers and/or fuses are tested. If a wide variety exists within any manufacturer's brand of molded case circuit breakers and/or fuses, it is necessary to divide that manufacturer's breakers and/or fuses into groups and treat each group as a separate type of breaker or fuses for surveillance purposes.

The bypassing of the motor operated valves thermal overload protection continuously or during accident conditions by integral bypass devices ensures that the thermal overload protection will not prevent safety related valves from performing their function. The Surveillance Requirements for demonstrating the bypassing of the thermal overload protection continuously and during accident conditions are in accordance with Regulatory Guide 1.106 "Thermal Overload Protection for Electric Motors on Motor Operated Valves", Revision 1, March 1977.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

COMMONWEALTH EDISON COMPANY

DOCKET NO. 50-374

LASALLE COUNTY STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 60
License No. NPF-18


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment filed by the Commonwealth Edison Company (the licensee), dated September 21, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the enclosure to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-18 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 60, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This amendment is effective upon date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Richard J. Barrett, Director
Project Directorate III-2
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: December 18, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 60

FACILITY OPERATING LICENSE NO. NPF-18

DOCKET NO. 50-374

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain a vertical line indicating the area of change.

REMOVE

3/4 8-25

B 3/4 8-3

INSERT

3/4 8-25

3/4 8-25a

B 3/4 8-3

TABLE 3.8.3.2-1 (Continued)

<u>DEVICE NUMBER AND LOCATION</u>	<u>SYSTEM/COMPONENT POWERED</u>
d) MCC 234X-1 (Compt. B4)	NB/MOV 2B21-F002
e) MCC 236Y-1 (Compt. B2 (Normal))	RH/MOV 2E12-F009
f) MCC 236Y-2 (Compt. E4)	RI/MOV 2E51-F063
g) MCC 235Y-1 (Compt. A1)	RR/MOV 2B33-F023A
h) MCC 235Y-1 (Compt. A4)	RR/MOV 2B33-F067A
i) MCC 233-1 (Compt. C2)	RT/MOV 2G33-F102
j) MCC-233-1 (Compt. E1)	NB/MOV 2B21-F005
k) MCC-236Y-2 (Compt. B1)	NB/MOV 2B21-F016
l) MCC 236Y-2 (Compt. E1)	RH/MOV 2E12-F099A
m) MCC 236Y-1 (Compt. E4)	RT/MOV 2G33-F001
n) MCC 236Y-2 (Compt. A5)	WR/MOV 2WR180
o) MCC 236Y-2 (Compt. D6)	RH/MOV 2E12-F099B
p) MCC 236Y-1 (Compt. H5)	VP/MOV 2VP113B
q) MCC 236Y-1 (Compt. H4)	VP/MOV 2VP114A
r) MCC 236Y-1 (Compt. H3)	VP/MOV 2VP113A
s) MCC 236Y-1 (Compt. H6)	VP/MOV 2VP114B
t) MCC 236Y-2 (Compt. A4)	WR/MOV 2WR179
u) MCC 235Y-1 (Compt. D3)	RT/MOV 2G33-F101
v) MCC 235Y-1 (Compt. D4)	RT/MOV 2G33-F100
w) MCC 233-1 (Compt. C3)	RT/MOV 2G33-F106
x) MCC 236Y-2 (Compt. D5)	RI/MOV 2E51-F076
y) MCC 235X-1 (Compt. C2/C3) (Emerg)	RH/MOV 2E12-F009
z) MCC 233-2 (Compt. AC1)	VP/Drywell Cooler 2VP15SA
aa) MCC 233-2 (Compt. AB1)	VP/Drywell Cooler 2VP15SE

TABLE 3.8.3.2-1 (continued)

<u>DEVICE NUMBER AND LOCATION</u>	<u>SYSTEM/COMPONENT POWERED</u>
ab) MCC 233-2 (Compt. AB2)	VP/Drywell Cooler 2VP15SD
ac) MCC 234X-2 (Compt. H1)	VP/Drywell Cooler 2VP15SB
ad) MCC 234X-2 (Compt. H2)	VP/Drywell Cooler 2VP15SC
ae) MCC 234X-2 (Compt. J1)	VP/Drywell Cooler 2VP15SF
2. Backup breakers are located in the front of the respective MCC.	
a) MCC 235X-2 (Compt. AA4)	VP/Pri. Cont. Vent Supply Fan 2A Backup
b) MCC 236X-2 (Compt. AA4)	VP/Pri. Cont. Vent Supply Fan 2B Backup

ELECTRICAL POWER SYSTEMS

BASES

A.C. SOURCES AND ONSITE POWER DISTRIBUTION SYSTEMS (Continued)

specific gravity, ensures that the decrease in rating will be less than the safety margin provided in sizing; (3) the allowable value for an individual cell's specific gravity ensures that an individual cell's specific gravity will not be more than 0.040 below the manufacturer's full charge specific gravity and that the overall capability of the battery will be maintained within an acceptable limit; and (4) the allowable value for an individual cell's float voltage, greater than 2.07 volts, ensures the battery's capability to perform its design function.

The battery load profile and battery charger specifications will be maintained and are located in Chapter 8, "Electrical Power", section of the Updated Final Safety Analysis Report, UFSAR.

3/4.8.3 ELECTRICAL EQUIPMENT PROTECTIVE DEVICES

Primary containment medium and high voltage (6.9 kV, 4.16 kV and 480 volt) electrical penetrations and penetration conductors are protected by either de-energizing circuits not required during reactor operation or demonstrating the OPERABILITY of primary and backup overcurrent protection circuit breakers by periodic surveillance.

The surveillance requirements applicable to lower voltage circuit breakers and fuses provides assurance of breaker and fuse reliability by testing at least one representative sample of each manufacturers brand of circuit breaker and/or fuse. Each manufacturer's molded case and metal case circuit breakers and/or fuses are grouped into representative samples which are then tested on a rotating basis to ensure that all breakers and/or fuses are tested. If a wide variety exists within any manufacturer's brand of molded case circuit breakers and/or fuses, it is necessary to divide that manufacturer's breakers and/or fuses into groups and treat each group as a separate type of breaker or fuses for surveillance purposes.

The bypassing of the motor operated valves thermal overload protection continuously or during accident conditions by integral bypass devices ensures that the thermal overload protection will not prevent safety related valves from performing their function. The Surveillance Requirements for demonstrating the bypassing of the thermal overload protection continuously and during accident conditions are in accordance with Regulatory Guide 1.106 "Thermal Overload Protection for Electric Motors on Motor Operated Valves", Revision 1, March 1977.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 76 TO FACILITY OPERATING LICENSE NO. NPF-11 AND
AMENDMENT NO. 60 TO FACILITY OPERATING LICENSE NO. NPF-18
COMMONWEALTH EDISON COMPANY
LASALLE COUNTY STATION, UNITS 1 AND 2
DOCKET NOS. 50-373 AND 50-374

1.0 INTRODUCTION

The licensee installed six cooling units in the drywells of Units 1 and 2 as part of a commitment to the NRC. This was accomplished to restore design redundancy to the drywell ventilation system. Technical Specification 3/4.8.3.2, "Primary Containment Penetration Conductor Overcurrent Protective Devices," establishes requirements for the operability of these devices. The licensee proposes to add to Table 3.8.3.2-1, the new overcurrent protective devices associated with the new cooling units to assure they are properly controlled and tested. Also, to clarify the Bases (3/4.8.3), "Electrical Equipment Protective Devices," it is proposed to identify the electrical devices as medium and high voltage (6.9 kV, 4.16 kV and 480 volt).

2.0 EVALUATION

The licensee installed new drywell cooling units to restore design redundancy to the drywell ventilation system. This modification necessitated the addition of primary containment penetration conductor overcurrent protective devices. This proposed amendment adds these devices to Table 3.8.3.2-1, so that the requirements of Technical Specification 3/4.8.3.2 will apply.

Technical Specification 3/4.8.3.2, Limiting Condition for Operation (LCO), requires all devices in Table 3.8.3.2-1 be operable in Operational Conditions 1, 2, and 3. The LCO requires that the affected penetrations be de-energized if one or more of the protective devices in the penetrations is inoperable. A test program to select and test at least 10% of each type breaker is required by the surveillance requirements. These new devices will be added to this program and tested periodically on a rotating basis. If failures occur, then the sample size is increased to include at least 10% of the inoperable type of device.

Each device is also subject to an inspection and preventive maintenance in accordance with procedures in accordance with the manufacturer's recommendations. The Bases is also revised to highlight the voltage rating of the protective devices included in this specification.

This proposed Technical Specification amendment is an administrative change to add protective devices to reflect the addition of cooling units into the primary containment and to clarify the Bases by specifying the voltage ratings for the devices.

3.0 ENVIRONMENTAL CONSIDERATION

The amendments involve a change to a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR 20 or a change to a surveillance requirement. The staff has determined that these amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that these amendments involve no significant hazards consideration and there has been no public comment on such finding. Accordingly, these amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of this amendment.

4.0 CONCLUSION

The staff has concluded, based on the considerations discussed above, that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of these amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: Robert M. Pulsifer

Dated: December 18, 1990