

March 1, 1988

Docket No. 50-373

Mr. L. D. Butterfield, Jr.
Nuclear Licensing Manager
Commonwealth Edison Company
P. O. Box 767
Chicago, Illinois 60690

DISTRIBUTION:

Docket File
PDIII-2 r/f
NRC/Local PDRs
GHolahan
LLuther
PShemanski
OGC-Rock.

ACRS (10)
GPA/PA
PDIII-2 plant file

Dear Mr. Butterfield:

SUBJECT: ISSUANCE OF AMENDMENT NO. 54 TO FACILITY OPERATING LICENSE
NPF-11 - LASALLE COUNTY STATION, UNIT 1 (TAC NO. 66102)

The U. S. Nuclear Regulatory Commission has issued the enclosed Amendment No. 54 to Facility Operating License No. NPF-11 for the LaSalle County Station, Unit 1. This amendment is in response to your letters dated August 25 and November 17, 1987.

The amendment revises the LaSalle County Station, Unit 1 Technical Specifications by changing the identification of the compartment in which the normal and emergency supply breakers for the shutdown cooling isolation valve are located.

A copy of the related Safety Evaluation supporting Amendment No. 54 to Facility Operating License No. NPF-11 is enclosed.

The Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Paul Shemanski

Paul Shemanski, Project Manager
Project Directorate III-2
Division of Reactor Projects - III
IV, V and Special Projects

Enclosures:

1. Amendment No. 54 to License No. NPF-11
2. Safety Evaluation

cc w/enclosure:
See next page

P.S.

PDIII-2:PM
PShemanski:bj
2/18/88

PDIII-2:LA
LLuther
2/18/88

PDIII-2:PD
DMiller
2/18/88

8803070324 880301
PDR ADOCK 05000373
P PDR

Mr. L. D. Butterfield, Jr.
Commonwealth Edison Company

LaSalle County Nuclear Power Station
Units 1 & 2

cc:
Philip P. Steptoe, Esquire
Suite 5200
Three First National Plaza
Chicago, Illinois 60603

John W. McCaffrey
Chief, Public Utilities Division
160 North LaSalle Street, Room 900
Chicago, Illinois 60601

Assistant Attorney General
100 West Randolph Street
Chicago, Illinois 60601

Resident Inspector/LaSalle, NPS
U. S. Nuclear Regulatory Commission
Rural Route No. 1
P. O. Box 224
Marseilles, Illinois 61341

Chairman
LaSalle County Board of Supervisors
LaSalle County Courthouse
Ottawa, Illinois 61350

Attorney General
500 South 2nd Street
Springfield, Illinois 62701

Chairman
Illinois Commerce Commission
Leland Building
527 East Capitol Avenue
Springfield, Illinois 62706

Mr. Gary N. Wright, Manager
Nuclear Facility Safety
Illinois Department of Nuclear Safety
1035 Outer Park Drive, 5th Floor
Springfield, Illinois 62704

Regional Administrator, Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

COMMONWEALTH EDISON COMPANY
DOCKET NO. 50-373
LASALLE COUNTY STATION, UNIT 1
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 54
License No. NPF-11


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The applications for amendment filed by the Commonwealth Edison Company (the licensee), dated August 25, 1987 and supplemented November 17, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the enclosure to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-11 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 54, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This amendment is effective 15 days after the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in cursive script, reading "Daniel R. Muller".

Daniel R. Muller, Director
Project Directorate III-2
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosure:
Changes to the Technical
Specifications

Date of Issuance: March 1, 1988

ENCLOSURE TO LICENSE AMENDMENT NO. 54

FACILITY OPERATING LICENSE NO. NPF-11

DOCKET NO. 50-373

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains a vertical line indicating the area of change.

REMOVE

3/4 8-25

INSERT

3/4 8-25

TABLE 3.8.3.2-1 (Continued)

<u>DEVICE NUMBER AND LOCATION</u>	<u>SYSTEM/COMPONENT POWERED</u>
d) MCC 134X-1 (Compt. B4)	NB/MOV 1B21-F002
e) MCC 136Y-1 (Compt. B-2) (Normal)	RH/MOV 1E12-F009
f) MCC 136Y-2 (Compt. E4)	RI/MOV 1E51-F063
g) MCC 135Y-1 (Compt. A1)	RR/MOV 1B33-F023A
h) MCC 135Y-1 (Compt. A4)	RR/MOV 1B33-F067A
i) MCC 133-1 (Compt. C2)	RT/MOV 1G33-F102
j) MCC-133-1 (Compt. E1)	NB/MOV 1B21-F005
k) MCC-136Y-2 (Compt. B1)	NB/MOV 1B21-F016
l) MCC 136Y-2 (Compt. E1)	RH/MOV 1E12-F099A
m) MCC 136Y-1 (Compt. E4)	RT/MOV 1G33-F001
n) MCC 136Y-2 (Compt. A5)	WR/MOV 1WR180
o) MCC 136Y-2 (Compt. D6)	RH/MOV 1E12-F099B
p) MCC 136Y-1 (Compt. H5)	VP/MOV 1VP113B
q) MCC 136Y-1 (Compt. H4)	VP/MOV 1VP114A
r) MCC 136Y-1 (Compt. H3)	VP/MOV 1VP113A
s) MCC 136Y-1 (Compt. H6)	VP/MOV 1VP114B
t) MCC 136Y-2 (Compt. A4)	WR/MOV 1WR179
u) MCC 135Y-1 (Compt. D3)	RT/MOV 1G33-F101
v) MCC 135Y-1 (Compt. D4)	RT/MOV 1G33-F100
w) MCC 133-1 (Compt. C3)	RT/MOV 1G33-F106
x) MCC 136Y-2 (Compt. D5)	RI/MOV 1E51-F076
y) MCC 135X-1 (Compt. C2/C3) (Emerg)	RH/MOV 1E12-F009
2. Type K-M Cat # NZ M12V-630/ZM12AV	
a) MCC 135X-2 (Compt. E4)	VP/Pri. Cont. Vent Supply Fan 1A Backup
b) MCC 136X-2 (Compt. G4)	VP/Pri. Cont. Vent Supply Fan 1B Backup



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
SUPPORTING AMENDMENT NO. 54 TO FACILITY OPERATING LICENSE NO. NPF-11
COMMONWEALTH EDISON COMPANY
LASALLE COUNTY STATION, UNIT 1
DOCKET NO. 50-373

1.0 INTRODUCTION

By letters dated August 25, and November 17, 1987, Commonwealth Edison proposed to amend Facility Operating License NPF-11 pursuant to 10 CFR 50.90. The proposed amendment changes the identification of the compartment in which the normal and emergency supply breakers for the shutdown cooling isolation valve are located and is purely administrative in nature.

2.0 EVALUATION

The amendment requested changes the identification of the compartment in which the normal and emergency supply breakers for the shutdown cooling isolation valve (1E12 F0009) are located. This change was required because CECO has replaced the motor operator with one of the larger capacity to increase the reliability of the valve. The new, larger capacity operator requires the use of larger capacity breakers which will not fit into the existing cubicles. The replacement breakers will be installed in larger compartments within the same motor control center as the originals. This change is purely administrative in nature to correct the identification of these new cubicle locations.

The staff has reviewed the proposed Technical Specification changes and concludes that the resultant Unit 1 license amendment is acceptable.

3.0 ENVIRONMENTAL CONSIDERATION

This amendment involves changes in the installation and use of a facility component located within the restricted area as defined in 10 CFR Part 20 and changes in surveillance requirements. The staff has determined that this amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that this amendment involves a no significant hazards consideration and there has been no public comment on such finding. Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of this amendment.

4.0 CONCLUSION

The Commission made a proposed determination that the amendment involves no significant hazards consideration which was published in the FEDERAL REGISTER (52 FR 49220) on December 30, 1987, and consulted with the state of Illinois. No public comments were received, and the state of Illinois did not have any comments.

The staff has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

REFERENCE

Letters from C. Allen, Commonwealth Edison to USNRC dated August 25 and November 17, 1987.

Principal Contributor: Paul Shemanski, NRR/PDIII-2

Dated: March 1, 1988