

June 18, 1996

Mr. D. L. Farrar
Manager, Nuclear Regulatory Services
Commonwealth Edison Company
Executive Towers West III
1400 Opus Place, Suite 500
Downers Grove, IL 60515

SUBJECT: ISSUANCE OF AMENDMENTS (TAC NOS. M94938 AND M94939)

Dear Mr. Farrar:

The U.S. Nuclear Regulatory Commission (Commission) has issued the enclosed Amendment No. 113 to Facility Operating License No. NPF-11 and Amendment No. 98 to Facility Operating License No. NPF-18 for the LaSalle County Station, Units 1 and 2, respectively. The amendments are in response to your application dated December 21, 1995.

The amendments delete the requirement to place the reactor mode switch in the Shutdown position if a stuck open safety/relief valve can not be closed within 2 minutes. The operator will still be required to scram the reactor if suppression pool average water temperature reaches 110 degrees Fahrenheit or greater. The amendment also includes editorial changes to the index pages.

A copy of the Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

/s/

Donna M. Skay, Project Manager
Project Directorate III-2
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Docket Nos. 50-373, 50-374

Enclosures: 1. Amendment No. 113 to NPF-11
2. Amendment No. 98 to NPF-18
3. Safety Evaluation

cc w/encl: see next page

DISTRIBUTION:

Docket File

J. Roe, JWR

D. Skay

G. Hill (4), T5C3

B. Clayton RIII

PUBLIC

R. Capra

OGC, 015B18

C. Grimes, 011E22

PDIII-2 r/f

C. Moore

R. Jones

ACRS, T2E26

200096

DOCUMENT NAME: G:\LA94938.AMD

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

| | | | | | |
|--------|------------|------------|------------|----------|----------|
| OFFICE | LA:PDIII-2 | PM:PDIII-2 | D:PDIII-2 | BC:SRXB | OGC |
| NAME | CMOORE | DSKAY:avl | RCAPRA ROE | RJONES | |
| DATE | 05/17/96 | 05/17/96 | 05/17/96 | 05/17/96 | 05/17/96 |

9606210259 960618
PDR ADOCK 05000373
PDR

OFFICIAL RECORD COPY

FILE CENTER COPY