Mr. D. L. Farrar Manager, Nuclear Regulatory Services Commonwealth Edison Company Executive Towers West III 1400 Opus Place, Suite 500 Downers Grove, IL 60515

SUBJECT: CORRECTION OF ISSUANCE OF AMENDMENTS - LASALLE COUNTY STATION, UNITS 1 AND 2 (TAC NOS. M91375 AND M91376)

Dear Mr. Farrar:

On August 15, 1995, the U.S. Nuclear Regulatory Commission issued Amendment No. 105 to Facility Operating License No. NPF-11 and Amendment No. 91 to Facility Operating License No. NPF-18 for the LaSalle County Station, Units 1 and 2, respectively.

The enclosed pages associated with those amendments were in error.

Please incorporate the enclosed corrected pages in your copy of the abovementioned amendments.

We regret any inconvenience this error may have created.

Sincerely,

Original signed by:

Robert M. Latta, Project Manager Project Directorate III-2 Division of Reactor Projects - III/IV Office of Nuclear Reactor Regulation

Docket Nos. 50-373, 50-374

Enclosures: Corrected pages

cc w/encls: See next page

DISTRIBUTION: Docket File PDIII-2 r/f RCapra RLatta OGC ACRS (4)

PUBLIC JRoe (JWR) CMoore CGrimes, O-11/E/22 GHill (4) BClayton, RIII

9509140275 93	50912
PDR ADDCK 03	5000373
P	PDR

DOCUMENT NAME: G:\CMVLJR\LASALLE\LA91375.LTR To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE		PM:PDIII-	2 E	p:PDIII-2	1	F			
NAME	dmoore	RLATTA:av	1 RML	RCAPRA	ba		 	<u> </u>	
DATE	09/0/95	09/12/95	(1	09/12/95	20 4				
	2300		OFFICI	AL RECORD	COPY)OPY

D. L. Farrar Commonwealth Edison Company

cc:

Phillip P. Steptoe, Esquire Sidley and Austin One First National Plaza Chicago, Illinois 60603

Assistant Attorney General 100 West Randolph Street Suite 12 Chicago, Illinois 60601

U.S. Nuclear Regulatory Commission Resident Inspectors Office LaSalle Station 2605 N. 21st Road Marseilles, Illinois 61341-9756

Chairman LaSalle County Board of Supervisors LaSalle County Courthouse Ottawa, Illinois 61350

Attorney General 500 South Second Street Springfield, Illinois 62701

Chairman Illinois Commerce Commission Leland Building 527 East Capitol Avenue Springfield, Illinois 62706

Illinois Department of Nuclear Safety Office of Nuclear Facility Safety 1035 Outer Park Drive Springfield, Illinois 62704

Regional Administrator U.S. NRC, Region III 801 Warrenville Road Lisle, Illinois 60532-4351

LaSalle Station Manager LaSalle County Station Rural Route 1 P.O. Box 220 Marseilles, Illinois 61341 LaSalle County Station Unit Nos. 1 and 2

Robert Cushing Chief, Public Utilities Division Illinois Attorney General's Office 100 West Randolph Street Chicago, Illinois 60601

Michael I. Miller, Esquire Sidley and Austin One First National Plaza Chicago, Illinois 60603

ATTACHMENT TO LICENSE AMENDMENT NO. 105

FACILITY OPERATING LICENSE NO. NPF-11

DOCKET NO. 50-373

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain a vertical line indicating the area of change. Pages indicated with an asterisk are provided for convenience only.

REMOVE

INSERT

	XIV 3/4 3/4 3/4	5-4 5-5 7-7		XIV 3/4 3/4 3/4	5-4 5-5 7-7
	3/4	7-8		3/4	7-8
В	3/4	5-1	В	3/4	5-1
B	3/4	5-2	В	3/4	5-2
_		-	В	3/4	5-3
В	3/4	7-1	В	3/4	7-1
*B	3/4	7-2	*B	3/4	7-2

<u>INDEX</u>

BASES	
SECTION	PAGE
3/4.5 EMER	GENCY CORE COOLING SYSTEMS
3/4.5	.1 and 3/4.5.2 ECCS-OPERATING and SHUTDOWN B 3/4 5-1
3/4.5	.3 SUPPRESSION CHAMBER B 3/4 5-3
3/4.6 CONT	AINMENT SYSTEMS
3/4.6	.1 PRIMARY CONTAINMENT
	Primary Containment Integrity B 3/4 6-1
	Primary Containment Leakage B 3/4 6-1
	Primary Containment Air Locks B 3/4 6-1
	MSIV Leakage Control System B 3/4 6-1
	Drywell and Suppression Chamber Internal Pressure B 3/4 6-2
	Drywell Average Air Temperature B 3/4 6-2
	Drywell and Suppression Chamber Purge System B 3/4 6-2
3/4.6	.2 DEPRESSURIZATION SYSTEMS B 3/4 6-3
3/4.6	.3 PRIMARY CONTAINMENT ISOLATION VALVES B 3/4 6-4
3/4.6	.4 VACUUM RELIEF B 3/4 6-4
3/4.6	.5 SECONDARY CONTAINMENT B 3/4 6-5
3/4.6	.6 PRIMARY CONTAINMENT ATMOSPHERE CONTROL B 3/4 6-5

.

w

EMERGENCY CORE COOLI' SYSTEMS

SURVEILLANCE REQUIREMENTS

4.5.1 ECCS divisions 1, 2, and 3 shall be demonstrated OPERABLE by:

- a. At least once per 31 days for the LPCS, LPCI, and HPCS systems:
 - 1. Verifying by venting at the high point vents that the system piping from the pump discharge valve to the system isolation valve is filled with water.
 - 2. Performance of a CHANNEL FUNCTIONAL TEST of the:
 - a) Discharge line "keep filled" pressure alarm instrumentation, and
 - b) Header delta P instrumentation.
 - 3. Verifying that each valve, manual, power operated, or automatic, in the flow path that is not locked, sealed, or otherwise secured in position, is in its correct position.
 - Verifying that each ECCS corner room watertight door is closed, except during entry to and exit from the room.
- b. Verifying that, when tested pursuant to Specification 4.0.5, each:
 - 1. LPCS pump develops a flow of at least 6350 gpm against a test line pressure greater than or equal to 290 psig.
 - 2. LPCI pump develops a flow of at least 7200 gpm against a test line pressure greater than or equal to 130 psig.
 - 3. HPCS pump develops a flow of at least 6250 gpm against a test line pressure greater than or equal to 370 psig.
- c. For the LPCS, LPCI and HPCS systems, at least once per 18 months:
 - 1. Performing a system functional test which includes simulated automatic actuation of the system throughout its emergency operating sequence and verifying that each automatic valve in the flow path actuates to its correct position. Actual injection of coolant into the reactor vessel may be excluded from this test.
 - 2. Performing a CHANNEL CALIBRATION of the:
 - a) Discharge line "keep filled" pressure alarm instrumentation and verifying the:
 - 1) High pressure setpoint allowable value and the low pressure setpoint allowable value of the:

ATTACHMENT TO LICENSE AMENDMENT NO. 91

FACILITY OPERATING LICENSE NO. NPF-18

DOCKET NO. 50-374

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain a vertical line indicating the area of change. Pages indicated with an asterisk are provided for convenience only.

REMOVE

INSERT

.

	XIV			XIV	
	3/4	5- 5		3/4	5-5
	3/4	7-7		3/4	7-7
	3/4	7-8		3/4	7-8
В	3/4	5-1	В	3/4	5-1
B	3/4	5-2	В	3/4	5-2
-		-	В	3/4	5-3
В	3/4	7-1	В	3/4	7-1
*B	3/4	7-2	*B	3/4	7-2

<u>INDEX</u>

BASES		
SECTION		PAGE
3/4.5 EMERGENO	CY CORE COOLING SYSTEMS	
3/4.5.1 a	and 3/4.5.2 ECCS-OPERATING and SHUTDOWN	B 3/4 5-1
3/4.5.3	SUPPRESSION CHAMBER	B 3/4 5-3
3/4.6 CONTAIN	MENT SYSTEMS	
3/4.6.1	PRIMARY CONTAINMENT	
	Primary Containment Integrity	B 3/4 6-1
	Primary Containment Leakage	B 3/4 6-1
	Primary Containment Air Locks	B 3/4 6-1
	MSIV Leakage Control System	B 3/4 6-1
	Drywell and Suppression Chamber Internal Pressure	B 3/4 6-2
	Drywell Average Air Temperature	B 3/4 6-2
	Drywell and Suppression Chamber Purge System	B 3/4 6-2
3/4.6.2	DEPRESSURIZATION SYSTEMS	B 3/4 6-3
3/4.6.3	PRIMARY CONTAINMENT ISOLATION VALVES	B 3/4 6-4
3/4.6.4	VACUUM RELIEF	B 3/4 6-4
3/4.6.5	SECONDARY CONTAINMENT	B 3/4 6-5
3/4.6.6	PRIMARY CONTAINMENT ATMOSPHERE CONTROL	B 3/4 6-5

.