

MAR 28 1985

Docket No.: 50-374

Mr. Dennis L. Farrar
Director of Nuclear Licensing
Commonwealth Edison Company
P. O. Box 767
Chicago, Illinois 60690

Dear Mr. Farrar:

Subject: Amendment No. 8 to Facility Operating License No. NPF-18 La Salle
County Station, Unit 2

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 8 to Facility Operating License No. NPF-18 for the La Salle County Station, Unit 2. This Amendment is in response to two letters dated January 8, 1985 as supplemented by letters dated January 30, 1985 and February 5, 1985, which you submitted to revise the La Salle County Station, Unit 2 license to extend the scheduler requirements of License Condition 2.C.(5) for replacement/modification and test completion for specific equipment subject to the environmental qualification rule. The extension is from March 31, 1985 to November 30, 1985. We expect compliance for these remaining components at the earliest practicable time but in no event later than November 30, 1985.

A copy of the related safety evaluation supporting Amendment No. 8 to Facility Operating License NPF-18 is enclosed.

Sincerely,

A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing

Enclosures:

1. Amendment No. 8 to NPF-18
2. Safety Evaluation

cc w/enclosures:
See next page

DISTRIBUTION:
See attached page

*See previous concurrence concurren on by:

LB#2/DL
*ABournia:dh
3/21/85

LB#2/DL
*EGHylton
3/21/85

LB#2/DL
*ASchwencer
3/27/85

AD/L/DL
*TMNovak
3/25/85

8504080036 850328
PDR ADDCK 05000374
P PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

MAR 28 1985

Docket No.: 50-374

Mr. Dennis L. Farrar
Director of Nuclear Licensing
Commonwealth Edison Company
P. O. Box 767
Chicago, Illinois 60690

Dear Mr. Farrar:

Subject: Amendment No. 8 to Facility Operating License No. NPF-18 La Salle
County Station, Unit 2

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 8 to Facility Operating License No. NPF-18 for the La Salle County Station, Unit 2. This Amendment is in response to two letters dated January 8, 1985 as supplemented by letters dated January 30, 1985 and February 5, 1985, which you submitted to revise the La Salle County Station, Unit 2 license to extend the schedular requirements of License Condition 2.C.(5) for replacement/modification and test completion for specific equipment subject to the environmental qualification rule. The extension is from March 31, 1985 to November 30, 1985. We expect compliance for these remaining components at the earliest practicable time but in no event later than November 30, 1985.

A copy of the related safety evaluation supporting Amendment No. 8 to Facility Operating License NPF-18 is enclosed.

Sincerely,

A handwritten signature in cursive script, reading "A. Schwencer", is positioned above the typed name.

A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing

Enclosures:

1. Amendment No. 8 to NPF-18
2. Safety Evaluation

cc w/enclosures:
See next page

La Salle

Mr. Dennis L. Farrar
Director of Nuclear Licensing
Commonwealth Edison Company
P.O. Box 767
Chicago, Illinois 60690

cc: Philip P. Steptoe, Esquire
Suite 4200
One First National Plaza
Chicago, Illinois 60603

Assistant Attorney General
188 West Randolph Street
Suite 2315
Chicago, Illinois 60601

Michael J. Jordan, Resident Inspector
La Salle, NPS, U.S.N.R.C.
P.O. Box 224
Marseilles, Illinois 61364

Chairman
La Salle County Board of Supervisors
La Salle County Courthouse
Ottawa, Illinois 61350

Attorney General
500 South 2nd Street
Springfield, Illinois 62701

The Honorable Tom Corcoran
United States House of Representatives
Washington, D.C. 20515

Chairman
Illinois Commerce Commission
Leland Building
527 East Capitol Avenue
Springfield, Illinois 62706

Mr. Gary N. Wright, Manager
Nuclear Facility Safety
Illinois Department of Nuclear Safety
1035 Outer Park Drive, 5th Floor
Springfield, Illinois 62704

John W. McCaffrey
Chief, Public Utilities Division
160 North LaSalle Street, Room 900
Chicago, Illinois 60601

DISTRIBUTION:

Document File

NRC PDR

Local PDR

NSIC

PRC

LB#2 Rdg.

E. Hylton

A. Bournia

A. Schwencer

J. Saltzman, SAB

C. Miles

H. R. Denton

J. Rutberg

A. Toalston

WMiller, LFMB

J. Partlow

B. Grimes

E. L. Jordan

L. Harmon

T. Barnhart (4)



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

MAR 28 1985

COMMONWEALTH EDISON COMPANY
DOCKET NO. 50-374
LA SALLE COUNTY STATION, UNIT 2
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 8
License No. NPF-18

1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
 - A. The application for amendment filed by the Commonwealth Edison Company, dated January 8, 1985, January 30, 1985 and February 5, 1985, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, paragraph 2.C.(5) of the Facility Operating License No. NPF-18 is hereby amended to read as follows:


(5) Environmental Qualification (Section 3.11, SER, SSER#1, SSER #5)

Prior to November 30, 1985, the licensee shall environmentally qualify all electrical equipment as required by 10 CFR 50.49.

8504080039 850328
PDR ADOCK 05000374
P PDR

3. This amendment is effective as of date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


for Harold R. Denton, Director
Office of Nuclear Reactor Regulation

Date of Issuance: March 28 , 1985



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION
AMENDMENT NO. 8 TO NPF-18
LA SALLE COUNTY STATION, UNIT 2
DOCKET NO. 50-374

Introduction

License Condition 2.C.(5) of License NPF-18 and Section 50.49, "Environmental Qualification of Electric Equipment Important to Safety for Nuclear Power Plants," established a deadline for completion of the environmental qualification of electrical equipment. By letters dated January 8, 1985, as supplemented by letters dated January 30, 1985 and February 5, 1985, Commonwealth Edison Company (licensee) requested an extension from March 31, 1985 to November 30, 1985.

Plants are allowed to operate prior to the deadline for qualification specified in 10 CFR 50.49, or any extension to that deadline granted by the staff or the Commission, with equipment whose qualification has not been completed if it can be shown that such operation will not present undue risk to the public health and safety pending complete qualification. Analyses, called justifications for continued operation (JCOs) in the case of an operating plant, and required to be performed by the licensee that demonstrate the plant can be operated in a safe manner with the equipment not yet qualified.

The licensee provided JCOs addressing the equipment for which an extension to the qualification deadline has been requested. In addition, the licensee indicated that the principle factors for not meeting the date were test complications, long procurement lead times and installation complexities.

Evaluation

Licensee Condition 2.C.(5) has been revised to incorporate a November 30, 1985 deadline for completion of environmental qualification of electrical equipment important to safety instead of the presently imposed March 31, 1985 deadline.

The licensee indicates that the total number of components requiring qualification for Unit 2 to 10 CFR 50.49 requirements are 745, 656 of which will be qualified prior to March 31, 1985. The items subject to the extension request and the justification offered by the licensee for each group of equipment, are as follows:

1. Fifty (50) Limitorque Valve Motor Operators to be modified to attain a qualified configuration. The operators have been ordered but will not be available until April 1985.

8504080042 850328
PDR ADOCK 05000374
P PDR

2. Four (4) S&K Flow Elements to be replaced by qualified elements. The qualifications of the original elements was determined to be insufficient late into the testing program, July 1984, and a long lead time is required for procurement of the new hardware.
3. Two (2) Delphi Hydrogen-Oxygen Analyzers to be modified to attain qualified configuration. The extension is requested because of the long procurement time for heat tracing systems and their associated control panels which are scheduled for delivery by August 1985.
4. One (1) Atomic International Hydrogen Recombiner to be modified to attain qualified configuration. The extension is warranted partly because of difficulty in procuring thermocouples needed to be replaced and also the complexity of the installation. The thermocouples are scheduled to be delivered August 1985.
5. Six (6) Klockner-Moeller AC Motor Control Centers are not qualified. Testing began in September 1984 but, due to long aging times and detailed functional testing of so many devices, this test will not be completed until September 1985. The test models represent the present installation so that no field modifications are anticipated.
6. Eight (8) Magnetrol Level Switches to be modified to attain qualified configuration. A unit outage is required to complete the modification work.
7. Eighteen (18) Terminal Boards to be modified to attain qualified configuration. Testing on these boards were completed on October 24, 1984, and the data is presently under evaluation by the licensee's Architect/Engineer (A/E). This review and recommendation for any corrective action by the A/E will be completed this month. Preliminary results of the A/E's review indicates that modifications maybe needed for terminal boards in safety-related instrumentation. All modifications identified in this evaluation will be completed prior to any operation after November 30, 1985.

The staff has reviewed each of the JCOs provided by the licensee and find them acceptable since they are based on essentially the same criteria that were used by the staff and its contractor to review JCO's previously submitted by licensees. These criteria, listed below, are also essentially the same as those contained in 10 CFR 50.49(i):

- a. The safety function can be accomplished by some other designated equipment that is qualified, and failure of the principal equipment as a result of the harsh environment will not degrade other safety functions or mislead the operator.

- b. Partial test data that does not demonstrate full qualification, but provides a basis for concluding the equipment will perform this function. If it can not be concluded from the available data that the equipment will not fail after completion of its safety function, then that failure must not result in significant degradation of any safety function or provide misleading information to the operator.
- c. Limited use of administrative controls over equipment that has not been demonstrated to be fully qualified. For any equipment assumed to fail as a result of the accident environment that failure must not result in significant degradation of any safety function or provide misleading information to the operator.

Based on the above evaluation, we conclude that continued operation of La Salle Unit 2, with the environmental qualification of the equipment identified above not fully established, will not present undue risk to the public health and safety. The staff finds that the requested schedule change is acceptable and License Condition 2.C.(5) may be revised accordingly.

Environmental Consideration

This amendment involves a change in the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that this amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR Section 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of this amendment.

Conclusion

The Commission made a proposed determination that the amendment involves no significant hazards consideration which was published in the Federal Register (50 FR 7420) on February 22, 1985. No public comments were received.

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Dated: **MAR 28 1985**