

JUN 24 1985

Docket No. 50-374

Mr. Dennis L. Farrar  
Director of Nuclear Licensing  
Commonwealth Edison Company  
Post Office Box 767  
Chicago, Illinois 60690

Dear Mr. Farrar:

This confirms our telephone authorization given on June 20, 1985, for the change in the Technical Specifications for La Salle County Station Unit 2, as requested in your letter of June 14, 1985. Facility Operating License NPF-18 is amended on June 20, 1985, by changing the instrument response time from 1 to 2 seconds for the Main Steam Line Low Pressure Instrument on Table 3.3.2-2 of the Technical Specifications.

The formal license amendment, our completed safety evaluation, and the Federal Register Notice for this change to the Technical Specifications are being processed and copies of these documents will be sent to you in the near future.

Sincerely,

Thomas M. Novak, Assistant Director  
for Licensing  
Division of Licensing

cc: See next page

DISTRIBUTION  
Docket File  
NRC PDR  
Local PDR  
PRC System  
NSIC  
LB#2 Reading  
Ehlyton  
ABournia  
Woodhead, OELD  
ACRS (16)  
JPartlow  
BGrimes  
EJordan

\*Previously concurred:

DL:LB#2	DL:LB#2
*ABournia	*WButler
06/20/85	06/20/85

DL:LB#2  
TNovak  
06/20/85

8507030559 850624  
PDR ADDCK 05000374  
P PDR

Docket No. 50-374

Mr. Dennis L. Farrar  
Director of Nuclear Licensing  
Commonwealth Edison Company  
Post Office Box 767  
Chicago, Illinois 60690

Dear Mr. Farrar:

This confirms our telephone authorization given on June 20, 1985, for the change in the Technical Specifications for La Salle County Station Unit 2, as requested in your letter of June 14, 1985. Facility Operating License NPF-18 is amended on June 20, 1985, by changing the instrument response time from 1 to 2 seconds for the Main Steam Line Low Pressure Instrument on Table 3.3.2-2 of the Technical Specifications.

The formal license amendment, our completed safety evaluation, and the Federal Register Notice for this change to the Technical Specifications is being processed and copies of these documents will be sent to you in the near future.

Sincerely,

Thomas M. Novak, Assistant Director  
for Licensing  
Division of Licensing

cc: See next page

DISTRIBUTION

DL:LB#2  
ABournia  
06/20/85

DL:LB#2  
WButler  
06/20/85

DL:LB#2  
TNovak  
06/ /85



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

JUN 24 1985

Docket No. 50-374

Mr. Dennis L. Farrar  
Director of Nuclear Licensing  
Commonwealth Edison Company  
Post Office Box 767  
Chicago, Illinois 60690

Dear Mr. Farrar:

This confirms our telephone authorization given on June 20, 1985, for the change in the Technical Specifications for La Salle County Station Unit 2, as requested in your letter of June 14, 1985. Facility Operating License NPF-18 is amended on June 20, 1985, by changing the instrument response time from 1 to 2 seconds for the Main Steam Line Low Pressure Instrument on Table 3.3.2-2 of the Technical Specifications.

The formal license amendment, our completed safety evaluation, and the Federal Register Notice for this change to the Technical Specifications are being processed and copies of these documents will be sent to you in the near future.

Sincerely,

A handwritten signature in dark ink, appearing to read "Tom Novak", is written over the typed name.

Thomas M. Novak, Assistant Director  
for Licensing  
Division of Licensing

cc: See next page

Mr. Dennis L. Farrar  
Commonwealth Edison Company

La Salle County Nuclear Power Station  
Units 1 & 2

cc: Philip P. Steptoe, Esquire  
Suite 4200  
One First National Plaza  
Chicago, Illinois 60603

John W. McCaffrey  
Chief, Public Utilities Division  
160 North La Salle Street, Room 900  
Chicago, Illinois 60601

Assistant Attorney General  
188 West Randolph Street  
Suite 2315  
Chicago, Illinois 60601

Michael J. Jordan, Resident Inspector  
La Salle, NPS, U.S.N.R.C.  
P.O. Box 224  
Marseilles, Illinois 61364

Chairman  
La Salle County Board of Supervisors  
La Salle County Courthouse  
Ottawa, Illinois 61350

Attorney General  
500 South 2nd Street  
Springfield, Illinois 62701

Chairman  
Illinois Commerce Commission  
Leland Building  
527 East Capitol Avenue  
Springfield, Illinois 62706

Mr. Gary N. Wright, Manager  
Nuclear Facility Safety  
Illinois Department of Nuclear Safety  
1035 Custer Park Drive, 5th Floor  
Springfield, Illinois 62704

Mr. James G. Keppler  
U. S. NRC, Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137