



*Pacific Gas and
Electric Company*

James R. Becker
Station Director

Diablo Canyon Power Plant
Mail Code 104/5/504
P.O. Box 56
Avila Beach, CA 93424

April 15, 2002

805.545.3462
Fax: 805.545.4234

PG&E Letter DCL-02-040

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Docket No. 50-275, OL-DPR-80
Docket No. 50-323, OL-DPR-82
Diablo Canyon Units 1 and 2
Monthly Operating Report for March 2002

Dear Commissioners and Staff:

Attached is the Monthly Operating Report for Diablo Canyon Power Plant, Units 1 and 2, for March 2002. This report is submitted in accordance with Technical Specification 5.6.4 and NRC Generic Letter 97-02.

Sincerely,

James R. Becker

Imp/1713/R0230813

Enclosures

cc/enc: Robert D. Glynn, Jr.
Kurt Larson
Barbara Lewis
Ellis W. Merschoff
David L. Proulx
Gregory M. Rueger
Girija S. Shukla
INPO Record Center

IE24

**MARCH 2002, OPERATION SUMMARIES
DIABLO CANYON POWER PLANT
UNITS 1 AND 2**

Summary of Unit 1 Operation

Unit 1 began March in Mode 1 (Power Operation), at approximately 100 percent power. There were no significant operational activities.

Summary of Unit 2 Operation

Unit 2 began March in Mode 1 at approximately 100 percent power. There were no significant operational activities.

Actuations of Safety or Pressurizer Power Operated Relief Valves

There were no challenges to the pressurizer power operated relief valves, pressurizer safety valves, or steam generator safety valves.

OPERATING DATA REPORT

DOCKET NO.: 50-275
UNIT NAME: Diablo Canyon Unit 1
DATE: 04/01/2002
COMPLETED BY: L. M. Parker
TELEPHONE: (805) 545-3386

REPORT MONTH: March 2002

1.	Design Electrical Rating (MWe - Net):	1,103
2.	Maximum Dependable Capacity (MWe - Net):	1,087

		This Month	YTD	Cumulative
3.	Number of Hours Reactor Critical:	744.0	2,160.0	129,580.0
4.	Number of Hours Generator On-Line:	744.0	2,160.0	128,202.3
5.	Unit Reserve Shutdown Hours:	0.0	0.0	0.0
6.	Net Electrical Energy Generated (MWH):	821,202	*2,377,415	132,535,504

* Correction: Unit 1 YTD Net Electrical Energy Generated for February should have been 1,556,213 MWH.

UNIT SHUTDOWNS

DOCKET NO.: 50-275
 UNIT NAME: Diablo Canyon Unit 1
 DATE: 04/01/2002
 COMPLETED BY: L. M. Parker
 TELEPHONE: (805) 545-3386

REPORT MONTH: March 2002

NO.	DATE	TYPE F (Forced) S (Scheduled)	DURATION (HOURS)	REASON ¹	METHOD OF SHUTTING DOWN ²	CAUSE & CORRECTIVE ACTIONS COMMENTS
N/A						There were no shutdowns this month.

1. Reason

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F- Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

2. Method

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation from Previous Month
- 5-Other

OPERATING DATA REPORT

DOCKET NO.: 50-323
UNIT NAME: Diablo Canyon Unit 2
DATE: 04/01/2002
COMPLETED BY: L. M. Parker
TELEPHONE: (805) 545-3386

REPORT MONTH: March 2002

1.	Design Electrical Rating (MWe - Net):	1119
2.	Maximum Dependable Capacity (MWe - Net):	1087

		This Month	YTD	Cumulative
3.	Number of Hours Reactor Critical:	744.0	2,128.1	124,809.9
4.	Number of Hours Generator On-Line:	744.0	2,123.0	123,347.0
5.	Unit Reserve Shutdown Hours:	0.0	0.0	0.0
6.	Net Electrical Energy Generated (MWH):	819,698	2,235,604	129,641,536

UNIT SHUTDOWNS

DOCKET NO.: 50-323
 UNIT NAME: Diablo Canyon Unit 2
 DATE: 04/01/2002
 COMPLETED BY: L. M. Parker
 TELEPHONE: (805) 545-3386

REPORT MONTH: March 2002

NO.	DATE	TYPE F (Forced) S (Scheduled)	DURATION (HOURS)	REASON ¹	METHOD OF SHUTTING DOWN ²	CAUSE & CORRECTIVE ACTIONS COMMENTS
N/A						There were no shutdowns this month.

1. Reason

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F- Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

2. Method

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation from Previous Month
- 5-Other