



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555
July 28, 1988

Docket Nos. 50-237
and 50-249

Mr. L. D. Butterfield, Jr.
Nuclear Licensing Manager
Commonwealth Edison Company
Post Office Box 767
Chicago, Illinois 60690

Dear Mr. Butterfield:

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT AND OPPORTUNITY
FOR HEARING (TAC NOS. 67562 AND 67563)

Re: Dresden Nuclear Power Station Unit Nos. 2 and 3.

The Commission has filed the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License and Opportunity for Hearing" with the Office of the Federal Register for publication. This notice relates to your request of March 28, 1988, to amend the Technical Specifications to correct the discrepancy between the Table 3.2.2 value for the 4KV emergency bus undervoltage trip (3092V) and the current trip value (2930V). It has been determined that the value in Table 3.2.2 is not consistent with the engineering and design basis upon which the actual trip value is based.

This amendment request is consistent with the NRC letter dated March 25, 1988 granting a temporary waiver of compliance.

Sincerely,

Marshall Grotenhuis
Marshall Grotenhuis, Sr. Project Manager
Project Directorate III-2
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosure:
As stated

cc: See next page

8808120025 880728
PDR ADDCK 05000237
P PNU

DF01
11

Mr. L. D. Butterfield, Jr.
Commonwealth Edison Company

Dresden Nuclear Power Station
Units 2 and 3

cc:

Michael Miller, Esq.
Sidley and Austin
One First National Plaza
Chicago, Illinois 60603

Mr. J. Eenigenburg
Plant Superintendent
Dresden Nuclear Power Station
Rural Route #1
Morris, Illinois 60450

U.S. Nuclear Regulatory Commission
Resident Inspection Office
Dresden Station
Rural Route #1
Morris, Illinois 60450

Chairman
Board of Supervisors of
Grundy County
Grundy County Courthouse
Morris, Illinois 60450

Regional Administrator
Nuclear Regulatory Commission, Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Mr. Michael C. Parker, Chief
Division of Engineering
Illinois Department of Nuclear Safety
1035 Outer Park Drive, 5th Floor
Springfield, Illinois 62704

Docket Nos. 50-237
and 50-249

Mr. L. D. Butterfield, Jr.
Nuclear Licensing Manager
Commonwealth Edison Company
Post Office Box 767
Chicago, Illinois 60690

DISTRIBUTION:

Docket File
NRC & Local PDRs
DCrutchfield
LLuther
MGrotenhuis
OGC-Rockville

PDIII-2 Plant File
PDIII-2 r/f
GHolahan
GPA/PA
ACRS (10)
DHagan

Dear Mr. Butterfield:

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT AND OPPORTUNITY
FOR HEARING (TAC NOS. 67562 AND 67563)

Re: Dresden Nuclear Power Station Unit Nos. 2 and 3.

The Commission has filed the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License and Opportunity for Hearing" with the Office of the Federal Register for publication. This notice relates to your request of March 28, 1988, to amend the Technical Specifications to correct the discrepancy between the Table 3.2.2 value for the 4KV emergency bus undervoltage trip (3092V) and the current trip value (2930V). It has been determined that the value in Table 3.2.2 is not consistent with the engineering and design basis upon which the actual trip value is based.

This amendment request is consistent with the NRC letter dated March 25, 1988 granting a temporary waiver of compliance.

Sincerely,

Marshall Grotenhuis, Sr. Project Manager
Project Directorate III-2
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosure:
As stated

cc: See next page

PDIII-2 <i>MG</i> MGrotenhuis/ww 4/17/88	PDIII-2 <i>LL</i> LLuther 4/13/88	PDIII-2 <i>DM</i> DMutler 4/25/88
--	---	---

DF01
||
||

A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, and to Michael Miller, Esquire, Sidley and Austin, One First National Plaza,

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board, that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

If a request for hearing is received, the Commission's staff may issue the amendment after it completes its technical review and prior to the completion of any required hearing if it publishes a further notice for public comment of its proposed finding of no significant hazards consideration in accordance with 10 CFR 50.91 and 50.92.

For further details with respect to this action, see the NRC letter to Commonwealth Edison Company dated March 25, 1988 confirming a temporary waiver of compliance and the application for amendment dated March 28, 1988, which are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C., and at the Morris Public Library, 604 Liberty Street, Morris, Illinois 60450.

Dated at Rockville, Maryland this day of

FOR THE NUCLEAR REGULATORY COMMISSION

Daniel R. Muller, Director
Project Directorate III-2
Division of Reactor Projects - III,
IV, V and Special Project

BS
PDIII-2
MGrotenhuis/ww
04/08 188

PDIII-212
LLuther
4/13/88

PDIII-211
DMuller
4/14/88

OGC
/ 188

From the [unclear] 4/14/88

Docket Nos. 50-237
and 50-249

Mr. L. D. Butterfield, Jr.
Nuclear Licensing Manager
Commonwealth Edison Company
Post Office Box 767
Chicago, Illinois 60690

DISTRIBUTION:

Docket File
NRC & Local PDRs
DCrutchfield
LLuther
MGrotenhuis
OGC-Rockville

PDIII-2 Plant File
PDIII-2 r/f
GHolahan
GPA/PA
ACRS (10)
DHagan

Dear Mr. Butterfield:

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT AND OPPORTUNITY
FOR HEARING (TAC NOS. 67562 AND 67563)

Re: Dresden Nuclear Power Station Unit Nos. 2 and 3.

The Commission has filed the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License and Opportunity for Hearing" with the Office of the Federal Register for publication. This notice relates to your request of March 28, 1988, to amend the Technical Specifications to correct the discrepancy between the Table 3.2.2 value for the 4KV emergency bus undervoltage trip (3092V) and the current trip value (2930V). It has been determined that the value in Table 3.2.2 is not consistent with the engineering and design basis upon which the actual trip value is based.

This amendment request is consistent with the NRC letter dated March 25, 1988 granting a temporary waiver of compliance.

Sincerely,

Marshall Grotenhuis, Sr. Project Manager
Project Directorate III-2
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosure:
As stated

cc: See next page

PDIII-2 *MG*
MGrotenhuis/ww
4/17/88

PDIII-2
LLuther *LL*
4/13/88

PDIII-2
DMiller
4/25/88

UNITED STATES NUCLEAR REGULATORY COMMISSION

COMMONWEALTH EDISON COMPANY

DOCKET NO. 50-249

NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT

TO FACILITY OPERATING LICENSE AND

OPPORTUNITY FOR HEARING

The United States Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. 25, issued to Commonwealth Edison Company (the licensee), for operation of the Dresden Nuclear Power Station Unit 3 located in Grundy County, Illinois.

The amendment would amend the Technical Specifications to correct the discrepancy between the Table 3.2.2 value for the 4KV emergency bus under-voltage trip (3092V) and the current trip value (2930V). It has been determined that the value in Table 3.2.2 is not consistent with the engineering and design basis upon which the actual trip value is based.

This amendment request is consistent with the NRC letter dated March 25, 1988 granting a temporary waiver of compliance.

Prior to issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

By June 2, 1988 the licensees may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for hearing and a petition for leave to intervene.

8808120027 880728
PDR ADDCK 05000237
P PNU

- 2 -

Requests for a hearing and petitions for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition, and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR §2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) the nature of the petitioner's right under the Act to be made a party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to fifteen (15) days prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

- 3 -

Not later than fifteen (15) days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter, and the bases for each contention set forth with reasonable specificity. Contentions shall be limited to matters within the scope of the amendment under consideration. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

A request for a hearing or a petition for leave to intervene shall be filed with the Secretary of the Commission, United States Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Docketing and Service Branch, or may be delivered to the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C., by the above date. Where petitions are filed during the last ten (10) days of the notice period, it is requested that the petitioner or representative for the petitioner promptly so inform the Commission by a toll-free telephone call to Western Union at 1-800-325-6000 (in Missouri 1-800-342-6700). The Western Union operator should be given Datagram Identification Number 3737 and the following message addressed to D. R. Muller: (petitioner's name and telephone number); (date Petition was mailed); (plant name); and (publication date and page number of this FEDERAL REGISTER notice).

- 4 -

A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, and to Michael Miller, Esquire, Sidley and Austin, One First National Plaza, Chicago, Illinois 60603.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board, that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

If a request for hearing is received, the Commission's staff may issue the amendment after it completes its technical review and prior to the completion of any required hearing if it publishes a further notice for public comment of its proposed finding of no significant hazards consideration in accordance with 10 CFR 50.91 and 50.92.

For further details with respect to this action, see the NRC letter to Commonwealth Edison Company dated March 25, 1988 confirming a temporary waiver of compliance and the application for amendment dated March 28, 1988, which are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C., and at the Morris Public Library, 604 Liberty Street, Morris, Illinois 60450.

Dated at Rockville, Maryland this 25th day of April 1988.

FOR THE NUCLEAR REGULATORY COMMISSION



Daniel R. Muller, Director
Project Directorate III-2
Division of Reactor Projects - III,
IV, V and Special Project

A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, and to Michael Miller, Esquire, Sidley and Austin, One First National Plaza,

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board, that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

If a request for hearing is received, the Commission's staff may issue the amendment after it completes its technical review and prior to the completion of any required hearing if it publishes a further notice for public comment of its proposed finding of no significant hazards consideration in accordance with 10 CFR 50.91 and 50.92.

For further details with respect to this action, see the NRC letter to Commonwealth Edison Company dated March 25, 1988 confirming a temporary waiver of compliance and the application for amendment dated March 28, 1988, which are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C., and at the Morris Public Library, 604 Liberty Street, Morris, Illinois 60450.

Dated at Rockville, Maryland this day of

FOR THE NUCLEAR REGULATORY COMMISSION

Daniel R. Muller, Director
Project Directorate III-2
Division of Reactor Projects - III,
IV, V and Special Project

BS
PDIII-2 *fn*
MGrotenhuis/ww
04/08 188

PDIII-22
LLuther
4/13/88

PDIII-221
DMiller
4/14/88

OGC *sc*
/ 188

Frankie
4/14/88