

July 6, 1988

Docket Nos. 50-237
and 50-249

Mr. Henry E. Bliss
Nuclear Licensing Manager
Commonwealth Edison Company
P.O. Box 767
Chicago, Illinois 60690

DISTRIBUTION:

Docket File
NRC & Local PDRs
PDIII-2 r/f
DCrutchfield
GHolahan
LLuther
MGrotenhuis
BSiegel

PDIII-2 Plant File
GPA/PA
ACRS (10)
JPartlow
EJordan
OGC-Beth.
MRing, RIII

Dear Mr. Bliss:

SUBJECT: ENVIRONMENTAL ASSESSMENT AND FINDING OF NO SIGNIFICANT IMPACT
(TAC NOS. 67562 AND 67563)

Re: Dresden Nuclear Power Station, Unit Nos. 2 and 3

Enclosed is the subject Environmental Assessment and Finding of No Significant Impact which relates to your submittal dated March 28, 1988 which proposed to amend the Technical Specifications to correct the discrepancy between the Table 3.2.2 value for the 4KV emergency bus undervoltage trip (3092V) and the current trip value (2930V). It has been determined that the value in Table 3.2.2 is not consistent with the engineering and design basis upon which the actual trip value is based.

This amendment request is consistent with the NRC letter dated March 15, 1988 granting a temporary waiver of compliance.

The notice is being forwarded to the Office of the Federal Register for publication.

Sincerely,

Byron Siegel, Senior Project Manager
Project Directorate III-2
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosure:
As stated

cc: See next page

*See previous concurrences

PDIII-2	PDIII-2	PDIII-2	OGC
*MGrotenhuis/ww	*LLuther	*DMuller	*
4/18/88	4/18/88	4/20/88	5/4/88

DF01
11

8807130145 880418
PDR ADOCK 05000237
P PDC

July 6, 1988

Docket Nos. 50-237
and 50-249

DISTRIBUTION:

Docket File
NRC & Local PDRs
PDIII-2 r/f
DCrutchfield
GHolahan
LLuther
MGrotenhuis

PDIII-2 Plant File
GPA/PA
ACRS (10)
JPartlow
EJordan
OGC-Beth.
MRing, RIII

Mr. L. D. Butterfield, Jr.
Nuclear Licensing Manager
Commonwealth Edison Company
P.O. Box 767
Chicago, Illinois 60690

Dear Mr. Butterfield:

SUBJECT: ENVIRONMENTAL ASSESSMENT AND FINDING OF NO SIGNIFICANT IMPACT
(TAC NOS. 67562 AND 67563)

Re: Dresden Nuclear Power Station, Unit Nos. 2 and 3

Enclosed is the subject Environmental Assessment and Finding of No Significant Impact which relates to your submittal dated March 28, 1988 which proposed to amend the Technical Specifications to correct the discrepancy between the Table 3.2.2 value for the 4KV emergency bus undervoltage trip (3092V) and the current trip value (2930V). It has been determined that the value in Table 3.2.2 is not consistent with the engineering and design basis upon which the actual trip value is based.

This amendment request is consistent with the NRC letter dated March 15, 1988 granting a temporary waiver of compliance.

The notice is being forwarded to the Office of the Federal Register for publication.

Sincerely,

Marshall Grotenhuis, Senior Project Manager
Project Directorate III-2
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosure:
As stated

cc: See next page

PDIII-2 *MO*
MGrotenhuis/ww
4/18/88

PDIII-2 *LL*
LLuther
4/18/88

PDIII-2 *DM*
DMutter
4/12/88

OGC *OC*
5/18/88



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

July 6, 1988

Docket Nos. 50-237
and 50-249

Mr. Henry E. Bliss
Nuclear Licensing Manager
Commonwealth Edison Company
P.O. Box 767
Chicago, Illinois 60690

Dear Mr. Bliss:

SUBJECT: ENVIRONMENTAL ASSESSMENT AND FINDING OF NO SIGNIFICANT IMPACT
(TAC NOS. 67562 AND 67563)

Re: Dresden Nuclear Power Station, Unit Nos. 2 and 3

Enclosed is the subject Environmental Assessment and Finding of No Significant Impact which relates to your submittal dated March 28, 1988 which proposed to amend the Technical Specifications to correct the discrepancy between the Table 3.2.2 value for the 4KV emergency bus undervoltage trip (3092V) and the current trip value (2930V). It has been determined that the value in Table 3.2.2 is not consistent with the engineering and design basis upon which the actual trip value is based.

This amendment request is consistent with the NRC letter dated March 15, 1988 granting a temporary waiver of compliance.

The notice is being forwarded to the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in cursive script that reads "Byron Siegel".

Byron Siegel, Senior Project Manager
Project Directorate III-2
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosure:
As stated

cc: See next page

Mr. L. D. Butterfield, Jr.
Commonwealth Edison Company

Dresden Nuclear Power Station
Units 2 and 3

cc:

Michael Miller, Esq.
Sidley and Austin
One First National Plaza
Chicago, Illinois 60603

Mr. J. Eenigenburg
Plant Superintendent
Dresden Nuclear Power Station
Rural Route #1
Morris, Illinois 60450

U.S. Nuclear Regulatory Commission
Resident Inspection Office
Dresden Station
Rural Route #1
Morris, Illinois 60450

Chairman
Board of Supervisors of
Grundy County
Grundy County Courthouse
Morris, Illinois 60450

Regional Administrator
Nuclear Regulatory Commission, Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Mr. Michael C. Parker, Chief
Division of Engineering
Illinois Department of Nuclear Safety
1035 Outer Park Drive, 5th Floor
Springfield, Illinois 62704

UNITED STATES NUCLEAR REGULATORY COMMISSIONCOMMONWEALTH EDISON COMPANYDOCKET NOS. 50-237 AND 50-249ENVIRONMENTAL ASSESSMENT AND FINDING OF NO SIGNIFICANT IMPACT

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to the Licenses and Technical Specifications in support of refueling and startup to the Commonwealth Edison Company (CECo, the licensee) for the Dresden Nuclear Power Station, Unit Nos. 2 and 3, located at the licensee's site in Grundy County, Illinois.

ENVIRONMENTAL ASSESSMENTIdentification of the Proposed Action:

The proposed action would amend the Technical Specifications to correct the discrepancy between the Table 3.2.2 value for the 4KV emergency bus undervoltage trip (3092V) and the current trip value (2930V). It has been determined that the value in Table 3.2.2 is not consistent with the engineering and design basis upon which the actual trip value is based.

This amendment request is consistent with the NRC letter dated March 25, 1988 granting a temporary waiver of compliance.

The Need for the Proposed Action:

By letter dated March 28, 1988, the licensee requested review and approval of a change to the Technical Specifications to correct a discrepancy in Table 3.2.2. Should this approval not be granted, the Technical Specification would not be consistent with the design basis and existing relays and could possibly lead to a misinterpretation in the future.

- 2 -

Environmental Impacts of the Proposed Action:

The proposed action corrects a number in Table 3.2.2 of the Technical Specification which is related to the degraded voltage on the 4KV emergency buses. Based on the staff's evaluation, the level of safety in the operation of the plant is equivalent to that anticipated when the license was granted. There is no significant change in probability or consequence of a serious accident. Radiological releases will not differ from those determined previously and the proposed amendments do not otherwise affect facility radiological effluents or occupational exposures. The proposed amendments do not affect plant nonradiological effluents and have no other environmental impact. Therefore, the Commission concludes there are no measurable radiological or nonradiological environmental impacts associated with the proposed amendments. Alternatives to the Proposed Action:

Since the Commission has concluded there is no measurable environmental impact associated with the proposed exemption, any alternatives with equal or greater environmental impact need not be evaluated. The principal alternative to the exemption would be to deny the amendment. Such action would not enhance the protection of the environment and would result in unjustifiable costs for the licensee.

Alternative Use of Resources:

This action does not involve the use of resources not considered previously in the Final Environmental Statement for Dresden, Units 2 and 3 dated November 1973.

Agencies and Persons Consulted:

The NRC staff reviewed the licensee's request and did not consult other agencies or persons.

FINDING OF NO SIGNIFICANT IMPACT


The Commission has determined not to prepare an environmental impact statement for the proposed amendment.

Based upon the Environmental Assessment, the NRC staff concludes that the proposed action will not have a significant effect on the quality of the human environment.

For further details with respect to this proposed action, see the NRC letter dated March 25, 1988 confirming a temporary waiver of compliance and the licensee's letter dated March 28, 1988. These letters are available for public inspection at the Commission's Public Document Room, 1717 H. Street, N.W., Washington, D.C. and at the Morris Public Library, 604 Liberty Street, Morris, Illinois 60451.

Dated at Rockville, Maryland this 6th day of July 1988.

FOR THE NUCLEAR REGULATORY COMMISSION



Daniel R. Muller, Director
Project Directorate III-2
Division of Reactor Projects - III,
IV, V, and Special Projects

- 3 -

FINDING OF NO SIGNIFICANT IMPACT

The Commission has determined not to prepare an environmental impact statement for the proposed amendment.

Based upon the Environmental Assessment, the NRC staff concludes that the proposed action will not have a significant effect on the quality of the human environment.

For further details with respect to this proposed action, see the NRC letter dated March 25, 1988 confirming a temporary waiver of compliance and the licensee's letter dated March 28, 1988. These letters are available for public inspection at the Commission's Public Document Room, 1717 H. Street, N.W., Washington, D.C. and at the Morris Public Library, 604 Liberty Street, Morris, Illinois 60451.

Dated at Rockville, Maryland this 6th day of July 1988.

FOR THE NUCLEAR REGULATORY COMMISSION

Daniel R. Muller, Director
Project Directorate III-2
Division of Reactor Projects - III,
IV, V, and Special Projects

PDIII-2
MGrotenhuis/ww
4/18/88

PDIII-2
LLuther
4/18/88

PDIII-2
DMuller
/ /88

OGC
/ /88