

April 25, 2002

Mr. Mark Warner  
Site Vice President  
Kewaunee and Point Beach Nuclear Plants  
Nuclear Management Company, LLC  
6610 Nuclear Road  
Two Rivers, WI 54241

SUBJECT: ELECTRIC POWER RESEARCH INSTITUTE (EPRI) REPORT TR-113594,  
"RESOLUTION OF GENERIC LETTER 96-06 WATERHAMMER ISSUES,"  
VOLUMES 1 AND 2 (TAC NO. M96824)

Dear Mr. Warner:

Generic Letter (GL) 96-06, "Assurance of Equipment Operability and Containment Integrity During Design-Basis Accident Conditions," dated September 30, 1996, requested that licensees evaluate (among other things) waterhammer and two-phase flow concerns associated with containment air cooler cooling water systems. Your remaining actions to fully address these concerns were deferred pending Nuclear Regulatory Commission (NRC) review and approval of EPRI Report TR-113594, "Resolution of Generic Letter 96-06 Waterhammer Issues," Volumes 1 and 2. The purpose of this letter is to inform you that we have completed our review, and we have determined that use of EPRI Report TR-113594 for evaluating the GL 96-06 waterhammer issues is acceptable to the extent specified and within the limitations delineated in the report and NRC safety evaluation. We request that you complete your actions to address GL 96-06 and submit the information referred to in Section 3.3 of the NRC safety evaluation by July 30, 2002.

Please contact us to make alternate arrangements if you are unable to meet this schedule. A copy of our April 3, 2002, acceptance letter to EPRI, which includes the NRC safety evaluation, is enclosed for your information.

Sincerely,

**/RA/**

John G. Lamb, Project Manager, Section 1  
Project Directorate III  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-305

Enclosure: Safety Evaluation

cc w/encl: See next page

April 25, 2002

Mr. Mark Warner  
Site Vice President  
Kewaunee and Point Beach Nuclear Plants  
Nuclear Management Company, LLC  
6610 Nuclear Road  
Two Rivers, WI 54241

SUBJECT: ELECTRIC POWER RESEARCH INSTITUTE (EPRI) REPORT TR-113594,  
"RESOLUTION OF GENERIC LETTER 96-06 WATERHAMMER ISSUES,"  
VOLUMES 1 AND 2 (TAC NO. M96824)

Dear Mr. Warner:

Generic Letter (GL) 96-06, "Assurance of Equipment Operability and Containment Integrity During Design-Basis Accident Conditions," dated September 30, 1996, requested that licensees evaluate (among other things) waterhammer and two-phase flow concerns associated with containment air cooler cooling water systems. Your remaining actions to fully address these concerns were deferred pending Nuclear Regulatory Commission (NRC) review and approval of EPRI Report TR-113594, "Resolution of Generic Letter 96-06 Waterhammer Issues," Volumes 1 and 2. The purpose of this letter is to inform you that we have completed our review, and we have determined that use of EPRI Report TR-113594 for evaluating the GL 96-06 waterhammer issues is acceptable to the extent specified and within the limitations delineated in the report and NRC safety evaluation. We request that you complete your actions to address GL 96-06 and submit the information referred to in Section 3.3 of the NRC safety evaluation by July 30, 2002.

Please contact us to make alternate arrangements if you are unable to meet this schedule. A copy of our April 3, 2002, acceptance letter to EPRI, which includes the NRC safety evaluation, is enclosed for your information.

Sincerely,

/RA/

John G. Lamb, Project Manager, Section 1  
Project Directorate III  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-305

Enclosure: Safety Evaluation

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	PDIII-1 Reading	JLamb	THarris
OGC	ACRS	JTatum	RLanksbury, RIII

ADAMS Accession no.: ML021150154

OFFICE	PDIII-1/PM	PDIII-1/LA	PDIII-1/SC
NAME	JLamb	THarris	LRaghavan
DATE	04/25/02	04/25/02	04/25/02

OFFICIAL RECORD COPY

Kewaunee Nuclear Power Plant

cc:

Foley & Lardner  
ATTN: Bradley D. Jackson  
One South Pinckney Street  
P.O. Box 1497  
Madison, WI 53701-1497

Chairman  
Town of Carlton  
Route 1  
Kewaunee, WI 54216

Mr. Gerald Novickis, Chairman  
Kewaunee County Board  
Kewaunee County Courthouse  
613 Dodge Street  
Kewaunee, WI 54216

Attorney General  
114 East, State Capitol  
Madison, WI 53702

U.S. Nuclear Regulatory Commission  
Resident Inspectors Office  
Route #1, Box 999  
Kewaunee, WI 54216

Regional Administrator - Region III  
U.S. Nuclear Regulatory Commission  
801 Warrenville Road  
Lisle, IL 60532-4531

James D. Looock, Chief Engineer  
Public Service Commission  
of Wisconsin  
610 N. Whitney Way  
Madison, WI 53707-7854

Mr. Roy A. Anderson  
Executive Vice President and  
Chief Nuclear Officer  
Nuclear Management Company, LLC  
700 First Street  
Hudson, WI 54016

Nuclear Asset Manager  
Wisconsin Public Service Corporation  
600 N. Adams Street  
Green Bay, WI 54307-9002

Plant Manager  
Kewaunee Nuclear Power Plant  
Nuclear Management Company, LLC  
North 490, Highway 42  
Kewaunee, WI 54216-9511