

June 12, 1984

Docket Nos. 50-237/249

DISTRIBUTION

Docket File
NRC PDR
Local PDR
NSIC
ORB #5 Reading
DCrutchfield
HSmith
RGilbert
OELD (Cuoco)
ELJordan
JMTaylor
ACRS (10)
SEPB
LSchneider
TBarnhart (4)
LJHarmon

Mr. Dennis L. Farrar
Director of Nuclear Licensing
Commonwealth Edison Company
Post Office Box 767
Chicago, Illinois 60690

Dear Mr. Farrar:

SUBJECT: ISSUANCE OF ORDER CONFIRMING LICENSEE COMMITMENTS ON EMERGENCY
RESPONSE CAPABILITY

Re: Dresden Nuclear Power Station, Unit Nos. 2 and 3

The Commission has issued the enclosed Order confirming your commitments on emergency response capability for the Dresden Nuclear Power Station, Unit Nos. 2 and 3. This Order is based on your letters dated April 14, July 20, July 28, August 25, November 15, and December 15, 1983, committing to the actions specified in the Order.

A copy of this Order is being filed with the Office of the Federal Register for publication.

Sincerely,

Original signed by James Lyons
for

Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Licensing

*SEE 16
USE 16*

**ADD: T. BARNHART (4)
L. HARMON (2)
OELD (Cuoco) (4)**

Enclosure:
Order

cc w/enclosure:
See next page

8406250321 840612
PDR ADDCK 05000237
F PDR

*SEE PREVIOUS PAGE FOR CONCURRENCE

OFFICE	DL: ORB #5*	DL: ORB #5*	DL: ORB #5*	OELD*	DL: AD/SA*	DL: DIB	
SURNAME	HSmith:cc	RGilbert	DCrutchfield	SBurns	FMiraglia	DEKsenAut	
DATE	9/20/83	9/20/83	9/20/83	9/27/83	9/28/83	6/12/83	

OFFICIAL RECORD COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

June 12, 1984

Docket Nos. 50-237/249
LS05-84-06-023

Mr. Dennis L. Farrar
Director of Nuclear Licensing
Commonwealth Edison Company
Post Office Box 767
Chicago, Illinois 60690

Dear Mr. Farrar:

SUBJECT: ISSUANCE OF ORDER CONFIRMING LICENSEE COMMITMENTS ON EMERGENCY
RESPONSE CAPABILITY

Re: Dresden Nuclear Power Station, Unit Nos. 2 and 3

The Commission has issued the enclosed Order confirming your commitments on emergency response capability for the Dresden Nuclear Power Station, Unit Nos. 2 and 3. This Order is based on your letters dated April 14, July 20, July 28, August 25, November 15, and December 15, 1983, committing to the actions specified in the Order.

A copy of this Order is being filed with the Office of the Federal Register for publication.

Sincerely,

for *J. E. Lyons*
Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Licensing

Enclosure:
Order

cc w/enclosure:
See next page

Mr. Dennis L. Farrar

cc
Isham, Lincoln & Beale
Counselors at Law
Three First National Plaza,
Suite 5200
Chicago, Illinois 60602

Mr. Doug Scott
Plant Superintendent
Dresden Nuclear Power Station
Rural Route #1
Morris, Illinois 60450

U. S. Nuclear Regulatory Commission
Resident Inspectors Office
Dresden Station
Rural Route #1
Morris, Illinois 60450

Chairman
Board of Supervisors of
Grundy County
Grundy County Courthouse
Morris, Illinois 60450

U. S. Environmental Protection Agency
Federal Activities Branch
Region V Office
ATTN: Regional Radiation Representative
230 South Dearborn Street
Chicago, Illinois 60604

James G. Keppler, Regional Administrator
Nuclear Regulatory Commission, Region III
799 Roosevelt Street
Glen Ellyn, Illinois 60137

Mr. Gary N. Wright, Manager
Nuclear Facility Safety
Illinois Department of Nuclear Safety
1035 Outer Park Drive, 5th Floor
Springfield, Illinois 62704

DISTRIBUTION

Docket
NRC PDR
Local PDR
ORB Reading
NSIC
DCrutchfield
HSmith
RGilbert
OELD (cuoco)
ELJordan
JMTaylor
ACRS
SEPB
LSchneider
TBarnhart
LJHarmon

Docket Nos. 50-237/249

Mr. Dennis L. Farrar
Director of Nuclear Licensing
Commonwealth Edison Company
Post Office Box 767
Chicago, Illinois 60690

Dear Mr. Farrar:

SUBJECT: ORDER CONFIRMING COMMITMENTS TO IMPLEMENT POST-TMI
RELATED ITEMS IN SUPPLEMENT 1 OF NUREG-0737

Dresden Nuclear Power Station, Units 2 and 3

The Commission has issued the enclosed Order confirming your commitments to implement those post-TMI related items set forth in Supplement 1 of NUREG-0737. This Order is based on commitments contained in your letters dated April 14, July 20 and 28 and August 25, 1983, which are responses to our Generic Letter 82-33.

Your commitments include (1) dates for providing required submittals to the NRC, (2) dates for implementing certain requirements, and (3) a schedule for providing implementation dates for other requirements.

A copy of this Order is being filed with the Office of the Federal Register for publication.

Sincerely,

Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

OFFICE	DL:ORB #5	DL:ORB #5	DL:ORB #5	OELD	DL:SA	DL:DIR	
SURNAME	H. Smith: jc.	RGilbert	DCrutchfield	S BURNS	FMiraglia	DEisenhut	
DATE	9/20/83	9/20/83	9/20/83	9/27/83	9/28/83	1/83	

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)	
)	
COMMONWEALTH EDISON COMPANY)	Docket No. 50-237/249
)	
(Dresden Nuclear Power Station, Units 2 and 3))	

ORDER CONFIRMING LICENSEE COMMITMENTS
ON EMERGENCY RESPONSE CAPABILITY

I.

Commonwealth Edison Company, (CECo) (the licensee) is the holder of Provisional Operating License No. DPR-19 and Facility Operating License No. DPR-25 which authorize operation of the Dresden Nuclear Power Station, Units 2 and 3, respectively, (the facilities) at steady-state power levels not in excess of 2527 megawatts thermal. The facilities are boiling water reactors (BWRs) located in Grundy County, Illinois.

II.

Following the accident at Three Mile Island Unit No. 2 (TMI-2) on March 28, 1979, the Nuclear Regulatory Commission (NRC) staff developed a number of proposed requirements to be implemented on operating reactors and on plants under construction. These requirements include Operational Safety, Siting and Design, and Emergency Preparedness and are intended to provide substantial additional protection in the operation of nuclear facilities and significant upgrading of emergency response capability based on the experience from the accident at TMI-2 and the official studies and investigations of the accident. The requirements are set forth in NUREG-0737, "Clarification of

- 2 -

TMI Action Plan Requirements," and in Supplement 1 to NUREG-0737, "Requirements for Emergency Response Capability." Among these requirements are a number of items consisting of emergency response facility operability, emergency procedure implementation, addition of instrumentation, possible control room design modifications, and specific information to be submitted.

On December 17, 1982, a letter (Generic Letter 82-33) was sent to all licensees of operating reactors, applicants for operating licenses, and holders of construction permits enclosing Supplement 1 to NUREG-0737. In this letter operating reactor licensees and holders of construction permits were requested to furnish the following information, pursuant to 10 CFR 50.54(f), no later than April 15, 1983:

- (1) A proposed schedule for completing each of the basic requirements for the items identified in Supplement 1 to NUREG-0737, and
- (2) A description of plans for phased implementation and integration of emergency response activities including training.

III.

CECo responded to Generic Letter 82-33 by letter dated April 14, 1983. By letters dated July 20 and 28, August 25, November 15, and December 15, 1983, CECo modified several dates as a result of negotiations with the NRC staff. In these submittals, CECo made commitments to complete the basic requirements. The attached Table summarizing CECo's schedular commitments or status was developed by the NRC staff from the Generic Letter and the information provided by CECo.

- 3 -

CECo's commitments include (1) dates for providing required submittals to the NRC, (2) dates for implementing certain requirements, and (3) a schedule for providing implementation dates for other requirements. These latter implementation dates will be reviewed, negotiated and confirmed by a subsequent order.

The NRC staff reviewed CECo's April 14, 1983 letter and entered into negotiations with the licensee regarding schedules for meeting the requirements of Supplement 1 to NUREG-0737. As a result of these negotiations, the licensee modified certain dates by letters dated July 20 and 28, August 25, November 15, and December 15, 1983. The NRC staff finds that the modified dates are reasonable, achievable dates for meeting the Commission requirements. The NRC staff concludes that the schedule proposed by the licensee will provide timely upgrading of the licensee's emergency response capability.

In view of the foregoing, I have determined that the implementation of CECo's commitments are required in the interest of the public health and safety and should, therefore, be confirmed by an immediately effective Order.

IV.

Accordingly, pursuant to Sections 103, 161i, 161o and 182 of the Atomic Energy Act of 1954, as amended, and the Commission's regulations in 10 CFR Parts 2 and 50, IT IS HEREBY ORDERED, EFFECTIVE IMMEDIATELY, THAT the licensee shall:

Implement the specific items described in the Attachment to this ORDER in the manner described in CECo's submittals noted in Section III herein no later than the dates in the Attachment.

- 4 -

Extensions of time for completing these items may be granted by the Director, Division of Licensing, for good cause shown.

V.


The licensee may request a hearing on this Order within 20 days of the date of publication of this Order in the Federal Register. Any request for a hearing should be addressed to the Director, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555. A copy should also be sent to the Executive Legal Director at the same address. A REQUEST FOR HEARING SHALL NOT STAY THE IMMEDIATE EFFECTIVENESS OF THIS ORDER.

If a hearing is to be held, the Commission will issue an Order designating the time and place of any such hearing.

If a hearing is held concerning this Order, the issue to be considered at the hearing shall be whether the licensee should comply with the requirements set forth in Section IV of this Order.

This Order is effective upon issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Darrett G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

Dated at Bethesda, Maryland,
this 12 day of June, 1984.

Attachment:
Licensee's Commitments on
Requirements Specified in
Supplement 1 to NUREG-0737

Dresden Station Units 2 and 3
LICENSEE'S COMMITMENTS ON SUPPLEMENT 1 TO NUREG-0737

TITLE	REQUIREMENT	LICENSEE'S COMPLETION SCHEDULE (OR STATUS)
1. Safety Parameter Display System (SPDS)	1a. Submit a safety analysis and an implementation plan to the NRC.	Complete *
	1b. SPDS fully operational and operators trained.	01-01-85 *
2. Detailed Control Room Design Review (DCRDR)	2a. Submit a program plan to the NRC.	Submitted April 14, 1983
	2b. Submit a summary report to the NRC including a proposed schedule for implementation.	05-01-85
3. Regulatory Guide 1.97 - Application to Emergency Response Facilities	3a. Submit a report to the NRC describing how the requirements of Supplement 1 to NUREG-0737 have been or will be met.	08-01-85
	3b. Implement (installation or upgrade) requirements.	Provide an implementation schedule by 02-01-86

*"Consistent with Items I.a.1 and I.b of Attachment A of the November 15, 1983 letter from Cordell Reed to Harold Denton"

LICENSEE'S COMMITMENTS ON SUPPLEMENT 1 TO NUREG-0737

TITLE	REQUIREMENT	LICENSEE'S COMPLETION SCHEDULE (OR STATUS)
4. Upgrade Emergency Operating Procedures (EOPs)	4a. Submit a Procedures Generation Package to the NRC..	10-30-84
	4b. Implement the upgraded EOPs.	10-30-85
5. Emergency Response Facilities	5a. Technical Support Center fully functional.	Complete*
	5b. Operational Support Center fully functional.	Complete
	5c. Emergency Operations Facility fully functional.	01-01-85*

* The modifications and construction of the structures are finished but the TSC and EOF are not considered to be fully functional until the changes resulting from the R.G. 1.97 and human factors reviews are implemented and all testing and training are completed.