

July 31, 1984

DGR
016

Docket No. 50-346

DISTRIBUTION
Docket File
NRC PDR
L PDR
ORB#4 Rdg
DEisenhut
OELD
CMiles
LHarmon
ACRS-10
TBarnhart-4
EJordan

JNGrace
WJones
DBrinkman
RDiggs
RIngram
ADe Agazio
Gray File+4

Mr. Richard P. Crouse
Vice President, Nuclear
Toledo Edison Company
Edison Plaza - Stop 712
300 Madison Avenue
Toledo, Ohio 43652

Dear Mr. Crouse:

SUBJECT: AMENDMENT NO. 74 TO FACILITY OPERATING LICENSE NO. NPF-3

The Commission has issued Amendment No. 74 to Facility Operating License No. NPF-3 for the Davis-Besse Nuclear Power Station, Unit No. 1. The amendment consists of changes to the Appendix A Technical Specifications in response to your application dated May 19, 1983 (No. 947).

The amendment changes the Technical Specifications to require an audit of the Emergency Plan and Implementing Procedures and the Security Plan and Implementing Procedures at a frequency of at least once per twelve (12) months.

The bases for these changes are contained in NRC Generic Letter 82-17 dated October 1, 1982 (emergency preparedness programs) and NRC Generic Letter 82-23 dated October 30, 1982 (safeguards contingency plans). These changes are made specifically to make Facility Operating License NPF-3 consistent with the requirements of 10 CFR 50.54(t) and 10 CFR 73.40(d).

This amendment relates to changes in recordkeeping, reporting, or administrative procedures or requirements. Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(10). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of this amendment.

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will

not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Notice of Issuance will be included in the Commission's Monthly Notice.

Sincerely,

John F. Stolz, Chief
Operating Reactors Branch No. 4
Division of Licensing

Enclosure:
Amendment No. 74 to NPF-3

cc w/enclosures:
See next page

**See previous white for concurrence. This reflects change in branch chief signature only.

ORB#4:DL**	ORB#4:DL**	ORB#4:DL**	OELD**	AD:DL
RIngram	ADeAgazio;ef	GIVENBARK		GLainas
07/20/84	07/20/84	07/23/84	07/25/84	07/20/84

not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Notice of Issuance will be included in the Commission's Monthly Notice.

Sincerely,

George W. Rivenbark, Acting Chief
Operating Reactors Branch No. 4
Division of Licensing

Enclosure:
Amendment No. to NPF-3

cc w/enclosures:
See next page

ORB#4:DL
RIngram
07/20/84

ORB#4:DL
ADeAgazio;ef
07/20/84

ORB#4:DL
GRivenbark
07/27/84

ORB#4:DL
AD:OR:DL
GLainas
07/25/84 07/ /84

Toledo Edison Company

cc w/enclosure(s):

Mr. Donald H. Hauser, Esq.
The Cleveland Electric
Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
5503 N. State Route 2
Oak Harbor, Ohio 43449

Gerald Charnoff, Esq.
Shaw, Pittman, Potts
and Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

Paul M. Smart, Esq.
Fuller & Henry
300 Madison Avenue
P. O. Box 2088
Toledo, Ohio 43603

Regional Radiation Representative
EPA Region V
230 South Dearborn Street
Chicago, Illinois 60604

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
7910 Woodmont Avenue, Suite 220
Bethesda, Maryland 20814

Ohio Department of Health
ATTN: Radiological Health
Program Director
P. O. Box 118
Columbus, Ohio 43216

President, Board of County
Commissioners of Ottawa County
Port Clinton, Ohio 43452

Attorney General
Department of Attorney General
30 East Broad Street
Columbus, Ohio 43215

James W. Harris, Director (Addressee Only)
Division of Power Generation
Ohio Department of Industrial Relations
2323 West 5th Avenue
P. O. Box 825
Columbus, Ohio 43216

Harold Kohn, Staff Scientist
Power Siting Commission
361 East Broad Street
Columbus, Ohio 43216

Mr. James G. Keppler, Regional Administrator
U. S. Nuclear Regulatory Commission, Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Mr. Robert F. Peters
Manager, Nuclear Licensing
Toledo Edison Company
Edison Plaza
300 Madison Avenue
Toledo, Ohio 43652



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TOLEDO EDISON COMPANY

AND

THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

DOCKET NO. 50-346

DAVIS-BESSE NUCLEAR POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 74
License No. NPF-3

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Toledo Edison Company and The Cleveland Electric Illuminating Company (the licensees) dated May 19, 1983, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-3 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 74, are hereby incorporated in the license. The Toledo Edison Company shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John F. Stolz, Chief
Operating Reactors Branch No. 4
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: July 31, 1984

ATTACHMENT TO LICENSE AMENDMENT NO. 74

FACILITY OPERATING LICENSE NO. NPF-3

DOCKET NO. 50-346

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains vertical lines indicating the area of change. The corresponding overleaf page is also provided to maintain document completeness.

Page

6-11

ADMINISTRATIVE CONTROLS

AUDITS

6.5.2.8 Audits of facility activities shall be performed under the cognizance of the CNRB. These audits shall encompass:

- a. The conformance of unit operation to provisions contained within the Technical Specifications and applicable license conditions at least once per 12 months.
- b. The performance, training and qualifications of the entire station staff at least once per 12 months.
- c. The results of actions taken to correct deficiencies occurring in unit equipment, structures, systems or method of operation that affect nuclear safety at least once per 6 months.
- d. The performance of activities required by the Quality Assurance Program to meet the criteria of Appendix "B", 10 CFR 50, at least once per 24 months.
- e. The Station Emergency Plan and implementing procedures at least once per 12 months.
- f. The Station Security Plan and implementing procedures at least once per 12 months.
- g. Any other area of facility operation considered appropriate by the CNRB.
- h. The Facility Fire Protection Program and implementing procedures at least once per 24 months.
- i. An independent fire protection and loss prevention program inspection and audit shall be performed at least once per 12 months utilizing either qualified offsite licensee personnel or an outside fire protection firm.
- j. An inspection and audit of the fire protection and loss prevention program shall be performed by a qualified outside fire consultant at least once per 36 months.

AUTHORITY

6.5.2.9 The Company Nuclear Review Board shall report to and advise the President and Chief Operating Officer on those areas of responsibility specified in Sections 6.5.2.7 and 6.5.2.8.

ADMINISTRATIVE CONTROLS

RECORDS

6.5.2.10 Records of Company Nuclear Review Board activities shall be prepared, approved and distributed as indicated below:

- a. Minutes of each CNRB meeting shall be prepared, approved and forwarded to the President and Chief Operating Officer and CNRB members within 14 days following each meeting.
- b. Reports of reviews encompassed by Section 6.5.2.7 above, shall be prepared, approved and forwarded to the President and Chief Operating Officer and CNRB members within 14 days following completion of the review.
- c. Audit reports encompassed by Section 6.5.2.8 above, shall be forwarded to the President and Chief Operating Officer and CNRB members and to the management positions responsible for the areas audited within 30 days after completion of the audit.

6.6 REPORTABLE OCCURRENCE ACTION

6.6.1 The following actions shall be taken for REPORTABLE OCCURRENCES:

- a. The Commission shall be notified and/or a report submitted pursuant to the requirements of Specification 6.9.
- b. Each REPORTABLE OCCURRENCE requiring 24 hour notification to the Commission shall be reviewed by the SRB and submitted to the CNRB.

ADMINISTRATIVE CONTROLS

RECORDS

6.5.2.10 Records of Company Nuclear Review Board activities shall be prepared, approved and distributed as indicated below:

- a. Minutes of each CNRB meeting shall be prepared, approved and forwarded to the President and Chief Operating Officer and CNRB members within 14 days following each meeting.
- b. Reports of reviews encompassed by Section 6.5.2.7 above, shall be prepared, approved and forwarded to the President and Chief Operating Officer and CNRB members within 14 days following completion of the review.
- c. Audit reports encompassed by Section 6.5.2.8 above, shall be forwarded to the President and Chief Operating Officer and CNRB members and to the management positions responsible for the areas audited within 30 days after completion of the audit.

6.6 REPORTABLE OCCURRENCE ACTION

6.6.1 The following actions shall be taken for REPORTABLE OCCURRENCES:

- a. The Commission shall be notified and/or a report submitted pursuant to the requirements of Specification 6.9.
- b. Each REPORTABLE OCCURRENCE requiring 24 hour notification to the Commission shall be reviewed by the SRB and submitted to the CNRB.