P.O. Box 63
Lycoming, New York 13093

Constellation
Nuclear

Nine Mile Point
Nuclear Station

A Member of the
Constellation Energy Group

April 9, 2002
NMP1L 1658

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

RE: Nine Mile Point Unit 1
Docket No. 50-220
DPR-63

Subject: ***Monthly Operating Report for March 2002***

Gentlemen:

Submitted herewith are the Operating Data Report, Unit Shutdowns, and a Narrative of Operating Experience for March 2002 for the Nine Mile Point Nuclear Station Unit 1. Submittal of this information complies with Section 6.9.1.c of the Unit 1 Technical Specifications.

Very truly yours,

LA Hopkins

Lawrence A. Hopkins
Unit 1 Plant General Manager

LAH/jm
Attachments

cc: Mr. H. J. Miller, NRC Regional Administrator, Region I
Mr. G. K. Hunegs, NRC Senior Resident Inspector
Records Management

IE24

ATTACHMENT A

OPERATING DATA REPORT

DOCKET NO: 50-220
DATE: 4/2/02
PREPARED BY: P. E. Netusil
TELEPHONE: (315) 349-7935

OPERATING STATUS

Unit Name: Nine Mile Point Unit #1
Reporting Period: March 2002

1	Design Electrical Rating: (Net MWe)	613
2	Maximum Dependable Capacity: (Net MWe)	565

		This Month	Yr-to-Date	Cumulative
3	Critical Hours	744.0	2,160.0	199,182.1
4	Hours Generator On-Line	744.0	2,160.0	194,828.2
5	Unit Reserve Shutdown Hours	0.0	0.0	20.4
6	Net Electrical Energy Generated (MWH)	458,610.0	1,330,312.0	108,361,131.0

ATTACHMENT B

UNIT SHUTDOWNS
REPORTING PERIOD – MARCH 2002

DOCKET NO: 50-220
UNIT NAME: NMP1
DATE: 4/2/02
PREPARED BY: P. E. Netusil
TELEPHONE: (315) 349-7935

NO.*	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASONS[1]	METHOD OF SHUTTING DOWN[2]	CAUSE & CORRECTIVE ACTIONS COMMENTS
						No shutdown occurred in March 2002

(1) Reason
- A. Equipment Failure (Explain)
- B. Maintenance or Test
- C. Refueling
- D. Regulatory Restriction
- E. Operator Training/License Examination
- F. Administrative
- G. Operational Error (Explain)
- H. Other (Explain)

(2) Method
1. Manual
2. Manual Trip/Scram
3. Automatic Trip/Scram
4. Continuation
5. Other (Explain)

*NOTE: Sequential numbering used.

ATTACHMENT C

NARRATIVE OF OPERATING EXPERIENCE

DOCKET NO: 50-220
UNIT NAME: NMP1
DATE: 4/2/02
PREPARED BY: P. E. Netusil
TELEPHONE: (315) 349-7935

The unit operated during the month of March 2002 with a Net Electrical Design capacity factor of 100.6 percent. There were no challenges to the electromatic relief valves or safety valves during the operating period.