

December 27, 1988

Docket No. 50-346

Mr. Donald Shelton
Vice President, Nuclear
Toledo Edison Company
Edison Plaza - Stop 712
300 Madison Avenue
Toledo, Ohio 43652

Distribution
Docket File
NRC & Local PDRs
PDIII-3 r/f
GHolahan
MVirgilio
PKreutzer
Ade Agazio
OGC
DHagan

EJordon
BGrimes
TMeek(4)
WandaJones
EButcher
ACRS(10)
GPA/PA
ARM/LFMB
PDIII Gray File

Dear Mr. Shelton:

SUBJECT: CORRECTION TO AMENDMENT NO. 124

On October 5, 1988, the Commission issued Amendment No. 124 to Facility Operating License No. NPF-3 for the Davis-Besse Nuclear Power Station, Unit No. 1. The amendment consisted of changes to the Appendix A Technical Specifications in response to your application dated January 30, 1988.

The amendment revised Technical Specification Table 3.3-11 relating to the number of manual initiation pushbuttons required.

Page 3/4 3-26 was revised by the amendment. Overleaf page 3/4 3-25 was provided by you for convenience. However, although page 3/4 3-25 was unchanged by the amendment, it contained two typographical errors. The page has now been corrected and the corrected pages are provided herewith.

Sincerely,

/s/

Albert W. De Agazio, Sr. Project Manager
Project Directorate III-3
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc: w/ enclosure
See next page

Office: LA/PDIII-3
Surname: PKreutzer
Date: 12/27/88

PM/PDIII-3
Ade Agazio/mr
12/27/88

PD/PDIII-3
JHannon
12/27/88

JFO
11

CP
[Signature]

8901040181 881227
PDR ADOCK 05000346
P PNU

TABLE 3.3-11 (Continued)

STEAM AND FEEDWATER RUPTURE CONTROL SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>ACTION</u>
2. Feedwater/Steam Generator Differential Pressure - High Instrument Channels	2	1	2	13#
a. PDS 2685A Feedwater/Steam Generator 2 Channel 2 PDS 2685B Feedwater/Steam Generator 2 Channel 2				
b. PDS 2685C Feedwater/Steam Generator 2 Channel 1 PDS 2685D Feedwater/Steam Generator 2 Channel 1				
c. PDS 2686A Feedwater/Steam Generator 1 Channel 1 PDS 2686B Feedwater/Steam Generator 1 Channel 1				
d. PDS 2686C Feedwater/Steam Generator 1 Channel 2 PDS 2686D Feedwater/Steam Generator 1 Channel 2				
3. Steam Generator Level - Low Instrument Channels	2	1	2	13#
a. LSLP SP9B8 Steam Generator 1 Channel 1 LSLP SP9B9 Steam Generator 1 Channel 1				
b. LSLP SP9A6 Steam Generator 2 Channel 1 LSLP SP9A7 Steam Generator 2 Channel 1				
c. LSLP SP9A8 Steam Generator 2 Channel 2 LSLP SP9A9 Steam Generator 2 Channel 2				

DAVIS-BESSE, UNIT 1

3/4 3-25

Amendment No. 4
JUL 8 1977

8901040187 881227
PDR ADDCK 05000346
P PNU

TABLE 3.3-11 (Continued)

STEAM AND FEEDWATER RUPTURE CONTROL SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>ACTION</u>
3. Steam Generator Level - Low Instrument Channels (continued)				
d. LSL SP9B6 Steam Generator 1 Channel 2 LSLL SP9B7 Steam Generator 1 Channel 2				
4. Loss of RCP Channels	2	1	2	13#
5. Manual Initiation (Push buttons)				
a. Initiate AFPT #1	1	1	1	14
b. Initiate AFPT #2	1	1	1	14
c. Initiate AFPT #1 and Isolate SG #1	1	1	1	14
d. Initiate AFPT #2 and Isolate SG #2	1	1	1	14

Mr. Donald C. Shelton
Toledo Edison Company

Davis-Besse Nuclear Power Station
Unit No. 1

cc:

David E. Burke, Esq.
The Cleveland Electric
Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Radiological Health Program
Ohio Department of Health
1224 Kinnear Road
Columbus, Ohio 43212

Mr. Robert W. Schrauder
Manager, Nuclear Licensing
Toledo Edison Company
Edison Plaza
300 Madison Avenue
Toledo, Ohio 43652

Attorney General
Department of Attorney
General
30 East Broad Street
Columbus, Ohio 43215

Gerald Charnoff, Esq.
Shaw, Pittman, Potts
and Trowbridge
2300 N Street N.W.
Washington, D.C. 20037

Mr. James W. Harris, Director
(Addressee Only)
Division of Power Generation
Ohio Department of Industrial Relations
2323 West 5th Avenue
P. O. Box 825
Columbus, Ohio 43216

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois

Ohio Environmental Protection Agency
361 East Broad Street
Columbus, Ohio 43266-0558

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 525, 1700 Rockville Pike
Rockville, Maryland 20852

President, Board of
County Commissioners of
Ottawa County
Port Clinton, Ohio 43452

Resident Inspector
U.S. Nuclear Regulatory Commission
5503 N. State Route 2
Oak Harbor, Ohio 43449

State of Ohio
Public Utilities Commission
180 East Broad Street
Columbus, Ohio 43266-0573