

September 26, 1991

Docket No. 50-346

Mr. Donald C. Shelton
Vice President Nuclear - Davis-Besse
Centerior Service Company
c/o Toledo Edison Company
300 Madison Avenue
Toledo, Ohio 43652

DISTRIBUTION

Docket File	JHannon
NRC & Local PDRs	GHill(4)
PD33 Reading	Wanda Jones
BBoger	CGrimes
JZwolinski	ACRS(10)
PKreutzer	GPA/PA
JHopkins	OC/LFMB
OGC-OWF	PD33 Gray
DHagan	Region III, DRP

Dear Mr. Shelton:

SUBJECT: CORRECTION TO AMENDMENT NO. 161 TO FACILITY OPERATING LICENSE
NO. NPF-3 (TAC NO. 79962)

On August 26, 1991, the Commission issued Amendment No. 161 to Facility Operating License No. NPF-3 for the Davis-Besse Nuclear Power Station, Unit No. 1. The amendment revised the snubber surveillance schedule in response to your application dated March 1, 1991.

Technical Specification page 3/4 7-21 issued with the amendment should have had the amendment number inserted at the end of the last paragraph. Unfortunately, we overlooked the blank and failed to insert the number as required. The corrected page is enclosed.

Please accept our apologies for any inconvenience this error may have caused you.

Sincerely,

Original Signed By:

Jon B. Hopkins, Sr. Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosure:
TS page 3/4 7-21

cc w/enclosure:
See next page

NRC FILE CENTER COPY

LA:PD33:DRPW
PKreutzer
9/25/91

JBH
PM:PD33:DRPW
JHopkins/bj
9/25/91

H
PD:PD33:DRPW
JHannon
9/26/91

DOCUMENT NAME: 79962 AMD

9110040153 910926
PDR ADDCK 05000346
P PDR

DFD 11

September 26, 1991

Docket No. 50-346

DISTRIBUTION

Docket File	JHannon
NRC & Local PDRs	GHill(4)
PD33 Reading	Wanda Jones
BBoger	CGrimes
JZwolinski	ACRS(10)
PKreutzer	GPA/PA
JHopkins	OC/LFMB
OGC-OWF	PD33 Gray
DHagan	Region III, DRP

Mr. Donald C. Shelton
 Vice President Nuclear - Davis-Besse
 Centerior Service Company
 c/o Toledo Edison Company
 300 Madison Avenue
 Toledo, Ohio 43652

Dear Mr. Shelton:

SUBJECT: CORRECTION TO AMENDMENT NO. 161 TO FACILITY OPERATING LICENSE NO. NPF-3 (TAC NO. 79962)

On August 26, 1991, the Commission issued Amendment No. 161 to Facility Operating License No. NPF-3 for the Davis-Besse Nuclear Power Station, Unit No. 1. The amendment revised the snubber surveillance schedule in response to your application dated March 1, 1991.

Technical Specification page 3/4 7-21 issued with the amendment should have had the amendment number inserted at the end of the last paragraph. Unfortunately, we overlooked the blank and failed to insert the number as required. The corrected page is enclosed.

Please accept our apologies for any inconvenience this error may have caused you.

Sincerely,

Original Signed By:

Jon B. Hopkins, Sr. Project Manager
 Project Directorate III-3
 Division of Reactor Projects III/IV/V
 Office of Nuclear Reactor Regulation

Enclosure:
TS page 3/4 7-21

cc w/enclosure:
See next page

LA:PD33:DRPW
 PKreutzer
 9/25/91

JBH
 PM:PD33:DRPW
 JHopkins/bj
 9/25/91

H
 PD:PD33:DRPW
 JHannon
 9/26/91

DOCUMENT NAME: 79962 AMD

Mr. Donald C. Shelton
Toledo Edison Company

Davis-Besse Nuclear Power Station
Unit No. 1

cc:

David E. Burke, Esq.
The Cleveland Electric
Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Radiological Health Program
Ohio Department of Health
1224 Kinnear Road
Columbus, Ohio 43212

Mr. Robert W. Schrauder
Manager, Nuclear Licensing
Toledo Edison Company
300 Madison Avenue
Toledo, Ohio 43652

Attorney General
Department of Attorney
General
30 East Broad Street
Columbus, Ohio 43215

Gerald Charnoff, Esq.
Shaw, Pittman, Potts
and Trowbridge
2300 N Street N.W.
Washington, D.C. 20037

Mr. James W. Harris, Director
Division of Power Generation
Ohio Department of Industrial Relations
P. O. Box 825
Columbus, Ohio 43216

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Ohio Environmental Protection Agency
DERR--Compliance Unit
ATTN: Zack A. Clayton
P. O. Box 1049
Columbus, Ohio 43266-0149

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
1700 Rockville Pike, Suite 525
Rockville, MD 20852

Resident, Board of Ottawa
County Commissioners
Port Clinton, Ohio 43452

Resident Inspector
U. S. Nuclear Regulatory Commission
5503 N. State Route 2
Oak Harbor, Ohio 43449

State of Ohio
Public Utilities Commission
180 East Broad Street
Columbus, Ohio 43266-0573

Mr. Murray R. Edelman
Executive Vice President -
Power Generation
Centerior Service Company
6200 Oak Tree Boulevard
Independence, Ohio 44101

Mr. James R. Williams
State Liaison to the NRC
Adjutant General's Department
Office of Emergency Management
Agency
2825 West Ganville Road
Columbus, Ohio 43235-2712

PLANT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

a. General Requirements

At least once per inspection interval, each group of snubbers in use in the Plant shall be visually inspected in accordance with Specification 4.7.7.1.b and 4.7.7.1.c. Visual inspections may be performed with binoculars, or other visual support devices, for those snubbers that are difficult to access and where required to keep exposure as low as reasonably achievable. Response to failures shall be in accordance with Specification 4.7.7.1.d.

b. Inspection Interval

The inspection interval may be applied on the basis of snubber groups. The snubber groups may be established based on physical characteristics and accessibility. Inaccessible snubbers are defined as those located: (a) inside containment, (b) in high radiation exposure zones, or (c) in areas where accessibility is limited by physical constraints such as the need for scaffolding.

Each of the groups may be inspected independently according to the schedule determined by Table 4.7-5. The visual inspection interval for each snubber group shall be determined based upon the criteria provided in Table 4.7-5, and the first inspection interval determined using the criteria shall be based upon the previous inspection interval as established by the requirements in effect before amendment 161.

**TABLE 4.7-5
SNUBBER VISUAL INSPECTION INTERVAL**

Population or Group (Notes 1 and 2)	NUMBER OF UNACCEPTABLE SNUBBERS		
	Column A Extended Interval (Notes 3 and 6)	Column B Repeat Interval (Notes 4 and 6)	Column C Reduced Interval (Notes 5 and 6)
1	0	0	1
80	0	0	2
100	0	1	4
150	0	3	8
200	2	5	13
300	5	12	25
400	8	18	36
500	12	24	48
750	20	40	78
1000 or greater	29	56	109

Note 1: The next visual inspection interval for a snubber population or group size shall be determined based upon the previous inspection interval and the number of unacceptable snubbers found during that interval. Snubbers may be grouped, based upon their accessibility during power operation, as accessible or inaccessible. These categories may be examined separately or jointly. However, the licensee must make and document that decision before any inspection and shall use that decision as the basis upon which to determine the next inspection interval for that group.

Note 2: Interpolation between population or group sizes and the number of unacceptable snubbers is permissible. Use next lower integer for the value of the limit for Columns A, B, or C if that integer includes a fractional value of unacceptable snubbers as determined by interpolation.

Note 3: If the number of unacceptable snubbers is equal to or less than the number in Column A, the next inspection interval may be twice the previous interval but not greater than 48 months.

Note 4: If the number of unacceptable snubbers is equal to or less than the number in Column B but greater than the number in Column A, the next inspection interval shall be the same as the previous interval.