January 17, 1989

Docket No. 50-346 Serial No. DB-89-002

> Mr. Donald C. Shelton Vice President - Nuclear Toledo Edison Company Edison Plaza - Stop 712 300 Madison Avenue Toledo, Ohio 43652

Distribution Docket File NRC & Local PDRs PDIII-3 r/f MVirgilio PKreutzer TWambach OGC DHagan PDIII-3 Gray File

EJordon BGrimes TMeek (4) WandaJones EButcher ACRS(10) GPA/PA ARM/LFMB

Dear Mr. Shelton:

SUBJECT: CORRECTION TO AMENDMENT NO. 128 TO FACILITY OPERATING LICENSE NO. NPF-3 (TAC NO. 66727)

On December 28, 1988, the Commission issued Amendment No. 128 to Facility Operating License No. NPF-3 for the Davis-Besse Nuclear Power Station, Unit No. 1. The amendment consisted of changes to the Technical Specifications (TS) in response to your application dated February 1, 1988 (Serial No. 1464) as supplemented with information contained in a letter dated February 26, 1988 (Serial No. 1496).

It has been brought to our attention that two TS pages issued with the amendment did not incorporate previous changes issued by Amendment No. 123. Enclosed find corrected TS pages 2-2 and 2-5 with the corresponding overleaf pages.

Sincerely,

/s/

Thomas V. Wambach, Sr. Project Manager Project Directorate III-3 Division of Reactor Projects - III, IV, V and Special Projects Office of Nuclear Reactor Regulation

Enclosure: As stated

PDR

cc w/enclosure: See next page

Office: LA/PDIII-3 Surname: PKreutzer Date: ///3/8

8901200331 890117

05000346

PM/PDIII-3 TWambach/mr

1/12/86

PD/PDIII-3 JHannon \///88

Fol Oth

Mr. Donald C. Shelton Toledo Edison Company

cc: David E. Burke, Esq. The Cleveland Electric Illuminating Company P. O. Box 5000 Cleveland, Ohio 44101

Mr. Robert W. Schrauder Manager, Nuclear Licensing Toledo Edison Company Edison Plaza 300 Madison Avenue Toledo, Ohio 43652

Gerald Charnoff, Esq. Shaw, Pittman, Potts and Trowbridge 2300 N Street N.W. Washington, D.C. 20037

Regional Administrator, Region III U.S. Nuclear Regulatory Commission 799 Roosevelt Road Glen Ellyn, Illinois

Mr. Robert B. Borsum Babcock & Wilcox Nuclear Power Generation Division Suite 525, 1700 Rockville Pike Rockville, Maryland 20852

Resident Inspector U.S. Nuclear Regulatory Commission 5503 N. State Route 2 Oak Harbor, Ohio 43449 Davis-Besse Nuclear Power Station Unit No. 1

Radiological Health Program Ohio Department of Health 1224 Kinnear Road Columbus, Ohio 43212

Attorney General Department of Attorney General 30 East Broad Street Columbus, Ohio 43215

Mr. James W. Harris, Director (Addressee Only) Division of Power Generation Ohio Department of Industrial Relations 2323 West 5th Avenue P. O. Box 825 Columbus, Ohio 43216

Ohio Environmental Protection Agency 361 East Broad Street Columbus, Ohio 43266-0558

President, Board of County Commissioners of Ottawa County Port Clinton, Ohio 43452

State of Ohio Public Utilities Commission 180 East Broad Street Columbus, Ohio 43266-0573







DAVIS-BESSE, UNIT 1

Amendment No. 11, 33, 45, 61, 123, 128

# 2.0 SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

## 2.1 SAFETY LIMITS

#### REACTOR CORE

2.1.1 The combination of the reactor coolant core outlet pressure and outlet temperature shall not exceed the safety limit shown in Figure 2.1-1.

APPLICABILITY: MODES 1 and 2.

### ACTION:

Whenever the point defined by the combination of reactor coolant core outlet pressure and outlet temperature has exceeded the safety limit, be in HOT STANDBY within one hour.

#### REACTOR CORE

2.1.2 The combination of reactor THERMAL POWER and AXIAL POWER IMBALANCE shall not exceed the safety limit shown in Figure 2.1-2 for the various combinations of two, three and four reactor coolant pump operation.

APPLICABILITY: MODE 1.

ACTION:

Whenever the point defined by the combination of Reactor Coolant System flow, AXIAL POWER IMBALANCE and THERMAL POWER has exceeded the appropriate safety limit, be in HOT STANDBY within one hour.

REACTOR COOLANT SYSTEM PRESSURE

2.1.3 The Reactor Coolant System pressure shall not exceed 2750 psig.

APPLICABILITY: MODES 1, 2, 3, 4 and 5.

ACTION:

MODES 1 and $2 -$	Whenever the Reactor Coolant System pressure has
	exceeded 2750 psig, be in HOT STANDBY with the
	Reactor Coolant System pressure within its limit within one hour.

MODES 3, 4 - Whenever the Reactor Coolant System pressure has and 5 exceeded 2750 psig, reduce the Reactor Coolant System pressure to within its limit within 5 minutes.

	Functional unit	Trip setpoint	Allowable values
1.	Manual reactor trip	Not applicable.	Not applicable.
2. High flux	High flux	<104.94% of RATED THERMAL POWER with four pumps operating	<104.94% of RATED THERMAL POWER with four pumps operating#
		<80.6% of RATED THERMAL POWER with three pumps operating	<pre>&lt;80.6% of RATED THERMAL POWER with three pumps operating#</pre>
3.	RC high temperature	<u>&lt;</u> 618°F	<u>&lt;</u> 618°F#
<b>4.</b>	Flux Δflux/flow <sup>(1)</sup>	Four pump trip setpoint not to exceed the limit line of Figure 2.2-1. For three pump operation, see Figure 2.2-1	Four pump allowable values not to exceed the limit line of Figure 2.2-1# For three pump operation, see Figure 2.2-1
5.	RC low pressure <sup>(1)</sup>	≥1983.4 psig	≥1983.4 <b>psig</b> * ≥1983.4 psig**
6.	RC high pressure	<2355 psig	<2355.0 psig* <2355.0 psig**
7.	RC pressure-temperature <sup>(1)</sup>	≥(12.60 T <sub>out</sub> <sup>o</sup> F - 5662.2) psig	≥(12.60 T <sub>out</sub> °F - 5662.2) psig#
8.	High flux/number of RC pumps on (1)	<pre>&lt;55.1% of RATED THERMAL POWER with one pump operating in each loop</pre>	<55.1% of RATED THERMAL POWER with one pump operating in each loop#
		<0.0% of RATED THERMAL POWER with two pumps operating in one loop and no pumps operating in the other loop	<pre>&lt;0.0% of RATED THERMAL POWER with two pumps operating in one loop and no pumps operating in the other loop#</pre>
		<0.0% of RATED THERMAL POWER with no pumps operating or only one pump operating	<pre>&lt;0.0% of RATED THERMAL POWER with no pumps operating or only one pump op- erating#</pre>
€.	Containment pressure high	<4 psig	<4 nsig#

1

٠

DAVIS-

.

2-5

Amendment No. 11, 16, 33, 45, 61, 80, 123, 128

## Table 2.2-1. (Cont'd)

DAVIS-BESSE, UNIT 1

(1) Trip may be manually bypassed when RCS pressure <1820 psig by actuating shutdown bypass provided that:

a. The high flux trip setpoint is <5% of RATED THERMAL POWER.

b. The shutdown bypass high pressure trip setpoint of ≤1820 psig is imposed.

c. The shutdown bypass is removed when RCS pressure >1820 psig.

\*Allowable value for CHANNEL FUNCTIONAL TEST.

**\*\*Allowable** value for CHANNEL CALIBRATION.

#Allowable value for CHANNEL FUNCTIONAL TEST and CHANNEL CALIBRATION.