

June 2, 1998

Distribution /encl:

Docket File	GHill (2)
PUBLIC	WBeckner
PD3-3 Reading	ACRS
EGAI	OGC
GGrant, RIII	RBellamy
THarris (TLH3, SE only)	JWermiel

Mr. John K. Wood
 Vice President - Nuclear, Davis-Besse
 Centerior Service Company
 c/o Toledo Edison Company
 Davis-Besse Nuclear Power Station
 5501 North State Route 2
 Oak Harbor, OH 43449-9760

SUBJECT: CORRECTION TO AMENDMENT NO. 221 TO FACILITY OPERATING
 LICENSE NO. NPF-3 - DAVIS-BESSE NUCLEAR POWER STATION,
 UNIT NO. 1 (TAC NO. M99133)

Dear Mr. Wood:

On April 15, 1998, the Commission issued Amendment No. 221 to Facility Operating License No. NPF-3 for the Davis-Besse Nuclear Power Station, Unit No. 1. The amendment revised the Technical Specifications (TSs) in response to your application dated June 24, 1997.

This amendment revised TS Section 3/4.3.2.1, "Safety Features Actuation System Instrumentation," TS Section 3/4.6.1.7, "Containment Ventilation System," TS Section 3/4.6.3.1, "Containment Isolation Valves," and TS Section 3/4.9.4, "Refueling Operations - Containment Penetrations," and the associated TS Bases.

A typographical error in a part of the TSs not changed by this amendment was inadvertently introduced into TS Table 3.3-3 on TS page 3/4 3-12. Prior to the typographical error, the second line of the table read "...removed when RCS...." The typographical error introduced by Amendment No. 221 changed the line to "...removed with RCS...." This correction changes it to read "...removed when RCS...." A corrected copy of this page is enclosed.

Sincerely,

Original signed by:

Allen G. Hansen, Project Manager
 Project Directorate III-3
 Division of Reactor Projects III/IV
 Office of Nuclear Reactor Regulation

Docket No. 50-346

Enclosure: As stated

cc w/encl: See next page

DOCUMENT NAME: G:\DAVISBES\DB99133.COR

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	PD33-LA	<input checked="" type="checkbox"/>	PD33-PM	<input checked="" type="checkbox"/>	OGC	<input checked="" type="checkbox"/>
NAME	EBarnhill	<input checked="" type="checkbox"/>	AHansen	<input checked="" type="checkbox"/>	R. Beckner	<input checked="" type="checkbox"/>
DATE	5/21/98		5/21/98		5/26/98	

OFFICIAL RECORD COPY

9806040124 980602
 PDR ADOCK 05000346
 PDR

FILE COPY

June 2, 1998

Distributive /encl:

Docket File	GHill (2)
PUBLIC	WBeckner
PD3-3 Reading	ACRS
EGA1	OGC
GGrant, RIII	RBellamy
THarris (TLH3, SE only)	JWermiel

Mr. John K. Wood
 Vice President - Nuclear, Davis-Besse
 Centerior Service Company
 c/o Toledo Edison Company
 Davis-Besse Nuclear Power Station
 5501 North State Route 2
 Oak Harbor, OH 43449-9760

SUBJECT: CORRECTION TO AMENDMENT NO. 221 TO FACILITY OPERATING
 LICENSE NO. NPF-3 - DAVIS-BESSE NUCLEAR POWER STATION,
 UNIT NO. 1 (TAC NO. M99133)

Dear Mr. Wood:

On April 15, 1998, the Commission issued Amendment No. 221 to Facility Operating License No. NPF-3 for the Davis-Besse Nuclear Power Station, Unit No. 1. The amendment revised the Technical Specifications (TSs) in response to your application dated June 24, 1997.

This amendment revised TS Section 3/4.3.2.1, "Safety Features Actuation System Instrumentation," TS Section 3/4.6.1.7, "Containment Ventilation System," TS Section 3/4.6.3.1, "Containment Isolation Valves," and TS Section 3/4.9.4, "Refueling Operations - Containment Penetrations," and the associated TS Bases.

A typographical error in a part of the TSs not changed by this amendment was inadvertently introduced into TS Table 3.3-3 on TS page 3/4 3-12. Prior to the typographical error, the second line of the table read "...removed when RCS...." The typographical error introduced by Amendment No. 221 changed the line to "...removed with RCS...." This correction changes it to read "...removed when RCS...." A corrected copy of this page is enclosed.

Sincerely,

Original signed by:

Allen G. Hansen, Project Manager
 Project Directorate III-3
 Division of Reactor Projects III/IV
 Office of Nuclear Reactor Regulation

Docket No. 50-346

Enclosure: As stated

cc w/encl: See next page

DOCUMENT NAME: G:\DAVISBES\DB99133.COR

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	PD33-LA	C	PD33-PM	E	OGC
NAME	EBarnhill	EB	AHansen	AH	5/22/98
DATE	5/21/98		5/21/98		5/21/98

OFFICIAL RECORD COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

June 2, 1998

Mr. John K. Wood
Vice President - Nuclear, Davis-Besse
Centerior Service Company
c/o Toledo Edison Company
Davis-Besse Nuclear Power Station
5501 North State Route 2
Oak Harbor, OH 43449-9760

SUBJECT: CORRECTION TO AMENDMENT NO. 221 TO FACILITY OPERATING
LICENSE NO. NPF-3 - DAVIS-BESSE NUCLEAR POWER STATION,
UNIT NO. 1 (TAC NO. M99133)

Dear Mr. Wood:

On April 15, 1998, the Commission issued Amendment No. 221 to Facility Operating License No. NPF-3 for the Davis-Besse Nuclear Power Station, Unit No. 1. The amendment revised the Technical Specifications (TSs) in response to your application dated June 24, 1997.

This amendment revised TS Section 3/4.3.2.1, "Safety Features Actuation System Instrumentation," TS Section 3/4.6.1.7, "Containment Ventilation System," TS Section 3/4.6.3.1, "Containment Isolation Valves," and TS Section 3/4.9.4, "Refueling Operations - Containment Penetrations," and the associated TS Bases.

A typographical error in a part of the TSs not changed by this amendment was inadvertently introduced into TS Table 3.3-3 on TS page 3/4 3-12. Prior to the typographical error, the second line of the table read "...removed when RCS..." The typographical error introduced by Amendment No. 221 changed the line to "...removed with RCS..." This correction changes it to read "...removed when RCS..." A corrected copy of this page is enclosed.

Sincerely,

A handwritten signature in black ink, appearing to read "Allen G. Hansen".

Allen G. Hansen, Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-346

Enclosure: As stated

cc w/encl: See next page

John K. Wood
Toledo Edison Company

Davis-Besse Nuclear Power Station, Unit 1

cc:

Mary E. O'Reilly
FirstEnergy
Davis-Besse Nuclear Power Station
5501 North State - Route 2
Oak Harbor, OH 43449-9760

Robert E. Owen, Chief
Bureau of Radiological Health
Service
Ohio Department of Health
P.O. Box 118
Columbus, OH 43266-0118

James L. Freels
Manager - Regulatory Affairs
Toledo Edison Company
Davis-Besse Nuclear Power Station
5501 North State - Route 2
Oak Harbor, OH 43449-9760

James R. Williams, Chief of Staff
Ohio Emergency Management Agency
2855 West Dublin Granville Road
Columbus, OH 43235-2206

Gerald Charnoff, Esq.
Shaw, Pittman, Potts
and Trowbridge
2300 N Street, NW.
Washington, DC 20037

Donna Owens, Director
Ohio Department of Commerce
Division of Industrial Compliance
Bureau of Operations & Maintenance
6606 Tussing Road
P.O. Box 4009
Reynoldsburg, OH 43068-9009

Regional Administrator
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60523-4351

Ohio Environmental Protection Agency
DERR--Compliance Unit
ATTN: Zack A. Clayton
P.O. Box 1049
Columbus, OH 43266-0149

Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
1700 Rockville Pike, Suite 525
Rockville, MD 20852

State of Ohio
Public Utilities Commission
180 East Broad Street
Columbus, OH 43266-0573

Resident Inspector
U.S. Nuclear Regulatory Commission
5503 North State Route 2
Oak Harbor, OH 43449

Attorney General
Department of Attorney
30 East Broad Street
Columbus, OH 43216

James H. Lash, Plant Manager
Toledo Edison Company
Davis-Besse Nuclear Power Station
5501 North State Route 2
Oak Harbor, OH 43449-9760

President, Board of County
Commissioner of Ottawa County
Port Clinton, OH 43252

TABLE 3.3-3 (Continued)

TABLE NOTATION

- * Trip function may be bypassed in this MODE with RCS pressure below 1800 psig. Bypass shall be automatically removed when RCS pressure exceeds 1800 psig.
- ** Trip function may be bypassed in this MODE with RCS pressure below 660 psig. Bypass shall be automatically removed when RCS pressure exceeds 660 psig.
- *** DELETED
- **** DELETED
- ***** All functional units may be bypassed for up to one minute when starting each Reactor Coolant Pump or Circulating Water Pump.
- ***** When either Decay Heat Isolation Valve is open.
- # The provisions of Specification 3.0.4 are not applicable.

ACTION STATEMENTS

- ACTION 10 - With the number of OPERABLE functional units one less than the Total Number of Units, STARTUP and/or POWER OPERATION may proceed provided both of the following conditions are satisfied:
- a. The inoperable functional unit is placed in the tripped condition within one hour.
 - b. The Minimum Units OPERABLE requirement is met; however, one additional functional unit may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.2.1.1.
- ACTION 11 - With any component in the Output Logic inoperable, trip the associated components within one hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

9806040129 980602
PDR ADOCK 05000346
P PDR

DAVIS-BESSE, UNIT 1

3/4 3-12

Amendment No. ~~28, 37, 52, 102,~~
~~135, 159, 186, 211, 218, 221~~

Corrected by letter dated 6/2/98