



TXU Energy
Comanche Peak Steam
Electric Station
P.O. Box 1002 (E01)
Glen Rose, TX 76043
Tel: 254 897 8920
Fax: 254 897 6652
lance.terry@txu.com

C. Lance Terry
Senior Vice President &
Principal Nuclear Officer

Ref: [10CFR50.55a]

CPSES-200201225
Log # TXX-02076
File # 10010.1
916
RP-39

April 18, 2002

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

**SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES) -UNIT 2
DOCKET NO. 50-446
UNIT 2, SIXTH REFUELING OUTAGE (2RF06)
STEAM GENERATOR INSERVICE INSPECTION TUBE PLUGGING
SPECIAL REPORT NO. 2-SR-02-001-00**

Gentlemen:

Attached is a 15-day special report submitted pursuant to CPSES Technical Specification 5.6.10a. If there are any questions or additional information is needed, please contact Obaid Bhatti at (254) 897-5839.

This communication contains no new licensing basis commitments regarding CPSES Units 1 and 2.

*DO29
A047*

A member of the **STARS** (Strategic Teaming and Resource Sharing) Alliance


Callaway • Comanche Peak • Diablo Canyon • Palo Verde • South Texas Project • Wolf Creek

TXX-02076
Page 2 of 2

Sincerely,

TXU Generation Company LP
By: TXU Generation Management Company LLC,
Its General Partner

C. L. Terry
Senior Vice President and Principal Nuclear Officer

By: 
Roger D. Walker
Regulatory Affairs Manager

RJK/rjk

Attachment

cc - E. W. Merschoff, Region IV
W. D. Johnson, Region IV
D. H. Jaffe, NRR
Resident Inspectors, CPSES

Attachment to TXX-02076

Page 1 of 1

TXU ENERGY
COMANCHE PEAK STEAM ELECTRIC STATION - UNIT 2
SPECIAL REPORT NO. 2-SR-02-001-00
UNIT 2, SIXTH REFUELING OUTAGE (2RF06)
STEAM GENERATOR INSERVICE INSPECTION TUBE PLUGGING

This letter provides the Inservice Inspection (ISI) Special Report on the steam generator tube ISI for Comanche Peak Steam Electric Station's sixth refueling outage (2RF06) on Unit 2. This report is being provided to you pursuant to CPSES Technical Specification 5.6.10a.

Steam Generators 2 and 3 were inspected during 2RF06. The examinations were complete on April 14, 2002. The number of tubes plugged during this outage in each steam generator is as follows:

CPSES Unit 2 Steam Generator No. 2: Four (4)

CPSES Unit 2 Steam Generator No. 3: Seven (7)

Additional details on the plugged tubes and inspection effort will be provided in the 12-month report pursuant to CPSES Technical Specification 5.6.10b.