

September 19, 1986

DMB 016

Docket No. 50-313

DISTRIBUTION

Docket File

NRC PDR
L PDR
PBD-6
FMiraglia
OGC-MNBB 9604
EButcher
LHarmon
ACRS-10
CMiles

BGrimes
WJones
WRegan
RDiggs
RIngram
GVising
Gray File
EJordan
TBarnhart-12
JPartlow
NThompson

JRamsey
GEdison

Mr. Gene Campbell
Vice President, Nuclear
Operations
Arkansas Power and Light Company
P. O. Box 551
Little Rock, Arkansas 72203

Dear Mr. Campbell:

The Commission has issued the enclosed Amendment No. 100 to Facility Operating License No. DPR-51 for Arkansas Nuclear One, Unit No. 1 (ANO-1). This amendment consists of changes to the Technical Specifications (TSs) in response to your application dated January 24, 1986.

The amendment revises the TSs to delete the tabular listings of shock suppressors (snubbers) in accordance with the Commission's guidance contained in Generic Letter 84-13.

A copy of our Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

~~XXXXXXXXXX~~

Guy S. Vissing, Project Manager
PWR Project Directorate #6
Division of PWR Licensing-B

Enclosures:

- 1. Amendment No. 100 to DPR-51
- 2. Safety Evaluation

cc w/enclosures:
See next page

Chgs. made 9/18/86.

No legal direction
conclusions based on
McGarner's change
to
eval.

PBD-6
RIngram
9/10/86

PBD-6
GVising
9/10/86

PBD-6
JRamsey
9/10/86

PBD-6
CMcCracken
9/12/86

PBD-6
GEdison
9/12/86

PBD-6
JStolz
9/12/86

OGC
9/16/86

8610070506 860919
PDR ADOCK 05000313
P PDR

Mr. G. Campbell
Arkansas Power & Light Company

Arkansas Nuclear One, Unit 1

cc:

Mr. J. Ted Enos, Manager
Nuclear Engineering and Licensing
Arkansas Power & Light Company
P. O. Box 551
Little Rock, Arkansas 72203

Mr. James M. Levine, Director
Site Nuclear Operations
Arkansas Nuclear One
P. O. Box 608
Russellville, Arkansas 72801

Mr. Nicholas S. Reynolds
Bishop, Liberman, Cook, Purcell & Reynolds
1200 Seventeenth Street, N.W.
Washington, D.C. 20036

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220, 7910 Woodmont Avenue
Bethesda, Maryland 20814

Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 2090
Russellville, Arkansas 72801

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Office of Executive Director
for Operations
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Mr. Frank Wilson, Director
Division of Environmental Health
Protection
Department of Health
Arkansas Department of Health
4815 West Markham Street
Little Rock, Arkansas 72201

Honorable William Abernathy
County Judge of Pope County
Pope County Courthouse
Russellville, Arkansas 72801



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

ARKANSAS POWER AND LIGHT COMPANY

DOCKET NO. 50-313

ARKANSAS NUCLEAR ONE, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 100
License No. DPR-51

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Arkansas Power and Light Company (the licensee) dated January 24, 1986, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.c.(2) of Facility Operating License No. DPR-51 is hereby amended to read as follows:

8610070510 860919
PDR ADOCK 05000313
PDR

Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 100, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

A E Edison for

John F. Stolz, Director
PWR Project Directorate #6
Division of PWR Licensing-B

Attachment:
Changes to the Technical
Specifications

Date of Issuance: September 19, 1986

ATTACHMENT TO LICENSE AMENDMENT NO. 100

FACILITY OPERATING LICENSE NO. DPR-51

DOCKET NO. 50-313

Replace the following pages of the Appendix "A" Technical Specifications with the attached pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change.

<u>Remove</u>	<u>Insert</u>
66i	66i
66j	66j
66k	-
66l	-
66l-1	-
66l-2	-
66l-3	-
66l-4	-
66l-5	-
66l-6	-
66l-7	-
110e	110e
129	129

3.16 Shock Suppressors (Snubbers)

Applicability

This technical specification applies to all shock suppressors (snubbers). The only snubbers excluded from this requirement are those installed on nonsafety-related systems and then only if their failure or failure of the system on which they are installed, would have no adverse effect on any safety-related system.

Objective

To assure adequate shock suppression protection for primary coolant system piping and any other safety related system or component under dynamic loads as might occur during an earthquake or severe transient, while allowing normal thermal motion during startup and shutdown. This is done by assuring the operability of those shock suppressors installed for that purpose.

Specification

- 3.16.1 The reactor shall not be heated above 200F if any applicable shock suppressor is known to be inoperable.
- 3.16.2 If any applicable shock suppressor is determined to be inoperable during power operation, that shock suppressor shall be made operable or replaced within 72 hours or the reactor shall be placed in the cold shutdown condition within an additional 36 hours.

Bases

Shock suppressors are designed to prevent unrestrained pipe motion under dynamic loads as might occur during an earthquake or severe transient, while allowing normal thermal motion during startup and shutdown. The consequence of an inoperable shock suppressor is an increase in the probability of structural damage to piping as a result of a seismic or other event initiating dynamic loads. It is therefore required that all shock suppressors required to protect the primary coolant system or any other safety system or component be operable during reactor operation.

Because the shock suppressor protection is required only during low probability events, a period of 72 hours is allowed for repairs or replacements. In case a shutdown is required, the allowance of 36 hours to reach a cold shutdown condition will permit an orderly shutdown consistent with standard operating procedures. Since plant startup should not commence with knowingly defective safety related equipment, Specification 3.16.1 prohibits startup with inoperable shock suppressors.

TABLE 3.16-1

SAFETY RELATED HYDRAULIC SHOCK SUPPRESSORS (SNUBBERS)
(DELETED)

TABLE 3.16-2

SAFETY RELATED MECHANICAL SHOCK SUPPRESSORS (SNUBBERS)
(DELETED)

66j (NEXT PAGE 66m)

Amendment No. ~~23~~, ~~43~~, ~~84~~, 100

4.16 SHOCK SUPPRESSORS (Snubbers)

Applicability

This technical specification applies to all shock suppressors (snubbers). The only snubbers excluded from this requirement are those installed on nonsafety-related systems and then only if their failure or failure of the system on which they are installed would have no adverse effect on any safety-related system.

Objective

Verify an acceptable level of operability of the shock suppressors protecting the primary system and any other safety related system or component.

Specification

4.16.1 The following surveillance requirements apply to all applicable shock suppressors.

a. Inspection Types

As used in this specification, type of snubber shall mean snubbers of the same design and manufacturer, irrespective of capacity.

Snubbers are categorized as inaccessible or accessible during reactor operation.

b. Visual Inspections

Visual inspections shall be performed in accordance with the following schedule:

<u>No. Inoperable Snubbers per Inspection Period</u>	<u>Subsequent Visual Inspection Period</u>
0	18 months \pm 25%
1	12 months \pm 25%
2	6 months \pm 25%
3, 4	124 days \pm 25%
5, 6, 7	62 days \pm 25%
8 or more	31 days \pm 25%

The snubbers may be categorized into groups based on type and accessibility. Each group may be inspected independently in accordance with the above schedule.

The inspection interval for each type of snubber shall not be lengthened more than one step at a time unless a generic problem has been identified and corrected; in that event the inspection interval may be lengthened one step the first time and two steps thereafter if no inoperable snubbers of that type are found.

The provisions of Specification 4 regarding surveillance intervals are not applicable.

- h. Records of in-service inspections performed pursuant to these Technical Specifications.
- i. Records of Quality Assurance activities required by Section 17 of the Quality Assurance Manual for Operations.
- j. Records of reviews performed for changes made to procedures or equipment or reviews of tests and experiments pursuant to 10CFR50.59.
- k. Records of meetings of the PSC and the SRC.
- l. Records for Environmental Qualification which are covered under the provisions of paragraph 6.13.
- m. Records of the service lives of the seals of all hydraulic snubbers applicable to Specification 3.16 including the date at which the service life commences and associated installation and maintenance records.
- n. Records of the analyses required by the Radiological Environmental Monitoring Program.

6.10 RADIATION PROTECTION PROGRAM

Procedures for personnel radiation protection shall be prepared consistent with the requirements of 10CFR Part 20 and shall be approved, maintained and adhered to for all operations involving personnel radiation exposure.

6.11 HIGH RADIATION AREA

6.11.1 In lieu of the "control device" or "alarm signal" required by paragraph 20.203(c)(2) of 10CFR20, each high radiation area (as defined in 20.202(b)(3) of 10CFR20) in which the intensity of radiation is 1000 mrem/hr or less shall be barricaded and conspicuously posted as a high radiation area and shall be controlled by requiring the issuance of a radiation work permit. Any individual or group of individuals permitted to enter such areas shall be provided with or accompanied by one or more of the following:

- a. A radiation monitoring device which continuously indicates the radiation dose rate in the area.
- b. A radiation monitoring device which continuously integrates the radiation dose rate in the area and alarms when a pre-set integrated dose is received. Entry into such areas with this monitoring device may be made after the dose rate level in the area has been established and personnel have been made knowledgeable of them.
- c. An individual qualified in radiation protection procedures who is equipped with a radiation dose rate monitoring device. This individual shall be responsible for providing positive control over the activities within the area and shall perform periodic radiation surveillance at the frequency specified in the radiation work permit.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
SUPPORTING AMENDMENT NO.100 TO FACILITY OPERATING LICENSE NO. DPR-51

ARKANSAS POWER AND LIGHT COMPANY

ARKANSAS NUCLEAR ONE, UNIT NO. 1

DOCKET NO. 50-313

INTRODUCTION

By letter dated January 24, 1986, Arkansas Power and Light Company (AP&L or the licensee) requested amendment to the Technical Specifications (TSs) appended to Facility Operating License No. DPR-51 for Arkansas Nuclear One, Unit No. 1 (ANO-1). The proposed amendment would delete the tabular listing (Tables 3.16-1 and 3.16-2) of shock suppressors (snubbers) and add the criteria specifying which snubbers are required to be operable and which snubbers are exempted from the requirements of Specification 3.16. The licensee's application was made in response to the Commission's Generic Letter 84-13, "Technical Specification for Snubbers," dated May 3, 1984. These changes are expected to eliminate the need for frequent TS amendments to incorporate changes in the snubber listings.

EVALUATION

The NRC staff indicated in the aforementioned Generic Letter that it had reassessed the inclusion of snubber listings within the TSs and concluded that such listings were not necessary provided the snubber TSs are modified to specify which snubbers are required to be operable. The licensee's requested changes to the TSs would delete the tabular listings of snubbers and add the criteria requiring all snubbers operable except the snubbers on nonsafety-related systems whose failures would have no adverse effects on any safety-related system.

We have reviewed the current TSs together with the proposed changes and compared these changes with model TSs provided in the Generic Letter. From our review, we find that the proposed changes are administrative in nature and do not authorize any physical change to the plant's safety-related structures, systems or components. The proposed changes would not in any way reduce availability of those snubbers which are provided to ensure that the structural integrity of the reactor coolant system and all other safety-related systems is maintained during and following a seismic or other event initiating dynamic loads.

Based on the above discussions and the fact that the proposed changes are consistent with guidance provided in the Generic Letter, we have determined that the proposed changes are acceptable.

8610070512 860919
PDR ADOCK 05000312
P PDR

ENVIRONMENTAL CONSIDERATION

This amendment involves changes relating to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. We have determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that this amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of this amendment.

CONCLUSION

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Dated: September 19, 1986

Principal Contributors: J. Ramsey
M. Hartzman