

Lew W. Myers
Senior Vice President

724-682-5234
Fax: 724-643-8069

April 19, 2002
L-02-038

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555-0001

**Subject: Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
Technical Specification Bases Change Submittal**

This submittal provides three CD-ROMs containing Technical Specification Bases changes in accordance with Technical Specification 6.18, "Technical Specifications Bases Control Program." The enclosed attachment provides a summary of the changes.


If there are any questions concerning this matter, please contact Mr. Larry R. Freeland, Manager, Regulatory Affairs/Corrective Action at 724-682-5284.

Sincerely,



Lew W. Myers

c: Mr. D. S. Collins, Project Manager
Mr. D. M. Kern, Sr. Resident Inspector
Mr. H. J. Miller, NRC Region I Administrator
Mr. D. A. Allard, Director BRP/DEP
Mr. L. E. Ryan (BRP/DEP)

Acc 1
CD's 1/3


ATTACHMENT

TECHNICAL SPECIFICATION BASES CHANGE SUMMARY

CHANGE NUMBER	DESCRIPTION
1-002	Technical Specification bases were changed to reflect Amendment 247. Amendment 247 revised Technical Specification Section 3.9.3 to reduce the minimum decay time required prior to fuel movement from 150 hours to 100 hours.
1-003	Technical Specification bases were changed to reflect Amendments 243 and 248. Amendment 243 revised Technical Specifications to permit a 1.4-percent increase in the plant's operating power level. Amendment 248 modified Technical Specification 3.7.1.1, Main Steam Safety Valves (MSSVs), maximum power levels permissible with inoperable MSSVs, clarified the bases for the determination of the total relieving capacity of the MSSVs and made other minor changes.
1-004	Technical Specification bases were changed to reflect Amendment 249. This amendment revised the heat-up and cool-down pressure and temperature curves and the cold overpressure protection setpoints.