

January 27, 1995

Mr. Jerry W. Yelverton
Vice President, Operations ANO
Entergy Operations, Inc.
Route 3 Box 137G
Russellville, Arkansas 72801

SUBJECT: ARKANSAS NUCLEAR ONE-UNIT 1, USE OF LATER CODE EDITION TO TEST
SAFETY VALVES (TAC NO. M90220)

Dear Mr. Yelverton:

By letter dated December 22, 1994, we received your request to update your inservice testing program for testing the main steam safety valves per Part 1 to the ASME/ANSI Standard OMa-1988 (OM-1-1987). The staff approves the use of the 1989 Edition of ASME Section XI, which includes OM-1-1987 by reference, pursuant to 10 CFR 50.55a(f)(4)(iv).

Sincerely,

ORIGINAL SIGNED BY:

George Kalman, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-313

cc: See next page

DISTRIBUTION:

<u>Docket File</u>	PUBLIC	PD4-1 r/f
JRoe	PNoonan	GKalman
OGC	ACRS (4)	ABBeach, RIV
PCampbell	WBeckner	

Document Name: AR190220.LTR

OFC	LA/PD4-1	PM/PD4-1	EMEB <i>abc</i>	D/PDIV-1
NAME	PNoonan <i>PN</i>	GKalman/vw <i>GK</i>	PCampbell	WBeckner <i>WB</i>
DATE	1/27/95	1/27/95	1/27/95	1/27/95
COPY	YES/NO	YES/NO	YES/NO	YES/NO

OFFICIAL RECORD COPY

010027

Don Johnson
1/27/95

NUREG FILE CENTER COPY

9502010297 950127
PDR ADOCK 05000313
P PDR

DFD | 0



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

January 27, 1995

Mr. Jerry W. Yelverton
Vice President, Operations ANO
Entergy Operations, Inc.
Route 3 Box 137G
Russellville, Arkansas 72801

SUBJECT: ARKANSAS NUCLEAR ONE-UNIT 1, USE OF LATER CODE EDITION TO TEST
SAFETY VALVES (TAC NO. M90220)

Dear Mr. Yelverton:

By letter dated December 22, 1994, we received your request to update your inservice testing program for testing the main steam safety valves per Part 1 to the ASME/ANSI Standard OMa-1988 (OM-1-1987). The staff approves the use of the 1989 Edition of ASME Section XI, which includes OM-1-1987 by reference, pursuant to 10 CFR 50.55a(f)(4)(iv).

Sincerely,

A handwritten signature in black ink that reads "George Kalman".

George Kalman, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-313

cc: See next page

Mr. Jerry W. Yelverton
Entergy Operations, Inc.

Arkansas Nuclear One, Unit 1

cc:

Mr. Harry W. Keiser, Executive Vice
President & Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, Mississippi 39286

Mr. Jerrold G. Dewease
Vice President, Operations Support
Entergy Operations, Inc.
P. O. Box 31995
Jackson, Mississippi 39286

Mr. Charles B. Brinkman, Manager
Washington Nuclear Operations
ABB Combustion Engineering
Nuclear Power
12300 Twinbrook Parkway, Suite 330
Rockville, Maryland 20852

Mr. Robert B. McGehee
Wise, Carter, Child & Caraway
P. O. Box 651
Jackson, Mississippi 39205

Mr. Nicholas S. Reynolds
Winston & Strawn
1400 L Street, N.W.
Washington, D.C. 20005-3502

Admiral Kinnaird R. McKee, USN (Ret)
214 South Morris Street
Oxford, Maryland 21654

Mr. Robert B. Borsum
Licensing Representative
B&W Nuclear Technologies
1700 Rockville Pike, Suite 525
Rockville, Maryland 20852

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 310
London, Arkansas 72847

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Honorable C. Doug Lunningham
County Judge of Pope County
Pope County Courthouse
Russellville, Arkansas 72801

Ms. Greta Dicus, Director
Division of Radiation Control
and Emergency Management
Arkansas Department of Health
4815 West Markham Street
Little Rock, Arkansas 72205-3867