Docket No. 50-498

Mr. J. H. Goldberg Group Vice-President, Nuclear Houston Lighting & Power Company P. O. Box 1700 Houston, Texas 77001

Dear Mr. Goldberg:

SUBJECT: ISSUANCE OF AMENDMENT NO. 1 TO FACILITY OPERATING LICENSE NPF-76 - SOUTH TEXAS PROJECT, UNIT 1 (TAC NO. 67930)

The Commission has issued the enclosed Amendment No. 1 to Facility Operating License No. NPF-76 for the South Texas Project, Unit 1. The amendment consists of changes to the Technical Specifications (TSs) in response to your application dated May 23, 1988 as supplemented May 23, 1988.

The amendment changes the Technical Specifications to delete all references to the excessive cooldown protection and associated items.

A copy of the Safety Evaluation supporting the amendment is also enclosed. Notice of Issuance will be included in the Commission's next Bi-weekly <u>Federal</u> <u>Register</u> notice.

> Sincerely, /s/ George F. Dick, Jr., Project Manager Project Directorate - IV Division of Reactor Projects - III, IV, V and Special Projects Office of Nuclear Reactor Regulation

Enclosures: 1. Amendment No. 1 to NPF-76 2. Safety Evaluation

cc w/enclosures: See next page DISTRIBUTION: Docket File **JPartlow** NRC PDR TBarnhart (4) Local PDR PD4 Reading Wanda Jones EButcher PNoonan (3) ACRS (10) G. Dick GPA/PA OGC-Rockville JCalvo ARM/LFMB DHagan M. Hodges S. Newberry EJordan Plant File DOCUMENT NAME: STP TAC NO. 67930 PD4/D MC 4/PM PD4/LOW SRXBMM SICB -OGC-Rockville SNewberry PNoonan Glivck:sr MHodges JCalvo 05/23/88 05/23/88 05/23/88 05/3/88 05/2y/88 05 DR4A LRubenstéin 05/z4/88 8806020249 880524 PDR ADDCK 05000498 PDR

Docket No. 50-498

Mr. J. H. Goldberg Group Vice-President, Nuclear Houston Lighting & Power Company P. O. Box 1700 Houston, Texas 77001

Dear Mr. Goldberg:

SUBJECT: ISSUANCE OF AMENDMENT NO.<sup>1</sup> TO FACILITY OPERATING LICENSE NPF-76 - SOUTH TEXAS PROJECT, UNIT 1 (TAC NO. 67930)

The Commission has issued the enclosed Amendment No.<sup>1</sup> to Facility Operating License No. NPF-76 for the South Texas Project, Unit 1. The amendment consists of changes to the Technical Specifications (TSs) in response to your application dated May 23, 1988 as supplemented May 23, 1988.

The amendment changes the Technical Specifications to delete all references to the excessive cooldown protection and associated items.

A copy of the Safety Evaluation supporting the amendment is also enclosed. Notice of Issuance will be included in the Commission's next Bi-weekly <u>Federal</u> <u>Register</u> notice.

> Sincerely, /s/ George F. Dick, Jr., Project Manager Project Directorate - IV Division of Reactor Projects - III, IV, V and Special Projects Office of Nuclear Reactor Regulation

Enclosures: 1. Amendment No. 1 to NPF-76 2. Safety Evaluation

cc w/enclosures: See next page <u>DISTRIBUTION:</u> Docket File JPartlow Local PDR Wanda Jones PNoonan (3) ACRS (10) JCalvo ARM/LFMB M. Hodges S. Newberry

NRC PDR PD4 Reading G. Dick OGC-Rockville EJordan TBarnhart (4) EButcher GPA/PA DHagan Plant File

DOCUMENT NAME: STP TAC NO. 67930 PD4/D MC PD4/LACA 04/PM SRXB MM OGC-Rockville MHodges JCalvo PNoonan SNewberry GUNCK:sr 05/93/88 05/23/88 05/23/88 05/53/88 05/ 05/2y/88 DR4A LRubenstein 05/24/88



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555 May 24, 1988

Docket No. 50-498

Mr. J. H. Goldberg Group Vice-President, Nuclear Houston Lighting & Power Company P. O. Box 1700 Houston, Texas 77001

Dear Mr. Goldberg:

SUBJECT: ISSUANCE OF AMENDMENT NO. <sup>1</sup> TO FACILITY OPERATING LICENSE NPF-76 - SOUTH TEXAS PROJECT, UNIT 1 (TAC NO. 67930)

The Commission has issued the enclosed Amendment No. 1 to Facility Operating License No. NPF-76 for the South Texas Project, Unit 1. The amendment consists of changes to the Technical Specifications (TSs) in response to your application dated May 23, 1988 as supplemented May 23, 1988.

The amendment changes the Technical Specifications to delete all references to the excessive cooldown protection and associated items.

A copy of the Safety Evaluation supporting the amendment is also enclosed. Notice of Issuance will be included in the Commission's next Bi-weekly <u>Federal</u> <u>Register</u> notice.

Sincerely,

George F. Dick, Jr., Project Manager Project Directorate - IV Division of Reactor Projects - III, IV, V and Special Projects Office of Nuclear Reactor Regulation

Enclosures: 1. Amendment No. <sup>1</sup> to NPF-76 2. Safety Evaluation

cc w/enclosures: See next page Mr. J. H. Goldberg Houston Lighting and Power Company

cc: Brian Berwick, Esq. Assistant Attorney General Environmental Protection Division P. O. Box 12548 Capitol Station Austin, Texas 78711

Mr. J. T. Westermeier General Manager, South Texas Project Houston Lighting and Power Company P. O. Box 289 Houston, Texas 77483

Mr. R. J. Miner Chief Operating Officer City of Austin Electric Utility 721 Barton Springs Road Austin, Texas 78704

Mr. R. J. Costello Mr. M. T. Hardt City Public Service Board P. O. Box 1771 San Antonio, Texas 78296

Jack R. Newman, Esq. Newman & Holtzinger, P. C. 1615 L Street, NW Washington, D.C. 20036

Melbert Schwartz, Jr., Esq. Baker & Botts One Shell Plaza Houston, Texas 77002

Mrs. Peggy Buchorn Executive Director Citizens for Equitable Utilities, Inc. Route 1, Box 1684 Brazoria, Texas 77422

Mr. S. L. Rosen General Manager, Operations Support Houston Lighting and Power Company P. O. Box 289 Wadsworth, Texas 77483 South Texas Project

Resident Inspector/South Texas Project c/o U.S. Nuclear Regulatory Commission P. O. Box 910 Bay City, Texas 77414 Mr. Jonathan Davis Assistant City Attorney City of Austin P. 0. Box 1088 Austin, Texas 78767 Ms. Pat Coy Citizens Concerned About Nuclear Power 10 Singleton Eureka Springs, Arkansas 72632 Mr. M. A. McBurnett Manager, Operations Support Licensing Houston Lighting and Power Company P. 0. Box 289 Wadsworth, Texas 77483 Mr. A. Zaccaria Mr. K. G. Hess **Bechtel Corporation** P. 0. Box 2166 Houston, Texas 77001 Mr. R. P. Verret Mr. R. L. Range Central Power and Light Company P. O. Box 2121 Corpus Christi, Texas 78403

Mr. J. H. Goldberg Houston Lighting & Power

#### cc:

۰.

Regional Administrator, Region IV U.S. Nuclear Regulatory Commission Office of Executive Director for Operations 611 Ryan Plaza Drive, Suite 1000 Arlington, Texas 76011

Mr. Lanny Sinkin, Counsel for Intervenor Citizens Concerned about Nuclear Power, Inc. Christic Institute 1324 North Capitol Street Washington, D.C. 20002

Licensing Representative Houston Lighting and Power Company Suite 610 Three Metro Center Bethesda, Maryland 20814

Rufus S. Scott Associate General Counsel Houston Lighting & Power Company P. O. Box 1700 Houston, Texas 77001

#### INPO

Records Center 1100 Circle 75 Parkway Atlanta, Georgia 30339-3064

Joseph M. Hendrie 50 Bellport Lane Bellport, New York 11713

Gerald E. Vaughn, Vice President Nuclear Operations Houston Lighting & Power Company P. O. Box 289 Wadsworth, Texas 77483

R. W. Chewning, Chairman Nuclear Safety Review Board Houston Lighting & Power Company P. O. Box 289 Wadsworth, Texas 77483



#### UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

# HOUSTON LIGHTING & POWER COMPANY

# DOCKET NO. 50-498

# SOUTH TEXAS PROJECT, UNIT 1

## AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 1 License No. NPF-76

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Houston Lighting & Power Company (HL&P) dated May 23, 1988 as supplemented May 23, 1988, complies with the standards and requirements of the Atomic Energy Act\_ of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8806020255 880524 PDR ADOCK 05000478

- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph-2.C.(2) of Facility Operating License No. NPF-76 is hereby amended to read as follows:
  - 2. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. , and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

- . . . X.S.M. chenslen

Lester S. Rubenstein, Assistant Director for Region IV and Special Projects Division of Reactor Projects - III, IV, V and Special Projects Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: May 24, 1988

# ATTACHMENT TO LICENSE AMENDMENT NO. 1

# FACILITY OPERATING LICENSE NO. NPF-76

## DOCKET NO. 50-498

Replace the following pages of the Appendix A Technical Specifications with the attached pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change. The corresponding overleaf pages are also provided to maintain document completeness.

	Remove	Insert	
	3/4 3-18	3/4 3-18	
	3/4 3-21	3/4 3-21	
	3/4 3-22	3/4 3-22	
	3/4 3-24	3/4 3-24	
	3/4 3-26	3/4 3-26	
	3/4 3-29	3/4 3-29	
	3/4 3-31	3/4 3-21	
	3/4 3-32	3/4 3-32	
	3/4 3-34	3/4 3-34	
	3/4 3-36	3/4 3-36	
	3/4 3-38	3/4 3-38	
	3/4 3-40	3/4 3-40	
	3/4 3-42	3/4 3-42	
	3/4 3-45	3/4 3-45	
	3/4 3-47	3/4 4-47	
	3/4 3-49	3/4 3-49	
R	3/4 3-3	R 3/4 3-45	
5		0 0/4 0-0	

## SURVEILLANCE REOUIREMENTS

4.3.2.1 Each ESFAS instrumentation channel and interlock and the automatic actuation logic and relays shall be demonstrated OPERABLE by performance of the ESFAS Instrumentation Surveillance Requirements specified in Table 4.3-2.

4.3.2.2 The ENGINEERED SAFETY FEATURES RESPONSE TIME of each ESFAS function shall be demonstrated to be within the limit at least once per 18 months. Each test shall include at least one train so that:

- a. Each logic train is tested at least once per 36 months,
- b. Each actuation train is tested at least once per 54 months\*, and
- c. One channel per function so that all channels are tested at least once per N times 18 months where N is the total number of redundant channels in a specific ESFAS function as shown in the "Total No. of Channels" column of Table 3.3-3.

SOUTH TEXAS - UNIT 1

<sup>\*</sup>If an ESFAS instrumentation channel is inoperable due to response times exceeding the limits of Table 3.3-5, perform an engineering evaluation to determine if the test failure is a result of degradation of the actuation relays. If degradation of the actuation relays is determined to be the cause, increase the ENGINEERED SAFETY FEATURES RESPONSE TIME surveillance frequency such that all trains are tested at least once per 36 months.

# TABLE 3.3-3

# ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION

FUN	CTION	AL UNIT	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
1.	Saf Tri Con Ven Die Con and	ety Injection (Reactor p, Feedwater Isolation, trol Room Emergency tilation, Start Standby sel Generators, Reactor tainment Fan Coolers, Essential Cooling Water)	).				
	a.	Manual Initiation	2	1	2	1, 2, 3, 4	19
	b.	Automatic Actuation Logic	2	1	2	1, 2, 3, 4	14
	c.	Actuation Relays	3	2	3	1, 2, 3, 4	14
	d.	Containment PressureHigh-1	3	2	2	1, 2, 3, 4	15
	e.	Pressurizer PressureLow	4	2	3	1, 2, 3#	20
	f.	Compensated Steam Line Pressure-Low	3/steam line	2/steam line any steam line	2/steam line in each steam line	1, 2, 3#	15

SOUTH TEXAS - UNIT 1

3/4 3-18

. )

		ENGINEER	ED SAFETY FEATU	RES ACTUATION S	YSTEM INSTRUMENT	ATION	
FUN	CTION	AL UNIT	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
4.	Stea	am Line Isolation					
	a.	Manual Initiation					
		1) Individual	2/steam line	1/steam line	2/operating steam line	1, 2, 3	24
		2) System	2	1	2	1, 2, 3	23
	b.	Automatic Actuation Logic and Actuation Relays	2	1	2	1, 2, 3	22
	c.	Steam Line Pressure - Negative RateHigh	3/steam line	2/steam line any steam line	2/steam line in each steam line	3###	15
	d.	Containment Pressure - High-2	3	2	2	1, 2, 3	15
	e.	Compensated Steam Line Pressure - Low	3/steam line	2/steam line any steam line	2/steam line in each steam line	1, 2, 3#	15

• ]

		ENGINEERE	D SAFETY FEATUR	RES ACTUATION SY	STEM INSTRUMEN	TATION	
<u>FUN(</u> 5.	<u>TION</u> Turl	AL UNIT Dine Trip and Feedwater Is	TOTAL NO. <u>OF CHANNELS</u> solation	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABL MODES	E <u>ACTION</u>
	a.	Automatic Actuation Logic and Actuation Relays	2	1	2	1, 2, 3	25
	b.	Steam Generator Water Level High-High (P-14)	4/stm. gen.	2/stm.gen. in any oper- ating stm. gen.	3/stm.gen. in each operating stm.gen.	1, 2, 3	20
	c.	Deleted					
	d.	Deleted					
	e.	Safety Injection	See Item 1. fo functions and	r all Safety In requirements.	jection initia	ting	
	f.	T <sub>avg</sub> -Low coincident with Reactor Trip (P-4)**	4 (1/loop)	2	3	1, 2, 3	20

SOUTH TEXAS - UNIT 1

3/4 3-22

Amendment No.<sup>1</sup>

•

# ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION

FUN	UNCTIONAL UNIT		TOTAL NO. <u>Of Channel</u>	CHANNELS S TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
6.	Aux	iliary Feedwater					
	a.	Manual Initiation	1/pump	1/pump	1/pump	1, 2, 3	26
	b.	Automatic Actuation Logic	2	1	2	1, 2, 3	22
	c.	Actuation Relays	3	2	3	1, 2, 3	22
	d.	Stm. Gen. Water Level Low-Low Start Motor- Driven Pumps 4/st and Turbine- Driven Pump	m. gen.	2/stm. gen. in any stm. gen.	3/stm. gen. in each stm. gen.	1, 2, 3	20
	e.	Safety Injection	See Item 1 requiremen	. above for all its.	Safety Injectio	n initiating fund	tions and
	f.	Loss of Power (Motor Driven Pumps Only)	See Item 8 requiremen	. below for all ts.	Loss of Power i	nitiating functio	ons and
7.	Aut Con	comatic Switchover to stainment Sump****					
	a.	Automatic Actuation Logic and Actuation Relays	3-1/train	1/train	1/train	1, 2, 3, 4	19
	b.	RWST LevelLow-Low	3-1/train	1/train	1/train	1, 2, 3, 4	19
		Coincident With: Safety Injection	See I and r	tem 1. above fo equirements.	r all Safety Inj .	ection initiating	g functions

SOUTH TEXAS - UNIT 1

3/4 3-23

# ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION

FUN	CTION	<u>AL UNIT</u>	TOTAL NO. <u>Of channels</u>	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
8.	Los	s of Power					
	a.	4.16 kV ESF Bus Under- voltage-Loss of Voltage	4/bus	2/bus	3/bus	1, 2, 3, 4	20
	b.	4.16 kV ESF Bus Under- voltage-Tolerable Degraded Voltage Coincident with SI	4/bus	2/bus	3/bus	1, 2, 3, 4	20
	C.	4.16 kV ESF Bus Under- voltage - Sustained Degraded Voltage	4/bus	2/bus	3/bus	1, 2, 3, 4	20
9.	Engi Actu	ineered Safety Features Jation System Interlocks					
	a.	Pressurizer Pressure, P-11	3	2	2	1, 2, 3	21
	b.	Low-Low T <sub>avg</sub> , P-12	4	2	3	1, 2, 3	21
	c.	Reactor Trip, P-4	2	1	2	1, 2, 3	23

. |

.

# ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION

FUNC	CTION/	AL UNIT	TOTAL NO. Of Channels	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	, <u>ACTION</u>
10.	Cont	trol Room Ventilation					
	a.	Manual Initiation	3(1/train)	2(1/train)	3(1/train)	A11	27
	b.	Safety Injection	See Item 1. a functions and	above for all S d requirements.	afety Injection	initiating	
	c.	Automatic Actuation Logi and Actuation Relays	c 3	2	3	A11	27
	d.	Control Room Intake Air Radioactivity - High	2	1	2	A11	28
	e.	Loss of Power	See Item 8. a and requireme	above fo <mark>r all L</mark> ents.	oss of Power ini	tiating function	5
11.	FHB	HVAC					
	a.	Manual Initiation	3(1/train)	2(1/train)	3(1/train)	1, 2, 3, 4 or with irradiated fuel in spent fuel pool	29, 30 1
	b.	Automatic Actuation Logic and Actuation Relays	3	2	3	1, 2, 3, 4 or with irradi- ated fuel in spent fuel pool	29, 30
	c.	Safety Injection	See Item 1. a functions and	above for all S d requirements.	afety Injection	initiating	
	d.	Spent Fuel Pool Exhaust Radioactivity - High	2	1	2	With irradi- ated fuel in spent fuel pool	30

3/4 3-25

#### TABLE NOTATIONS

\*\*Feedwater Isolation only.

- \*\*\*Function is actuated by either actuation train A or actuation train B. Actuation train C is not used for this function.
- \*\*\*\*Automatic switchover to containment sump is accomplished for each train using the corresponding RWST level transmitter.
  - #Trip function may be blocked in this MODE below the P-11 (Pressurizer Pressure Interlock) Setpoint.
  - ##During CORE ALTERATIONS or movement of irradiated fuel within containment.
- ###Trip function automatically blocked above P-11 and may be blocked below P-11 when Low Compensated Steamline Pressure Protection is not blocked.

## ACTION STATEMENTS

- ACTION 14 With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, be in at least HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours; however, one channel may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.2.1, provided the other channel is OPERABLE.
- ACTION 15 With the number of OPERABLE channels one less than the Total Number of Channels, operation may proceed until performance of the next required ANALOG CHANNEL OPERATIONAL TEST provided the inoperable channel is placed in the tripped condition within 1 hour.
- ACTION 16 (Not Used)
- ACTION 17 With the number of OPERABLE channels one less than the Total Number of Channels, operation may proceed provided the inoperable channel is placed in the bypassed condition and the Minimum Channels OPERABLE requirement is met. One additional channel may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.2.1.
- ACTION 18 With less than the Minimum Channels OPERABLE requirement, operation may continue provided the containment purge supply and exhaust valves are maintained closed.

SOUTH TEXAS - UNIT 1

3/4 3-26

Amendment No. 1

SOUTH			ENGINEERED SAFETY FEATU	TABLE 3. RES ACTUATION SYS	<u>3-4</u>	NTATION TRIP SETPOI	NTS		
i texas	FUNC	CTION/	AL UNIT	TOTAL ALLOWANCE (TA)	<u>Z</u>	SENSOR ERROR (S)	TRIP SETPOINT	ALLOWABLE	VALUE
- UNIT 1	<b>1.</b>	Safe Feed Room Star Conf Esse	ety Injection (Reactor Trip, dwater Isolation, Control n Emergency Ventilation, Start ndby Diesel Generators, Reactor tainment Fan Coolers, and ential Cooling Water)				· · · · · · · · · · · · · · · · · · ·		ζ.
		a.	Manual Initiation	N.A.	N.A.	N.A.	N.A.	N.A.	
		b.	Automatic Actuation Logic	N.A.	N. A.	N.A.	N.A.	N.A.	
3/4		c.	Actuation Relays	N.A.	N.A.	N.A.	N.A.	N.A.	
3-2		d.	Containment PressureHigh 1	3.6	0.71	2.0	≤ 3.0 psig	<b>≤ 4.0 psi</b> g	
9		е.	Pressurizer PressureLow	13.1	10.71	2.0	<u>&gt;</u> 1850 psig##	<u>&gt;</u> 1842 psi	g##
		f.	Compensated Steam Line Pressure-Low	13.6	10.71	2.0	≥ 735 psig	<u>≥</u> 714.7 ps	ig*
	2.	Cont	tainment Spray						
		a.	Manual Initiation	N.A.	N.A.	N.A.	N.A.	N.A.	Ć
Ą		b.	Automatic Actuation Logic	N.A.	N. A.	N.A.	N.A.	N.A.	
nendr		c.	Actuation Relays	N.A.	N.A.	N.A.	N.A.	N.A.	
nent		d.	Containment PressureHigh-3	3.6	0.71	2.0	<u>&lt;</u> 9.5 psig	≤ 10.5 psi/	g

• ]

.

۰.

No. 1

S					TABLE 3.3-4	(Continued)					
ŪΤΗ				ENGINEERED SAFETY FEAT	URES ACTUATION S	YSTEM INSTRUMENT	ATION TRIP SETPO	INTS			
TEXAS	FUNC	TIONA	L UN	IIT	TOTAL ALLOWANCE (TA)	<u>Z</u>	SENSOR ERROR (S)	TRIP SEIPOINT	ALLOWABLE VAL	UE	
ċ	3.	Conta	ainm	ent Isolation				,			
TIN		a.	Pha	se "A" Isolation							
			1)	Manual Initiation	N.A.	N.A.	N.A.	N.A.	N.A.		
			2)	Automatic Actuation Logic	N.A.	N.A.	N.A.	N.A.	N.A.	í	
			3)	Actuation Relays	N.A.	N.A.	N.A.	N.A.	N.A.		
			4)	Safety Injection	See Item 1. abo Values.	ve for all Safet	y Injection Trip	Setpoints and A	llowable		
3/4 3.		b.	Con	tainment Ventilation Isola	tion						
			1)	Automatic Actuation Logic	N.A.	N.A.	N.A.	N.A.	N.A.		
-30			2)	Actuation Relays	N.A.	N.A.	N.A.	N.A.	N.A.		
			3)	Safety Injection	See Item 1. abo Values.	ve for all Safet	y Injection Trip	Setpoints and A	llowable		
			4)	RCB Purge Radioactivity~High	3.1x10 <sup>-4</sup> µCi/cc	1.8x10 <sup>-4</sup> μCi/cc	1.3x10 <sup>-4</sup> µCi/cc	≤5x10-4 <i>###</i> µCi/cc	<6.4x10-⁴ µCi/cc		
			5)	Containment Spray - Manual Initiation	/ - See Item 2. above for Containment Spray manual initiation Trip Setpoints and Allowable Values						
			6)	Phase "A" Isolation - Manual Initiation	See Item 3.a. a Trip Setpoints a	bove for Phase "/ and Allowable Va	A" Isolation manu lues.	ual initiation		ť	
		с.	Pha	se "B" Isolation							
			1)	Automatic Actuation Logic	N.A.	N.A.	N.A.	N.A.	N.A.		
			2)	Actuation Relays	N.A.	N.A.	N.A.	N.A.	N.A.		
			3)	Containment Pressure High-3	3.6	0.71	2.0	<u>≤</u> 9.5 psig	≤ 10.5 psig		
			4)	Containment Spray- Manual Initiation	See Item 2. above Setpoints and A	ve for Containmer llowable Values.	nt Spray manual i	initiation Trip			

.

LNOS				TABLE 3.3-4	(Continued)			
H			ENGINEERED SAFETY FE	ATURES ACTUATION S	SYSTEM INSTR	UMENTATION TRIP SETP	OINTS	
'EXAS	FUNC	TIONA	LUNIT	TOTAL Allowance (ta)	<u>Z</u>	SENSOR ERROR (S)	TRIP SETPOINT	ALLOWABLE VALUE
- ⊆	4.	Stea	n Line Isolation				ţ	
NIT		a.	Manual Initiation	N.A.	N.A.	N.A.	N.A.	N.A.
⊢		b.	Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	N.A.	N.A.	N.A. (
		C.	Steam Line Pressure - Negative RateHigh	2.6	0.5	0	≤ 100 psi	≤ 126.3 psi**
3/1		d.	Containment Pressure - High-2	3.6	0.71	2.0	≤ 3.0 psig	≤ 4.0 psig
4 3-31		e.	Compensated Steam Line Pressure - Low	13.6	10.71	2.0	≥ 735 psig	<u>&gt;</u> 714.7 psig*
	5.	Turb Isol	ine Trip and Feedwater ation					
		a.	Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	N.A.	N.A.	N.A.
Amendr		b.	Steam Generator Water LevelHigh-High (P-14)	· <b>4.5</b>	2.35	2.0+0.2#	< 87.5% of narrow range instrument span.	<pre>&lt; 88.9% of narrow range instrument span.</pre>
nent		c.	Deleted					

. |

Ţ.

۰.

•

nent No.1

SO				TABLE 3.3-4	(Continued)			
UTH			ENGINEERED SAFETY FEA	TURES ACTUATION	SYSTEM INSTRUMENT	ATION TRIP SETPO	INTS	
TEXAS	FUNC	TIONA	AL UNIT	TOTAL <u>Allowance (TA)</u>	<u>Z</u>	SENSOR ERROR (S)	TRIP SETPOINT	ALLOWABLE VALUE
- UNIT	5.	Turt Iso]	pine Trip and Feedwater lation (Continued)			,	· ·	
ч		d.	Deleted					
		е.	Safety Injection	See Item 1 aboy Setpoints and A	ve for all Safety Allowable Values.	Injection Trip		
(1)		f.	T <sub>avg</sub> -Low Coincident with Reactor Trip (P-4) (Feedwater Isolation Only)	4.5	1.36	0.8	<u>&gt;</u> 574°F	≥ 571.1°F
/4 3	6.	Auxi	liary Feedwater					
-32		a.	Manual Initiation	N.A.	N. A.	N.A.	N.A.	NA
		b.	Automatic Actuation Logic	N.A.	N. A.	N.A.	N. A.	N Δ
		С.	Actuation Relays	N.A.	N. A.	N.A.	N. A.	N A
		d.	Steam Generator Water LevelLow-Low	15.0	12.75	2.0+0.2#	33.0% of narrow range instrument span.	2 31.5% of narrow range instrument span.
Amen		e.	Safety Injection	See Item 1. abo Setpoints and A	ve for all Safety llowable Values.	/ Injection Trip		

. .

• ]

S				TABLE 3.3-4	(Continued)			
HIOC			ENGINEERED SAFETY FEAT	URES ACTUATION S	YSTEM INSTRUMENT	ATION TRIP SETPO	INTS	
TEXAS -	FUNC	TIONA	L UNIT	TOTAL <u>Allowance (ta)</u>	<u>Z</u>	SENSOR ERROR (S)	TRIP SETPOINT	ALLOWABLE VALUE
S	6.	Auxi	liary Feedwater (Continued)					
		f.	Loss of Power (Motor Driven Pumps Only)	See Item 8. bel Setpoints and A	ow for all Loss llowable Values.	of Power Trip		(
	7.	Auto Cont	matic Switchover to ainment Sump					
		a.	Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	N.A.	N.A.	N.A.
3		b.	RWST LevelLow-Low	5.0	1.21	2.0	<u>&gt;</u> 11%	≥ 9.1%
4 3-33			Safety Injection	See Item 1. abo Values.	ve for all Safet	y Injection Trip	Setpoints and A	llowable
	8.	Loss	of Power					
		a.	4.16 kV ESF Bus Undervoltage (Loss of Voltage)	<b>N.A.</b>	N. A.	N.A.	> 3107 volts with a < 1.75 second time delay.	<pre>&gt; 2979 volts with a &lt; 1.93 second time delay.</pre>
		b.	4.16 kV ESF Bus Undervoltage (Tolerable Degraded Voltage Coincident with SI)	N. A.	N.A.	N.A.	≥ 3835 volts with a < 35 second time delay.	> 3786 volts with a < 39 second time delay.
		C.	4.16 kV ESF Bus Undervoltage (Sustained Degraded Voltage)	N.A.	N. A.	N.A.	> 3835 volts with a < 50 second time delay.	<pre>&gt; 3786 volts with a &lt; 55 second time delay.</pre>
					•			

i i

٠

۰.

•

LNOS	ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS										
TH TEXAS	FUN	CTION	AL UNIT	TOTAL Allowance (TA)	<u>Z</u>	SENSOR ERROR (S)	TRIP SETPOINT	ALLOWABLE VALUE			
NU N	9.	Eng Act	ineered Safety Features uation System Interlocks								
17		a.	Pressurizer Pressure, P-11	N. A.	N. A.	N. A.	<mark>≤ 19</mark> 85 psig	≤ 1993 psig			
		b.	Low-Low T <sub>avg</sub> , P-12	N.A.	N.A.	N.A.	≥ <b>56</b> 3°F	≥ 560.1°F			
		c.	Reactor Trip, P-4	N.A.	N.A.	N.A.	N. A.	N. A.			
	10.	Con	tro] Room Ventilation								
3/1		a.	Manual Initiation	N.A.	N. A.	N. A.	N. A.	N. A.			
<b>4</b> 3-34		b.	Safety Injection	See Item 1. ab Setpoints and	ove for all Sa Allowable Valu	afety Injection Tripues.	Þ				
		c.	Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	N. A.	N.A.	N. A.			
		d.	Control Room Intake Air Radioactivity - High	3.7x10-⁵ µCi/cc	2.2x10-5 µCi/cc	1.6x10- <sup>5</sup> μCi/cc	<6.1x10-5 µCi/cc	<7.8x10-5 µCi/cc			
Amenc		e.	Loss of Power	See Item 8. abo Allowable Value	ove for all Lo es.	ss of Power Trip Se	tpoints and				
lment	11.	FHB	HVAC								
No. 1		a.	Manual Initiation	N.A.	N.A.	N.A.	N. A.	N.A.			

SOUTH TEXAS - UNIT 1

3/4 3-34

• }

Sou			TABLE 3.3-4	(Continued)				
TH		ENGINEERED SAFETY FE	ATURES ACTUATION S	SYSTEM INSTRUM	ENTATION TRIP SETP	OINTS		
TEXAS -	TIONA	AL UNIT	TOTAL Allowance (TA)	<u>Z</u>	SENSOR ERROR (S)	TRIP SETPOINT	ALLOWABLE VA	<u>LUE</u>
<u>ב</u> 11.	FHB	HVAC (Continued)						
17 1	b.	Automatic Actuation Logic and Actuation Relays	N. A.	N.A.	N. A.	N.A.	N.A.	(
	C.	Safety Injection	See Item 1. abo Setpoints and A	ove for all Sa Allowable Valu	ifety Injection Tri Jes.	p		
3/4 3	d.	Spent Fuel Pool Exhuast Radioactivity - High	3.1x10-4 µCi/cc	1.8x10-4 µCi/cc	1.3x10-4 μCi/cc	<5.0x10-⁴ µCi/cc	<6.4x10-⁴ µCi/cc	

. 1

۰.

3-35

## TABLE NOTATIONS

\*Time constants utilized in the lead-lag controller for Steam Line Pressure-Low are  $\tau_1 \ge 50$  seconds and  $\tau_2 \le 5$  seconds. CHANNEL CALIBRATION shall ensure that these time constants are adjusted to these values.

\*\*The time constant utilized in the rate-lag controller for Steam Line Pressure-Negative Rate-High is greater than or equal to 50 seconds. CHANNEL CALIBRATION shall ensure that this time constant is adjusted to this value.

\*\*\*\*Loop design flow = 95,400 gpm

#2.0% span for Steam Generator Level; 0.2% span for Reference Leg RTDs

##Until resolution of the Veritrak transmitter uncertainty issue, the trip setpoint will be set at  $\geq$  1869 psig, with the allowable value at  $\geq$  1861 psig.

###This setpoint value may be increased up to the equivalent limits of Specification 3.11.2.1 in accordance with the methodology and parameters of the ODCM during containment purge or vent for pressure control, ALARA and respirable air quality considerations for personnel entry.

Amendment No. 1

TABL	E	3		3	-5	
			-	-		

# ENGINEERED SAFETY FEATURES RESPONSE TIMES

INI	TATI	ON SIGNAL AND FUNCTION	RESPONSE TIME IN SECONDS
1.	Manı	ual Initiation	
	a.	Safety Injection (ECCS)	N.A.
	b.	Containment Spray	N.A.
*	c.	Phase "A" Isolation	N.A.
	d.	Phase "B" Isolation	N.A.
	e.	Containment Ventilation Isolation	N.A.
	f.	Steam Line Isolation	N.A.
	g.	Feedwater Isolation	N.A.
	h.	Auxiliary Feedwater	N.A.
	i.	Essential Cooling Water	N.A.
	j.	Reactor Containment Fan Coolers	N.A.
	k.	Control Room Ventilation	N.A
	1.	Reactor Trip	N.A
	m.	Start Diesel Generator	N.A.
2.	Con	tainment PressureHigh-1	
	a.	Safety Injection (ECCS)	$\leq 27^{(1)}/12^{(5)}$
		1) Reactor Trip	$\leq 2^{(3)}$
		2) Feedwater Isolation	$\leq 12^{(3)}$
		3) Phase "A" Isolation	$\leq 33^{(1)}/23^{(2)}$
•		<ol> <li>Containment Ventilation Isolation (18-inch lines)</li> </ol>	$\leq 23^{(1)}/13^{(2)}$
		5) Auxiliary Feedwater	<u>&lt;</u> 60
		6) Essential Cooling Water	$\leq 62^{(1)}/52^{(2)}$
		7) Reactor Containment Fan Coolers	$\leq 38^{(1)}/28^{(2)}$
		8) Control Room Ventilation	$\leq 72^{(1)}/62^{(2)}$
		<ol><li>Start Standby Diesel Generators</li></ol>	<u>&lt;</u> 12

SOUTH TEXAS - UNIT 1

.

3/4 3-37

# ENGINEERED SAFETY FEATURES RESPONSE TIMES

INI	TIATI	NG SI	GNAL AND FUNCTION	RESPONSE TIME IN SECONDS
3.	Pre	ssuri	zer PressureLow	ALL ON OL THE IN SECONDS
	a.	Saf	ety Injection (ECCS)	$< 27^{(1)}/12^{(5)}$
		1)	Reactor Trip	< 2(3)
		2)	Feedwater Isolation	$\frac{12^{(3)}}{3}$
		3)	Phase "A" Isolation	$\frac{1}{33}(1)_{/23}(2)$
		4)	Containment Ventilation Isolation	N. A.
		5)	Auxiliary Feedwater	< 60
		6)	Essential Cooling Water	$\overline{\langle 62^{(1)}/52^{(2)}}$
		7)	Reactor Containment Fan Coolers	$< 38^{(1)}/28^{(2)}$
		8)	Control Room Ventilation	$< 72^{(1)}/62^{(2)}$
		9)	Start Standby Diesel Generators	- ≤ 12
4.	Dele	eted		
5.	Comp	ensat	ed Steam Line PressureLow	
	a.	Safe	ty Injection (ECCS)	$(22)(4)_{12}(5)$
		1)	Reactor Trip	< 2(3)
		2)	Feedwater Isolation	$\leq \frac{1}{2}(3)$
		3)	Phase "A" Isolation	$\frac{1}{33}(1)_{/23}(2)$
		4)	Containment Ventilation Isolation	<u> </u>
		5)	Auxiliary Feedwater	< 60
•		6)	Essential Cooling Water	$\leq 62^{(1)}/52^{(2)}$
		7)	Reactor Containment Fan Coolers	$\leq 38^{(1)}/28^{(2)}$

.

-

# ENGINEERED SAFETY FEATURES RESPONSE TIMES

# INITIATING SIGNAL AND FUNCTION

٠

÷ .

# RESPONSE TIME IN SECONDS

5.	Compensated Steam Line PressureLow (Continued	d)
	8) Control Room Ventilation	$\leq 72^{(1)}/62^{(2)}$
	9) Start Diesel Generators	$\frac{\leq 12}{2}$
	b. Steam Line Isolation	$\leq 8^{10}$
6.	Containment PressureHigh-3	
	a. Containment Spray	$\leq 30^{(1)}/20^{(2)}$
	b. Phase "B" Isolation	$\leq 28^{(1)}/18^{(2)}$
7.	Containment PressureHigh-2	
	Steam Line Isolation	$\leq 7^{(3)}$
8.	Steam Line Pressure - Negative RateHigh	
	Steam Line Isolation	N.A.
9.	Steam Generator Water LevelHigh-High	(0)
	a. Turbine Trip	$\leq 3^{(3)}$
	b. Feedwater Isolation	$\leq 12^{(3)}$
10.	Steam Generator Water LevelLow-Low	
	a. Motor-Driven Auxiliary	< 60
	reeuwaler rumps	2 00
	Feedwater Pump	<u>&lt;</u> 60
11.	RWST LevelLow-Low Coincident with Safety Injection	
	Automatic Switchover to Containment Sump	$\leq 32^{(2)}$
12.	Loss of Power	
	a. 4.16 kV ESF Bus Undervoltage (Loss of Voltage)	<u>&lt;</u> 12
	<ul> <li>b. 4.16 kV ESF Bus Undervoltage (Tolerable Degraded Voltage Coincident with Safety Injection)</li> </ul>	<u>&lt;</u> 49

SOUTH TEXAS - UNIT 1

3/4 3-39

# ENGINEERED SAFETY FEATURES RESPONSE TIMES

INIT	IATIN	G SIGNAL AND FUNCTION	RESPONSE TIME IN SECONDS
12.	Loss c.	of Power (Continued) 4.16 kV ESF Bus Undervoltage (Sustained Degraded Voltage)	<u>&lt;</u> 65
13.	RCB	Purge Radioactivity-High	
	a.	Containment Ventilation Isolation (48-inch lines)	< 73 <sup>(2)</sup>
	b.	Containment Ventilation Isolation (18-inch lines)	$\leq 23^{(2)}$
14.	Dele	ted	
15.	Dele	ted	
16.	T <sub>avg</sub>	- Low Coincident with Reactor Trip Feedwater Isolation	N. A.
17.	Cont	rol Room Intake Air Radioactivity - High Control Room Ventilation	< 78 <sup>(2)</sup>
18.	Spen	t Fuel Pool Exhaust Radioactivity - High FHB HVAC Emergency Startup	$\leq 42^{(2)}$

## TABLE NOTATIONS

- (1) Diesel generator starting and sequence loading delays included.
- (2) Diesel generator starting delay not included, sequence loading delay is included. Offsite power available.
- (3) Not dependent upon diesel generator starting or sequence loading delays.
- (4) Diesel generator starting and sequence loading delay included. Low Head Safety Injection pumps <u>not</u> included.
- (5) Diesel generator starting delays <u>not</u> included, sequence loading delay is included. Low Head Safety Injection pumps <u>not</u> included.

OS				-	TABLE 4.3-2					
JTH			ENGINEERED	SAFETY FEATUR	ES ACTUATION	SYSTEM INSTRU	MENTATION			
TEX/				SURVEIL	LANCE REQUIRE	MENTS			1	
AS - UNIT 1	FUNC	CHANNEL TIONAL UNIT	CHANNEL CHECK	CHANNEL CALIBRATION	DIGITAL OR ANALOG CHANNEL OPERATIONAL TEST	TRIP ACTUATING DEVICE OPERATIONAL TEST	ACTUATION LOGIC TEST	MASTER RELAY TEST	SLAVE RELAY TEST	MODES FOR WHICH SURVEILLAN IS REQUIRE
ω	1. S T C V D C a	afety Injection (Reac rip, Feedwater Isolat ontrol Room Emergency entilation, Start Sta iesel Generators, Rea ontainment Fan Cooler nd Essential Cooling	ctor cion, ndby nctor 's, Water)							
/4 3-	a	. Manual Initiation	N. A.	N.A.	N.A.	R	N.A.	N. A.	N.A.	1, 2, 3, 4
-42	þ	. Automatic Actuation Logic	N. A.	N.A.	N. A.	N.A.	M(1)	N.A.	N.A.	1, 2, 3, 4
	С	. Actuation Relays	N.A.	N.A.	N.A.	N.A.	N. A.	M(6)	Q(4,5)	1, 2, 3, 4
	đ	. Containment Pressur High-1	e- S	R	м	N.A.	N.A.	N. A.	N. A.	1, 2, 3, 4
Amendm	e	. Pressurizer Pressur Low	<b>e-</b> S	R	м	N.A.	N. A.	N.A.	N. A.	1, 2, 3
ent No. <sup>1</sup>	f.	Compensated Steam L Pressure-Low	ine S	R	М	N. A.	N.A.	N. A.	N. A.	1, 2, 3

TABLE 4.3-2

••

. ·

. .

)					TABLE 4.3	-2 (Continued	<u>)</u>					•
1			ENGIN	IEERED SAF	ETY FEATURES SURVEILLAN	ACTUATION SYS	TEM INSTRUMEN	TATION				
	<u>[</u>	FUN	CHANNEL CTIONAL UNIT	CHANNEL CHECK	CHANNEL CALIBRATION	DIGITAL OR ANALOG CHANNEL OPERATIONAL TEST	TRIP ACTUATING DEVICE OPERATIONAL TEST	ACTUATION LOGIC TEST	MASTER RELAY TEST	SLAVE RELAY TEST	MODES FOR WHICH SURVEILLANCE IS REQUIRED	
4	4.	St	eam Line Isolation		_							Ċ
		e.	Compensated Steam Line Pressure-Low	5	R	M	N.A.	N.A.	N.A.	N.A.	1, 2, 3	`.
	5.	Tu Is	rbine Trip and Feedwater olation									·
נ ג'ו		a.	Automatic Actuation Logic and Actuation Relays	N. A.	N.A.	N.A.	<b>N.A.</b>	M(1)	M(6)	Q(4)	1, 2, 3	
n		b.	Steam Generator Water Level-High-High (P-14)	S	R	м	N.A.	N.A.	N.A.	N.A.	1, 2, 3	
		c.	Deleted									1
		d.	Deleted									
		e.	Safety Injection	See Item	1. above for	all Safety I	njection Surv	eillance Reo	uirement	¢		(
Amendmer		f.	T <sub>avg</sub> -Low Coincident with Reactor Trip (P-4) (Feedwater Isolation Only)	S	R	M	N. A.	N.A.	N.A.	N. A.	1, 2, 3	
+												

. }

i

.

SOUTH TEXAS - UNIT 1

3/4 3-45

Amendment No. 1

SOUT			TABLE 4.	3-2 (Continue	<u>d)</u>				
H TEXA	ENG	INEERED SA	FETY FEATURES SURVEILLA	ACTUATION SY NCE REQUIREME	STEM INSTRUME NTS	NTATION			
S - UNIT 1	CHANNEL FUNCTIONAL UNIT 6. Auxiliary Feedwater	CHANNEL CHECK	CHANNEL CALIBRATION	DIGITAL OR ANALOG CHANNEL OPERATIONAL TEST	TRIP ACTUATING DEVICE OPERATIONAL TEST	ACTUATION LOGIC TEST	MASTER RELAY TEST	SLAVE RELAY TEST	MODES FOR WHICH SURVEILLANCE IS REQUIRED
	a. Manual Initiation b. Automatic Actuation Logic	N. A. N. A.	N.A. N.A.	N.A. N.A.	R N.A.	N.A. M(1)	N. A. N. A.	N.A. N.A.	1, 2, 3 1, 2, 3
3/4 3-4	c. Actuation Relays d. Steam Generator Water LevelLow-Low	N.A. S	N.A. R	N.A. M	N.A. N.A.	N.A. N.A.	M(6) N.A	Q N. A	1, 2, 3 1, 2, 3
46	e. Safety Injection f. Loss of Power 7. Automatic Switchover to	See Item See Item	1. above for 8. below for	all Safety I all Loss of I	njection Surve Power Surveill	eillance Requ lance Require	⊔irements ≥ments.	i.	, , ,
	Containment Sump								
	a. Automatic Actuation Logic and Actuation Relays	N. A.	N.Ą.	N.A.	N.A.	M(6)	<b>M</b> (6)	Q	1, 2, 3, 4
	b. RWST LevelLow-Low	S	R	M	N. A.	N.A.	N.A.	N.A	1, 2, 3, 4
	Safety Injection	See Item	l. above for	all Safety In	jection Surve	illance Recu	inomente		,, _, ,
8	3. Loss of Power				· · · · ·	er anee kequ	rements.		
	a. 4.16 kV ESF Bus Undervoltage (Loss of Voltage)	N. A.	R I	N.A J	1 N	1.A. N	I.A. N	.A. 1	, 2, 3, 4
					1				

.

so			TABLE 4.3	-2 (Continued	2					
UTH	ENG	INEERED SAF	ETY FEATURES	ACTUATION SYS	TEM INSTRUMEN	TATION				
ΤE			SURVEILLAN	CE REQUIREMEN	15					
KAS - UN		CHANNEL	CHANNEL	DIGITAL OR ANALOG CHANNEL OBERATIONAL	TRIP ACTUATING DEVICE OPERATIONAL	ΔΟΤΠΑΤΙΟΝ	MASTER	SLAVE RELAY	MODES FOR WHICH SURVETLLANCE	
Н	FUNCTIONAL UNIT	CHECK	CALIBRATION	TEST	TEST	LOGIC TEST	TEST	TEST	IS REQUIRED	
-4	8. Loss of Power (Continued)								(	с. К.
	b. 4.16 kV ESF Bus Undervoltage (Tolerabl Degraded Voltage Coincident with SI)	N.A. e	R	N.A.	M	N.A.	N.A.	N.A.	1, 2, 3, 4	
3/4 3-4	c. 4.16 kV ESF Bus Undervoltage (Sustaine Degraded Voltage)	N.A. d	R	N.A.	М	N.A.	N.A.	N.A.	1, 2, 3, 4	
7	9. Engineered Safety Features Actuation System Interlocks									
	a. Pressurizer Pressure, P-11	N.A.	R	M	N.A.	N.A.	N.A.	N. A.	1, 2, 3	(
A	b. Low-Low T <sub>avg</sub> , P-12	N.A.	R	М	N.A.	N.A.	N.A.	N.A.	1, 2, 3	·
mendn	c. Reactor Trip, P-4	N.A.	N.A	N.A.	R	N.A.	N.A.	N.A.	1, 2, 3	
nent	10. Control Room Ventilation	n								
No.	a. Manual Initiation	N.A.	N.A.	N.A.	R	N.A.	N.A.	N.A.	A11	

\_\_\_\_

• }

.

•

١

		ENGI	NEERED SAF	ETY FEATURES SURVETILIAN	ACTUATION SYS	<u>1)</u> STEM_INSTRUMEN ITS	ITATION			
	FUN	CHANNEL CTIONAL UNIT	CHANNEL CHECK	CHANNEL CALIBRATION	DIGITAL ANALOG CHANNEL OPERATIONAL TEST	TRIP ACTUATING DEVICE OPERATIONAL TEST	ACTUATION LOGIC TEST	MASTER RELAY TEST	SLAVE RELAY TEST	MODES FOR WHICH SURVEILLA IS REQUIR
10	. C	ontrol Room Ventilation (	Continued	)						
	b.	Safety Injection	See Item	1. above for	all Safety I	njection Surv	eillance Rec	quirement	.s.	
	C.	Automatic Actuation Logic and Actuation Relays	N. A.	N.A.	N.A.	N.A.	M(6)	N. A.	N.A.	A11
	d.	Control Room Intake Air Radioactivity-High	S	R	M	N. A.	N.A.	N.A.	N.A.	A11
	e.	Loss of Power	See Item	s 8. above fo	r all Loss of	Power Survei	llance Requi	rements.		
11	. F	HB HVAC								
	a.	Manual Initiation	<b>N. A.</b>	N.A.	N. A.	R	N. A.	N. A.	N. A.	1, 2, 3, or with irradiate fuel in t spent fue pool
	b.	Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	N. A.	N.A.	M(6)	N. A.	N. A.	1, 2, 3, 4 or with irradiate fuel in t spent fue pool

• }

So	• TABLE 4.3-2 (Continued)										
HTU		ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION									
TEXAS - UNIT 1	CHANNEL <u>FUNCTIONAL UNIT</u> 11. FHB HVAC (Continued)		CHANNEL <u>Check</u> See Item	CHANNEL CHANNEL CHECK CALIBRATION		CEREQUIREMENTSDIGITAL ORTRIPANALOGACTUATINGCHANNELDEVICEOPERATIONALOPERATIONALTESTTEST		MASTER RELAY TEST	SLAVE RELAY TEST	MODES FOR WHICH SURVEILLANCE IS REQUIRED	: (
	d.	Spent Fuel Pool Exhaust Radio- activity-High	S	R	M	N.A.	N.A.	N.A.	N. A.	With irradiated fuel in spent fuel	
3/										pool.	
4 3-40	TABLE NOTATION										
•	(1)	i) Each train shall be tested at least every 62 days on a STAGGERED TEST BASIS.									
(2) Deleted											
	(3)	) Deleted									
(4) Except relays K807, K814, K829 (Train B only), K831, K845, K852 and K854 (Trains B and C only) which shall be tested at least once per 18 months during refueling and during each COLD SHUTDOWN exceeding 24 hours unless they have been tested within the previous 92 days.											(
Amen	(5) Except relay K815 which shall be tested at indicated interval only when reactor coolant pressure is above 700 psig.										
ıdment	(6)	Each actuation train shall be tested at least every 92 days on a STAGGERED TEST BASIS. Testing of each actuation train shall include master relay testing of both logic trains. If an ESFAS instru-									

mentation channel is inoperable due to failure of the Actuation Logic Test and/or Master Relay Test, increase the surveillance frequency such that each train is tested at least every 62 days on a STAGGERED TEST BASIS unless the failure can be determined by performance of an engineering evaluation to be a single random failure.

\*During CORE ALTERATIONS or movement of irradiated fuel within containment.

No.

**....** 

# 3/4.3.3 MONITORING INSTRUMENTATION

# RADIATION MONITORING FOR PLANT OPERATIONS

## LIMITING CONDITION FOR OPERATION

3.3.3.1 The radiation monitoring instrumentation channels for plant operations shown in Table 3.3-6 shall be OPERABLE with their Alarm/Trip Setpoints within the specified limits.

APPLICABILITY: As shown in Table 3.3-6.

#### ACTION:

.

- a. With a radiation monitoring channel Alarm/Trip Setpoint for plant operations exceeding the value shown in Table 3.3-6, adjust the Setpoint to within the limit within 4 hours or declare the channel inoperable.
- c. The provisions of Specification 3.0.3 are not applicable.

#### SURVEILLANCE REQUIREMENTS

4.3.3.1 Each radiation monitoring instrumentation channel for plant operations shall be demonstrated OPERABLE by the performance of the CHANNEL CHECK, CHANNEL CALIBRATION and DIGITAL CHANNEL OPERATIONAL TEST for the MODES and at the frequencies shown in Table 4.3-3.

BASES

# REACTOR TRIP SYSTEM and ENGINEERED SAFETY FEATURES ACTUATION SYSTEMINSTRUMENTATION (Continued)The Engineered Safety Features Actuation System interlocks perform thefollowing functions:P-4P-4Reactor tripped - Actuates Turbine trip via P-16, closes main feed-<br/>water valves on Tavg below Setpoint, prevents the opening of the<br/>main feedwater valves which were closed by a Safety Injection or High<br/>Steam Generator Water Level, allows Safety Injection block so that<br/>components can be reset or tripped.<br/>Reactor not tripped - prevents manual block of Safety Injection.

- P-11 On increasing pressurizer pressure, P-11 automatically reinstates Safety Injection actuation on low pressurizer pressure or Low Compensated Steamline Pressure signals, reinstates steam line isolation on Low Compensated Steamline Pressure signals, and opens the accumulator discharge isolation valves. On decreasing pressure, P-11 allows the manual block of Safety Injection actuation on low pressurizer pressure or Low Compensated Steamline Pressure signals, allows the manual block of steamline isolation on Low Compensated Steamline Pressure signals, and enables steam line isolation on high negative steam line pressure rate.
- P-12 On increasing reactor coolant loop temperature, P-12 automatically provides an arming signal to the Steam Dump System. On decreasing reactor coolant loop temperature, P-12 automatically removes the arming signal from the Steam Dump System.
- P-14 On increasing steam generator water level, P-14 automatically trips the turbine and the main feedwater pumps, and closes all feedwater isolation valves and feedwater control valves.

## 3/4.3.3 MONITORING INSTRUMENTATION

#### 3/4.3.3.1 RADIATION MONITORING FOR PLANT OPERATIONS

The OPERABILITY of the radiation monitoring instrumentation for plant operations ensures that: (1) the associated action will be initiated when the radiation level monitored by each channel or combination thereof reaches its Setpoint, (2) the specified coincidence logic is maintained, and (3) sufficient redundancy is maintained to permit a channel to be out of service for testing or maintenance. The radiation monitors for plant operations sense radiation levels in selected plant systems and locations and determine whether or not predetermined limits are being exceeded. If they are, the signals are combined into logic matrices sensitive to combinations indicative of various accidents and abnormal conditions. Once the required logic combination is completed, the system sends actuation signals to initiate alarms or automatic isolation action and actuation of Emergency Exhaust or Ventilation Systems.

SOUTH TEXAS - UNIT 1

B 3/4 3-3

Amendment No. 1

## BASES

## 3/4.3.3.2 MOVABLE INCORE DETECTORS

The OPERABILITY of the movable incore detectors with the specified minimum complement of equipment ensures that the measurements obtained from use of this system accurately represent the spatial neutron flux distribution of the core. The OPERABILITY of this system is demonstrated by irradiating each detector used and determining the acceptability of its voltage curve.

For the purpose of measuring  $F_Q(Z)$  or  $F_{\Delta H}^N$  a full incore flux map is used. Quarter-core flux maps, as defined in WCAP-8648, June 1976, may be used in recalibration of the Excore Neutron Flux Detection System, and full incore flux maps or symmetric incore thimbles may be used for monitoring the QUADRANT POWER TILT RATIO when one Power Range channel is inoperable.

#### 3/4.3.3.3 SEISMIC INSTRUMENTATION

The OPERABILITY of the seismic instrumentation ensures that sufficient capability is available to promptly determine the magnitude of a seismic event and evaluate the response of those features important to safety. This capability is required to permit comparison of the measured response to that used in the design basis for the facility to determine if plant shutdown is required pursuant to Appendix A of 10 CFR Part 100. The instrumentation is consistent with the recommendations of Regulatory Guide 1.12, "Instrumentation for Earthquakes," April 1974.

#### 3/4.3.3.4 METEOROLOGICAL INSTRUMENTATION

The OPERABILITY of the meteorological instrumentation ensures that sufficient meteorological data are available for estimating potential radiation doses to the public as a result of routine or accidental release of radioactive materials to the atmosphere. This capability is required to evaluate the need for initiating protective measures to protect the health and safety of the public and is consistent with the recommendations of Regulatory Guide 1.23, "Onsite Meteorological Programs," February 1972.

## 3/4.3.3.5 REMOTE SHUTDOWN SYSTEM

The OPERABILITY of the Remote Shutdown System ensures that sufficient capability is available to permit safe shutdown of the facility from locations autside of the control room. This capability is required in the event control room habitability is lost and is consistent with General Design Criterion 19 of 10 CFR Part 50.



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

# RELATED TO AMENDMENT NO. TO

# FACILITY OPERATING LICENSE NO. NPF-76

# HOUSTON LIGHTING & POWER COMPANY

# SOUTH TEXAS PROJECT, UNIT 1

DOCKET NO. 50-498

## 1.0 INTRODUCTION

By letters dated May 23, 1988, Houston Lighting & Power Company, (HL&P, the licensee) requested an amendment to the Technical Specifications (TSs)appended to Facility Operating License No. NPF-76 for South Texas Project, Unit 1 (STP-1). The proposed amendment would delete all references to Excessive Cooldown Protection and associated items. Background information was contained in HL&P letter dated April 18, 1988. Additional information was provided in HL&P letter of May 18, 1988.

## 2.0 DISCUSSION

Excessive cooldown protection, as presently installed on South Texas Project, consists of Safety Injection actuation and steamline isolation from two out of three low-low compensated T-cold signals from any loop with the reactor tripped or below 10% power, feedwater isolation and turbine trip from two out of three low compensated T-cold signals in any loop with reactor tripped or below 10% power or from two out of three high feedwater flow signals in any loop with the reactor tripped or below 10% power, interlocked with two out of four RCS low flow signals or two out of four low T-avg signals.

Excessive cooldown protection was in the original design of South Texas Project to prevent the Reactor from returning critical subsequent to a steam system piping failure or inadvertent opening of steam generator relief or safety valve, or excessive main feedwater addition. South Texas Project has subsequently adopted NRC approved licensing criterion which permits return to criticality following the above mentioned events. The analyses for these events as described in Chapter 15 of the FSAR shows the possibility of return to criticality following these events. Two portions of the original excessive cooldown protection, emergency boration system and main steam isolation on any safety injection, were deleted prior to issuance of the operating license for South Texas Project, Unit 1.

8804020259 880524 PDR ADDCK 05000498 PDR PDR On March 30, 1988, STP-1 experienced a loss of offsite power, a reactor trip, and safety injection event. In reviewing the event, the licensee determined that the Low-Low Compensated T-Cold Excessive Cooldown Protection circuitry will initiate a safety injection actuation if charging flow is maintained after the Reactor Coolant Pumps stop or trip. This condition is unique to the STP design as a result of the inclusion of excessive cooldown protection circuitry. This condition is considered to be undesirable since it results in unwarranted cycling of safeguards equipment and complicates the response to less significant events. The licensee concludes that anytime the Reactor Coolant Pumps are stopped while charging flow is maintained, a safety injection actuation will occur due to excessive cooldown protection.

Not only is this an undesirable situation during normal operation but, the condition creates a special problem for conducting two required tests; the shutdown from outside the Control Room test, and the loss of offsite power (LOOP) test. During both of these tests, the conditions will be present in which the excessive cooldown protection can be expected to cause a safety injection (SI) actuation. Conducting the tests with the excessive cooldown protection in place will cause the operators to mitigate a safety injection as part of the tests. This is beyond the scope of the tests and significantly complicates plant response.

#### 3.0 EVALUATION

The staff has reviewed the licensee's evaluation of removal of the excessive cooldown protection on the appropriate accident analyses.

3.1 <u>Inadvertent Opening of a Steam Generator Relief or Safety Valve</u> causing a Depressurization of the Main Steam System (FSAR Chapter 15.1.4)

Although safety injection will no longer actuate from two out of three low-low compensated T-cold in any loop, it will actuate from two out of three low compensated steamline pressure signals from any loop or from two out of four low pressurizer pressure signals. In addition, redundant action will close the main feedwater valves following a reactor trip and a Safety Injection signal will rapidly close all feedwater control valves and feedwater isolation valves and trip the main feedwater pumps. Closure of the fast-acting main steam isolation valves (MSIVs) will be accomplished from either low compensated steamline pressure above the P-11 setpoint, or from high negative steamline pressure rate signal below the P-11 setpoint. The original analyses for these events show that safety injection is initiated by low pressurizer pressure. No credit is taken in the original analysis for mitigation from the excessive cooldown protection.

3.2

Steam System Piping Failures Inside Or Outside Containment (FSAR Chapter 15.1.5)

Although Safety Injection will no longer actuate from two out of three low-low compensated T-cold in any loop, it will actuate from 2 out of 3 low compensated steamline pressure signals from any loop, from two out of four low pressurizer pressure signals, or from two out of three high containment pressure signals. In addition, redundant isolation of the main feedwater flow is provided, in that normal control action will close the main feedwater valves following a reactor trip and a Safety Injection signal will rapidly close all feedwater control valves and feedwater isolation valves and trip the main feedwater pumps. Closure of the fast-acting main steam isolation valves (MSIVs) will be accomplished from either low compensated steamline pressure above the P-11 setpoint, from high negative steamline pressure rate signal below the P-11 setpoint, or from two out of three High-2 containment pressure signals. The original analyses for these events show that safety injection is initiated by low steam line pressure. No credit is taken in the original analysis for mitigation from the excessive cooldown protection.

## 3.3 <u>Mass and Energy Release for Postulated Secondary System Pipe Ruptures</u> Inside the Containment

No credit was taken in the original analysis for mitigation of the consequences from actuation of excessive cooldown protection.

The deletion of excessive cooldown protection (which results in a protection system functionally equivalent to RESAR 3S Protection Systems) does not have any effect upon the probability of occurrence of a malfunction of equipment important to safety in that the only physical changes on equipment important to safety is the deletion of the actuation signals from the protection system. The reduction in unnecessary cycling of Engineered Safeguards Equipment will have a positive effect upon reducing the potential of malfunction of equipment important to safety.

#### 3.4 Implementation of Circuitry Changes

During a meeting on May 6, 1988, the licensee proposed that the simplest method to delete the Excessive Cooldown Protection is by cutting the signal wires from the Process Instrument Cabinet to the ESFAS Cabinet. All of the logic circuit boards within the ESFAS cabinet will not be replaced until the first refueling. All the surveillance test provision will not be changed except the monthly analog Channel functional test procedure will be modified to indicate the disconnection between the process instrument cabinet and the ESFAS Cabinet. The T-cold analog signal which provides monitoring function will be maintained. The intertie between the process instrument cabinet and the ESFAS Cabinet is the relay to contact connection. Cutting signal wires will not affect the logic circuit operation inside the ESFAS Cabinet. Any malfunction within the ESFAS Cabinet still can be detected by the surveillance test provision. No jumpers or lifting leads are required to accomplish this modification. Therefore, the staff finds that the proposed circuitry changes are acceptable.

#### 4.0 EMERGENCY CIRCUMSTANCES

After the March 30, 1988 event, an analysis determined the root cause. The licensee then directed the vendor, Westinghouse, to consider the options and propose a solution. This required a review of the original design basis for the excessive cooldown actuation circuitry and the impact of its removal on the FSAR analyses. Westinghouse completed its review and made a recommendation on May 14, 1988. The licensee expedited the TS change request review through both the Plant Operations Review Committee and the Nuclear Safety Review Board. Approval of the TS change is needed in order to avoid a delay in the plant testing and startup. The affected power ascension tests, LOOP and shutdown cutside the control room are scheduled to begin by midnight, May 24, 1988 with the reactor at 30% power. Attempting to conduct the tests prior to the removal of the excessive cooldown protection is expected to result in SI actuation which will complicate the conductance of the tests, may obscure some of the results. The SI actuation will cause an additional challenge to the system and an additional transient on the plant. Using the normal procedures for processing the TS change will result in a delay in the startup schedule.

# 5.0 NO SIGNIFICANT HAZARDS CONSIDERATION

The Commission's regulations in 10 CFR 50.92 state that the Commission may make a final determination that a license amendment involves no significant hazards consideration if the operation of the facility in accordance with the amendment would not:

- (1) Involve a significant increase in the probability or consequences of an accident previously evaluated; or
- (2) Create the possibility of a new or different kind of accident from any accident previously evaluated; or
- (3) Involve a significant reduction in a margin of safety.

• The evaluation in Section 3.0 shows that deletion of the excessive cooldown protection will have no effect on the probability and no significant effect on the consequences of any of the accidents previously evaluated. The proposed change does not create a possibility of a new or different accident, and does not affect any margins of safety.

Based on the above evaluation, the staff concludes that operation of the facility in the proposed manner would not involve a significant increase in the probability or consequences of an accident previously evaluated, would not create the possibility of a new or different kind of accident from any accident previously evaluated, and would not involve a significant reduction in a margin of safety.

Accordingly, we conclude the amendment involves no significant hazards consideration.

6.0 STATE CONSULTATION

In accordance with the Commission's regulations, consultation was held with the State of Texas by telephone. The State expressed no concern from both the standpoint of safety and the standpoint of the no significant hazards consideration determination.

## 7.0 ENVIRONMENTAL CONSIDERATION

The amendment involves a deletion of the excessive cooldown protection circuitry. The staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposures. The Commission has made a final no significant hazards consideration finding with respect to this amendment. Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR Section 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

#### 8.0 CONCLUSION

The staff has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations, and the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Dated: May 24, 1988

Principal Contributors: H. Balukjian, H. Li