



A Subsidiary of RGS Energy Group, Inc.

ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001 • 716 546-2700

www.rge.com

ROBERT C. MECREDDY
Vice President
Nuclear Operations

April 26, 2002

U.S. Nuclear Regulatory Commission
Document Control Desk
Attn: Robert Clark
Project Directorate I
Washington, D.C. 20555

Subject: 10CFR50.46 Annual ECCS Report
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

Ref. (a) Westinghouse Letter RGE-02-002, Subject: 10CFR50.46 Annual
Notification and Reporting for 2001, dated March 1, 2002.

Dear Mr. Clark

In accordance with the requirements in 10CFR50.46 paragraph (a)(3)(ii), this annual ECCS report is hereby submitted.

Westinghouse, the provider of LOCA analysis for the R. E. Ginna Nuclear Power Plant, has provided RG&E with an update to the peak cladding temperature (PCT) margin for Ginna Station (Reference a).

The large break LOCA PCT has increased 13°F from the value previously reported due to an oxidation thickness input error (+15°F) and the removal of reconstituted fuel assemblies from Cycle 30 (-2°F). The new large break LOCA PCT is 2166°F and is summarized in Attachment 1 to this letter.

The small break LOCA PCT has not changed since the last report (Reference a). The small break LOCA PCT remains at 1346°F and is summarized in Attachment 1 to this letter.

Very truly yours,


Robert C. Mecreddy

1000463

A001

Attachment

cc: Mr. Robert Clark (Mail Stop O-8-C2)
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Rockville, MD 20852

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

U.S. NRC Ginna Senior Resident Inspector

ATTACHMENT I
LOCA PCT SUMMARY
APRIL 2002 UPDATE

ATTACHMENT I

LOCA PT SUMMARY

Large Break LOCA
 R.E. Ginna Nuclear Power Plant
 Rochester Gas and Electric Corporation

Evaluation Model: UPI SECY Fuel: OFA
 $F_Q = 2.45$ $F_{\Delta H} = 1.75$ SGTP = 15%

- | | | |
|----|---|-----------------------|
| A. | Analysis of Record (5/95) (effective 6/96) | PCT = 2051° F |
| B. | 1995 10CFR50.46 Model Assessments
1. Fixed heat transfer node assignment
Error/Accumulator water injection error | Δ PCT = 48° F |
| C. | 1996 10CFR50.46 Model Assessments
1. None | Δ PCT = 0° F |
| D. | 1997 10CFR50.46 Model Assessment
1. Accumulator Initial Water Volume
Restart Data Transportation Error
Plant Specific Analytical Reassessment
of 1995 Model Assessments
2. Accumulator Initial Water
Vol. = 1125 ft ³
3. 1-D Transition Boiling Heat Transfer Error
4. Vessel Channel DX Error
5. Input Consistency | Δ PCT = -41° F |
| E. | 1998 10CFR50.46 Model Assessments
1. None | Δ PCT = 0° F |
| F. | 1999 10CFR50.46 Model Assessments
1. None | Δ PCT = 0° F |
| G. | 2000 10CFR50.46 Model Assessments
1. 100 psig IFBA RIP Modeling Error
2. Channel Splitting Error | Δ PCT = 52° F |
| H. | 2001 10CFR50.46 Model Assessments
1. Oxidation Thickness Input Error | Δ PCT = 15° F |
| I. | Ginna Evaluations
1. Service Water Temp. $\geq 30^\circ$
(1997 evaluation; SEV-1090) | Δ PCT = 1° F |
| J. | Other Margin Allocations
1. None | Δ PCT = 0° F |

Licensing Basis

PCT = 2166° F
 Revision Date: 4/2002

ATTACHMENT I

LOCA PT SUMMARY

Small Break LOCA
R.E. Ginna Nuclear Power Plant
Rochester Gas and Electric Corporation

Evaluation Model: NOTRUMP Fuel: OFA
 $F_Q = 2.50$ $F_{\Delta H} = 1.75$ SGTP = 15%

- A. Analysis of Record (6/95) (effective 6/96) Δ PCT = 1308°F
- B. 1995 10CFR50.46 Model Assessments
 - 1. Notrump Specific Enthalpy Error Δ PCT = 20°F
 - 2. SALIBRARY Double Precision Errors Δ PCT = -15°F
- C. 1996 10CFR50.46 Model Assignments
 - 1. SBLOCA Fuel Rod Initialization Error Δ PCT = 10°F
- D. 1997 10CFR50.46 Model Assessment
 - 1. None Δ PCT = 0°F
- E. 1998 10CFR50.46 Model Assessments
 - 1. None Δ PCT = 0°F
- F. 1999 10CFR50.46 Model Assessments
 - 1. None Δ PCT = 0°F
- G. 2000 10CFR50.46 Model Assessments
 - 1. NOTRUMP - Mixture Level Tracking/ Region Depletion Errors Δ PCT = 13°F
- H. 2001 10CFR50.46 Model Assessments
 - 1. None Δ PCT = 0°F
- I. Ginna Evaluations
 - 1. Annular Axial Pellets Δ PCT = 10°F
(1997 evaluation; SEV-1108)
- J. Other Margin Allocations
 - 1. None Δ PCT = 0°F

Licensing Basis

PCT = 1346°F

Revision Date: 4/2002