February 17, 1989

Docket No. 40-498

Mr. J. H. Goldberg Group Vice-President, Nuclear Houston Lighting & Power Company P.O. Box 1700 Houston, Texas 77001

Dear Mr. Goldberg:

SUBJECT: CORRECTION TO AMENDMENT NO. 4 TO FACILITY OPERATING LICENSE NO. NPF-76, SOUTH TEXAS PROJECT, UNIT 1

On December 29, 1988, the Commission issued Amendment No. 4 to Facility Operating License No. NPF-76 for the South Texas Project, Unit 1. The amendment changed the Unit 1 Technical Specifications (TS) to the Combined TS for Units 1 and 2, added a requirement which places the positive displacement pump in a lock-out condition during modes 4, 5 and 6 to prevent cold overpressurization, added a reactor coolant pump seal isolation header pressure interlock and made changes to the administrative section of the TS.

The Combined TS issued with the Unit 2 low power license were complete. However, several TS pages with the vertical lines indicating the Unit 1 changes were inadvertently omitted from the amendment package. The pages are as follows: 2-2, 3/4 1-24, 3/4 2-4, 3/4 8-10, 3/4 8-13, 5-2 and 5-3. These pages are hereby enclosed, are identified by Amendment No. 4 and contain vertical lines indicating the areas of change. The corresponding overleaf pages, some of which were issued with Amendment No. 4, are also provided to maintain document completeness.

Please accept our apology for any inconvenience this error may have caused you.

Sincerely,

151

George F. Dick, Jr., Project Manager Project Directorate - IV, Division of Reactor Projects - III, IV, V and Special Projects Office of Nuclear Reactor Regulation

Enclosures: As stated

cc w/enclosures: See next page

8902280310 890217 PDR ADOCK 05000498 P PDC PDC

DOCUMENT NAME: STP LETTER 2/9 *PREVIOUSLY CONCURRED

 PD4/LA*
 PD4/PE*

 PNoonan
 CAbbate:bj

 02/11/89
 02/13/89

Docket File NRC PDR Local PDR PD4 Reading

DISTRIBUTION:

PNoonan GDick (2) JCalvo OGC-Rockville EJordan

D GDick 02/16 /89 BGrimes TMeek (4) Wanda Jones EButcher ACRS (10) GPA/PA ARM/LFMB DHagan Plant File MJCalvo 02/17/89 Docket No. 40-498

Mr. J. H. Goldberg Group Vice-President, Nuclear Houston Lighting & Power Company P. O. Box 1700 Houston, Texas 77001

Dear Mr. Goldberg:

SUBJECT: CORRECTION TO AMENDMENT NO. 4 TO FACILITY OPERATING LICENSE NO. NPF-76, SOUTH TEXAS PROJECT, UNIT 1

On December 29, 1988, the Commission issued Amendment No. 4 to Facility Operating License No. NPF-76 for the South Texas Project, Unit 1. The amendment changed the Unit 1 Technical Specifications (TS) to the Combined TS for Units 1 and 2, added a requirement which places the positive displacement pump in a lock-out condition during modes 4, 5 and 6 to prevent cold overpressurization, added a reactor coolant pump seal isolation header pressure interlock and made changes to the administrative section of the TS.

In the issuance, several TS pages were inadvertently omitted from the amendment package. The pages are as follows: 2-2, 3/4 1-24, 3/4 2-4, 3/4 8-10, 3/4 8-13, 5-2 and 5-3. These pages are hereby enclosed, are identified by Amendment No. 4 and contain vertical lines indicating the areas of change. The corresponding overleaf pages, some of which were issued with Amendment No. 4, are also provided to maintain document completeness.

Please accept our apology for any inconvenience this error may have caused you.

Sincerely,

George F. Dick, Jr., Project Manager Project Directorate - IV, Division of Reactor Projects - III, IV, V and Special Projects Office of Nuclear Reactor Regulation

Enclosures: As stated

cc w/enclosures: See next page

DISTRIBUTION:	
Docket File	BGrimes
NRC PDR	TMeek (4)
Local PDR	Wanda Jones
PD4 Reading	EButcher
PNoonan	ACRS (10)
GDick (2)	GPA/PA
JCalvo	ARM/LFMB
OGC-Rockville	DHagan
EJordan	Plant File

DOCUMENT NAME: STP LETTER 2/9

PD4/LADA	PD4/PE/MA	PD4/PM	PD4/D
PNoonan	CAbbate:bj	GDick	JCalvo
02/1//89	02/13/89	02/ /89	02/ /89



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555 February 17, 1989

Docket No. 40-498

Mr. J. H. Goldberg Group Vice-President, Nuclear Houston Lighting & Power Company P.O. Box 1700 Houston, Texas 77001

Dear Mr. Goldberg:

SUBJECT: CORRECTION TO AMENDMENT NO. 4 TO FACILITY OPERATING LICENSE NO. NPF-76, SOUTH TEXAS PROJECT, UNIT 1

On December 29, 1988, the Commission issued Amendment No. 4 to Facility Operating License No. NPF-76 for the South Texas Project, Unit 1. The amendment changed the Unit 1 Technical Specifications (TS) to the Combined TS for Units 1 and 2, added a requirement which places the positive displacement pump in a lock-out condition during modes 4, 5 and 6 to prevent cold overpressurization, added a reactor coolant pump seal isolation header pressure interlock and made changes to the administrative section of the TS.

The Combined TS issued with the Unit 2 low power license were complete. However, several TS pages with the vertical lines indicating the Unit 1 changes were inadvertently omitted from the amendment package. The pages are as follows: 2-2, 3/4 1-24, 3/4 2-4, 3/4 8-10, 3/4 8-13, 5-2 and 5-3. These pages are hereby enclosed, are identified by Amendment No. 4 and contain vertical lines indicating the areas of change. The corresponding overleaf pages, some of which were issued with Amendment No. 4, are also provided to maintain document completeness.

Please accept our apology for any inconvenience this error may have caused you.

Sincerely,

Géorge/F. Dick, Jr/, Project Manager Project Directorate - IV, Division of Reactor Projects - III, IV, V and Special Projects Office of Nuclear Reactor Regulation

Enclosures: As stated

cc w/enclosures: See next page Mr. J. H. Goldberg Houston Lighting and Power Company

cc: Brian Berwick, Esq. Assistant Attorney General Environmental Protection Division P. O. Box 12548 Capitol Station Austin, Texas 78711

Mr. J. T. Westermeier General Manager, South Texas Project Houston Lighting and Power Company P. O. Box 289 Houston, Texas 77483

Mr. R. J. Miner Chief Operating Officer City of Austin Electric Utility 721 Barton Springs Road Austin, Texas 78704

Mr. R. J. Costello Mr. M. T. Hardt City Public Service Board P. O. Box 1771 San Antonio, Texas 78296

Jack R. Newman, Esq. Newman & Holtzinger, P. C. 1615 L Street, NW Washington, D.C. 20036

Melbert Schwartz, Jr., Esq. Baker & Botts One Shell Plaza Houston, Texas 77002

Mrs. Peggy Buchorn Executive Director Citizens for Equitable Utilities, Inc. Route 1, Box 1684 Brazoria, Texas 77422

Mr. S. L. Rosen General Manager, Operations Support Houston Lighting and Power Company P. O. Box 289 Wadsworth, Texas 77483 South Texas Project

Resident Inspector/South Texas Project c/o U.S. Nuclear Regulatory Commission P. O. Box 910 Bay City, Texas 77414 Mr. Jonathan Davis Assistant City Attorney City of Austin P. O. Box 1088 Austin, Texas 78767 Ms. Pat Coy Citizens Concerned About Nuclear Power 10 Singleton Eureka Springs, Arkansas 72632 Mr. M. A. McBurnett Manager, Operations Support Licensing Houston Lighting and Power Company P. O. Box 289 Wadsworth, Texas 77483 Mr. A. Zaccaria Mr. K. G. Hess Bechtel Corporation P. O. Box 2166 Houston, Texas 77001 Mr. R. P. Verret Mr. R. L. Range Central Power and Light Company P. O. Box 2121 Corpus Christi, Texas 78403 Doub, Muntzing and Glasgow Attorneys at Law Suite 400 808 Seventeenth Street, N.W. Washington, D.C. 20006

Mr. J. H. Goldberg Houston Lighting & Power - 2 -

cc:

Regional Administrator, Region IV U.S. Nuclear Regulatory Commission Office of Executive Director for Operations 611 Ryan Plaza Drive, Suite 1000 Arlington, Texas 76011

Mr. Lanny Sinkin, Counsel for Intervenor Citizens Concerned about Nuclear Power, Inc. Christic Institute 1324 North Capitol Street Washington, D.C. 20002

Licensing Representative Houston Lighting and Power Company Suite 610 Three Metro Center Bethesda, Maryland 20814

Rufus S. Scott Associate General Counsel Houston Lighting & Power Company P. O. Box 1700 Houston, Texas 77001

INPO

Records Center 1100 Circle 75 Parkway Atlanta, Georgia 30339-3064

Joseph M. Hendrie 50 Bellport Lane Bellport, New York 11713

Gerald E. Vaughn, Vice President Nuclear Operations Houston Lighting & Power Company P. O. Box 289 Wadsworth, Texas 77483

R. W. Chewning, Chairman Nuclear Safety Review Board Houston Lighting & Power Company P. O. Box 289 Wadsworth, Texas 77483

2.0 SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

2.1 SAFETY LIMITS

REACTOR CORE

2.1.1 The combination of THERMAL POWER, pressurizer pressure, and the highest operating loop coolant temperature (T_{avg}) shall not exceed the limits shown in Figure 2.1-1.

APPLICABILITY: MODES 1 and 2.

ACTION:

Whenever the point defined by the combination of the highest operating loop average temperature and THERMAL POWER has exceeded the appropriate pressurizer pressure line, be in HOT STANDBY within 1 hour, and comply with the requirements of Specification 6.7.1.

REACTOR COOLANT SYSTEM PRESSURE

2.1.2 The Reactor Coolant System pressure shall not exceed 2735 psig.

APPLICABILITY: MODES 1, 2, 3, 4, and 5.

ACTION:

MODES 1 and 2:

Whenever the Reactor Coolant System pressure has exceeded 2735 psig, be in HOT STANDBY with the Reactor Coolant System pressure within its limit within 1 hour, and comply with the requirements of Specification 6.7.1.

MODES 3, 4 and 5:

Whenever the Reactor Coolant System pressure has exceeded 2735 psig, reduce the Reactor Coolant System pressure to within its limit within 5 minutes, and comply with the requirements of Specification 6.7.1.

8902280311 890217 PDR ADOCK 05000498 P PDC PDC





REACTOR CORE SAFETY LIMIT - FOUR LOOPS IN OPERATION

SOUTH TEXAS - UNITS 1 & 2

2-2 Unit 1 Amendment No. 4

REACTIVITY CONTROL SYSTEMS

CONTROL ROD INSERTION LIMITS

LIMITING CONDITION FOR OPERATION

3.1.3.6 The control banks shall be limited in physical insertion as shown in Figure 3.1-3.

APPLICABILITY: MODES 1* and 2* **.

ACTION:

•••

With the control banks inserted beyond the above insertion limits, except for surveillance testing pursuant to Specification 4.1.3.1.2:

- a. Restore the control banks to within the limits within 2 hours, or
- b. Reduce THERMAL POWER within 2 hours to less than or equal to that fraction of RATED THERMAL POWER which is allowed by the bank position using the above figure, or
- c. Be in at least HOT STANDBY within 6 hours.

SURVEILLANCE REOUIREMENTS

4.1.3.6 The position of each control bank shall be determined to be within the insertion limits at least once per 12 hours except during time intervals when the rod insertion limit monitor is inoperable, then verify the individual rod positions at least once per 4 hours.

*See Special Test Exceptions Specifications 3.10.2 and 3.10.3. **With K_{eff} greater than or equal to 1.

SOUTH TEXAS - UNITS 1 & 2 3/4 1-23



FIGURE 3.1-3

ROD BANK INSERTION LIMITS VERSUS THERMAL POWER FOUR-LOOP OPERATION

SOUTH TEXAS - UNITS 1 & 2 3/4 1-24

- - :

Unit 1 Amendment No. 4

POWER DISTRIBUTION LIMITS

:

- 2

۰.

SURVEILLANCE REQUIREMENTS (Continued)

pursuant to Specification 4.2.1.3 above or by linear interpolation between the most recently measured value and the predicted value at the end of the cycle life. The provisions of Specification 4.0.4 are not applicable.

SOUTH TEXAS - UNITS 1 & 2 3/4 2-3



FIGURE 3.2-1

AXIAL FLUX DIFFERENCE LIMITS AS A FUNCTION OF RATED THERMAL POWER

SOUTH TEXAS - UNITS 1 & 2

3/4 2-4

Unit 1 Amendment No. 4

A.C. SOURCES

SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.8.1.2 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. One circuit between the offsite transmission network and the Onsite Class 1E Distribution System, and
- b. Two standby diesel generators each with a separate fuel tank containing a minimum volume of 60,500 gallons of fuel.

APPLICABILITY: MODES 5 and 6.

ACTION:

. .

With less than the above minimum required A.C. electrical power sources OPERABLE, immediately suspend all operations involving CORE ALTERATIONS, positive reactivity changes, movement of irradiated fuel, or crane operation with loads over the spent fuel pool, and within 8 hours, depressurize and vent the Reactor Coolant System through a greater than or equal to 2.0 square inch vent. In addition, when in MODE 5 with the reactor coolant loops not filled, or in MODE 6 with the water level less than 23 feet above the reactor vessel flange, immediately initiate corrective action to restore the required sources to OPERABLE status as soon as possible.

SURVEILLANCE REQUIREMENTS

4.8.1.2 The above required A.C. electrical power sources shall be demonstrated OPERABLE by the performance of each of the requirements of Specifications 4.8.1.1.1, 4.8.1.1.2 (except for Specification 4.8.1.1.2a.3)), and 4.8.1.1.3.

SOUTH TEXAS - UNITS 1 & 2

3/4 8-9

3/4.8.2 D.C. SOURCES

OPERATING

LIMITING CONDITION FOR OPERATION

- 3.8.2.1 As a minimum, the following D.C. electrical sources shall be OPERABLE:
 - a. Channel I 125-volt Battery Bank E1A11 (Unit 1), E2A11 (Unit 2) and its two associated chargers,
 - b. Channel II 125-volt Battery Bank E1D11 (Unit 1), E2D11 (Unit 2) and its associated full capacity charger,
 - c. Channel III 125-volt Battery Bank E1B11 (Unit 1), E2B11 (Unit 2) and its associated full capacity charger, and
 - d. Channel IV 125-volt Battery Bank E1C11 (Unit 1), E2C11 (Unit 2) and its two associated chargers.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

- a. With one of the required battery banks, and/or one of the required chargers for the Channels II or III inoperable, restore the inoperable battery bank and/or charger to OPERABLE status within 2 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With only one charger on Channel I or IV OPERABLE, demonstrate the OPERABILITY of the associated battery bank by performing Surveillance Requirement 4.8.2.1.a.1) within 1 hour and at least once per 8 hours thereafter. If any Category A limit in Table 4.8-2 is not met, declare the battery inoperable. Restore the inoperable charger to OPERABLE status within 24 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.8.2.1 Each 125-volt battery bank and charger shall be demonstrated OPERABLE:

- a. At least once per 7 days by verifying that:
 - 1) The parameters in Table 4.8-2 meet the Category A limits, and
 - 2) The total battery terminal voltage is greater than or equal to 129 volts on float charge.

SOUTH TEXAS - UNITS 1 & 2	3/4 8-10	Unit 1	Amendment No. 4
---------------------------	----------	--------	-----------------

D.C. SOURCES

SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.8.2.2 As a minimum, Channel I 125-volt Battery Bank E1All (Unit 1), E2All (Unit 2), and Channel IV 125-volt battery bank E1Cl1 (Unit 1), E2Cl1 (Unit 2), and their two associated chargers shall be OPERABLE.

APPLICABILITY: MODES 5 and 6.

ACTION:

. ÷.

With the required battery banks and/or charger(s) inoperable, immediately suspend all operations involving CORE ALTERATIONS, positive reactivity changes, or movement of irradiated fuel; initiate corrective action to restore the required battery banks and/or chargers to OPERABLE status as soon as possible, and within 8 hours, depressurize and vent the Reactor Coolant System through a 2.0 square inch vent.

SURVEILLANCE REQUIREMENTS

4.8.2.2 The above required 125-volt battery banks and chargers shall be demonstrated OPERABLE in accordance with Specification 4.8.2.1.

.

Unit 1 Amendment No. 4

3/4.8.3 ONSITE POWER DISTRIBUTION

OPERATING

LIMITING CONDITION FOR OPERATION

3.8.3.1 The following electrical busses shall be energized in the specified manner:

- а. Train A A.C. ESF Busses consisting of:
 - 4160-Volt ESF Bus # E1A (Unit 1), E2A (Unit 2), and 1)
 - 480-Volt ESF Busses # E1A1 and E1A2 (Unit 1), E2A1 and E2A2 2) (Unit 2) from respective load center transformers.
- Train B A.C. ESF Busses consisting of: b.
 - 4160-Volt ESF Bus # E1B (Unit 1), E2B (Unit 2), and 1)
 - 480-Volt ESF Busses # E1B1 and E1B2 (Unit 1), E2B1 and E2B2 2) (Unit 2) from respective load center transformers.
- с.
- Train C A.C. ESF Busses consisting of: 1) 4160-Volt ESF Bus # E1C (Unit 1), E2C (Unit 2), and
 - 2) 480-Volt ESF Busses # ElCl and ElC2 (Unit 1), E2Cl and E2C2 (Unit 2) from respective load center transformers.
- d. 120-Volt A.C. Vital Distribution Panels DP1201 and DP001 energized from their associated inverters connected to D.C. Bus # E1A11* (Unit 1), E2A11* (Unit 2).
- 120-Volt A.C. Vital Distribution Panel DP1202 energized from its e. associated inverter connected to D.C. Bus # E1D11* (Unit 1), E2D11* (Unit 2).
- f. 120-Volt A.C. Vital Distribution Panel DP1203 energized from its associated inverter connected to D.C. Bus # E1B11* (Unit 1), E2B11* (Unit 2).
- 120-Volt A.C. Vital Distribution Panels DP1204 and DP002 energized g. from their associated inverters connected to D.C. Bus # E1C11* (Unit 1), E2C11* (Unit 2).
- 125-Volt D.C. Bus E1A11 (Unit 1) E2A11 (Unit 2) energized from h. Battery Bank E1A11 (Unit 1), E2A11 (Unit 2),
- 125-Volt D.C. Bus E1D11 (Unit 1) E2D11 (Unit 2) energized from 1. Battery Bank E1D11 (Unit 1), E2D11 (Unit 2),
- 125-Volt D.C. Bus E1B11 (Unit 1) E2B11 (Unit 2) energized from j. Battery Bank E1B11 (Unit 1), E2B11 (Unit 2), and
- 125-Volt D.C. Bus E1C11 (Unit 1) E2C11 (Unit 2) energized from k. Battery Bank E1C11 (Unit 1), E2C11 (Unit 2).

*The inverter(s) associated with one channel may be disconnected from its D.C. bus for up to 24 hours as necessary, for the purpose of performing an equalizing charge on its associated battery bank provided: (1) its vital distribution panels are energized, and (2) the vital distribution panels associated with the other battery banks are energized from their associated inverters and connected to their associated D.C. busses.

SOUTH TEXAS - UNITS 1 & 2

3/4 8-14 Unit 1

Amendment No. 4

5.0 DESIGN FEATURES

5.1 SITE

EXCLUSION AREA

5.1.1 The Exclusion Area shall be as shown in Figure 5.1-1.

LOW POPULATION ZONE

5.1.2 The Low Population Zone shall be as shown in Figure 5.1-2.

MAP DEFINING UNRESTRICTED AREAS AND SITE BOUNDARY FOR RADIOACTIVE GASEOUS AND LIQUID EFFLUENTS

5.1.3 Information regarding radioactive gaseous and liquid effluents, which will allow identification of structures and release points as well as definition of UNRESTRICTED AREAS within the SITE BOUNDARY that are accessible to MEMBERS OF THE PUBLIC, shall be as shown in Figures 5.1-3 and 5.1-4.

The definition of UNRESTRICTED AREA used in implementing these Technical Specifications has been expanded over that in 10 CFR 20.3(a)(17). The UNRESTRICTED AREA boundary may coincide with the Exclusion (fenced) Area boundary, as defined in 10 CFR 100.3(a), but the UNRESTRICTED AREA does not include areas over water bodies. The concept of UNRESTRICTED AREAS, established at or beyond the SITE BOUNDARY, is utilized in the Limiting Conditions for Operation to keep levels of radioactive materials in liquid and gaseous effluents as low as is reasonably achievable, pursuant to 10 CFR 50.36a.

5.2 CONTAINMENT

CONFIGURATION

5.2.1 The reactor containment building is a steel-lined, reinforced concrete building of cylindrical shape, with a dome roof and having the following design features:

a. Nominal inside diameter = 150 feet.

- b. Nominal inside height = 241.25 feet.
- c. Minimum thickness of concrete walls = 4 feet.
- d. Minimum thickness of concrete roof = 3 feet.
- e. Minimum thickness of concrete floor mat = 18 feet.
- f. Nominal thickness of steel liner = 3/8 inches.
- g. Net free volume = 3.56×10^6 cubic feet.

DESIGN PRESSURE AND TEMPERATURE

5.2.2 The reactor containment building is designed and shall be maintained for a maximum internal pressure of 56.5 psig and a temperature of 286°F.

SOUTH TEXAS - UNITS 1 & 2



Unit 1 Amendment No. 4



FIGURE 5.1-1

EXCLUSION AREA



N



•

FIGURE 5.1-2

LOW POPULATION ZONE



2

ŧ

FIGURE 5.1-3

UNRESTRICTED AREA* AND SITE BOUNDARY FOR RADIOACTIVE GASEOUS EFFLUENTS (SEE FIGURE 5.1-4 FOR COMPLETE SITE BOUNDARY)

SOUTH TEXAS - UNITS 1 &

N

5-4

Unit 1 Amendment No.

4