

April 3, 1990

Docket No. 50-498

Mr. Donald P. Hall
Group Vice-President, Nuclear
Houston Lighting & Power Company
P. O. Box 1700
Houston, Texas 77251

Dear Mr. Hall:

SUBJECT: ISSUANCE OF AMENDMENT NO. 13 TO FACILITY OPERATING LICENSE
NPF-76 - SOUTH TEXAS PROJECT, UNIT 1 (TAC NO. 72003)

The Commission has issued the enclosed Amendment No. 13 to Facility Operating License No. NPF-76 for the South Texas Project, Unit 1. The amendment consists of changes to the Technical Specifications (TSs) in response to your application dated January 25, 1989.

The amendment changes the Appendix A Technical Specifications by modifying the calibration requirements for the source range neutron monitor circuitry to allow for the installation of a new model low noise preamplifier.

A copy of the Safety Evaluation supporting the amendment is also enclosed. Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

/s/

George F. Dick, Project Manager
Project Directorate IV
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 13 to NPF-76
2. Safety Evaluation

cc w/enclosures:

See next page

DISTRIBUTION:

Docket File

G. Holahan
G. Dick (2)
G. Hill (4)
ACRS (10)
P. Milano

NRC PDR
ADR4
OGC-Rockville
Wanda Jones
GPA/PA

Local PDR
F. Hebdon
D. Hagan
J. Calvo
ARM/LFMB

PD4 Reading
P. Noonan
E. Jordan
PD4 Plant File
S. Newberry

OFC	:PD4/LA	:PD4/PM	:PD4/PM	:SCIB	:OGC-Rock.	:PD4/D	:
NAME	:PNoonan	:PMilano:cs	:GDick	:SNewberry	:FHebdon	:FHebdon	:
DATE	:02/23/90	:02/26/90	:02/26/90	:02/26/90	:02/25/90	:02/23/90	:

OFFICIAL RECORD COPY

Document Name: STP 72003

9004190201 900403
PDR ADDCK 05000498
PDC

Q601
111



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

April 3, 1990

Docket No. 50-498

Mr. Donald P. Hall
Group Vice-President, Nuclear
Houston Lighting & Power Company
P. O. Box 1700
Houston, Texas 77251

Dear Mr. Hall:

SUBJECT: ISSUANCE OF AMENDMENT NO. 13 TO FACILITY OPERATING LICENSE
NPF-76 - SOUTH TEXAS PROJECT, UNIT 1 (TAC NO. 72003)

The Commission has issued the enclosed Amendment No. 13 to Facility Operating License No. NPF-76 for the South Texas Project, Unit 1. The amendment consists of changes to the Technical Specifications (TSs) in response to your application dated January 25, 1989.

The amendment changes the Appendix A Technical Specifications by modifying the calibration requirements for the source range neutron monitor circuitry to allow for the installation of a new model low noise preamplifier.

A copy of the Safety Evaluation supporting the amendment is also enclosed. Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

A handwritten signature in cursive script, reading "George F. Dick".

George F. Dick, Project Manager
Project Directorate IV
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 13 to NPF-76
2. Safety Evaluation

cc w/enclosures:
See next page

Mr. Donald P. Hall
Houston Lighting and Power Company

South Texas Project

cc:
Brian Berwick, Esq.
Assistant Attorney General
Environmental Protection Division
P. O. Box 12548
Capitol Station
Austin, Texas 78711

Resident Inspector/South Texas
Project
c/o U.S. Nuclear Regulatory Commission
P. O. Box 910
Bay City, Texas 77414

Mr. J. T. Westermeier
General Manager, South Texas Project
Houston Lighting and Power Company
P. O. Box 289
Houston, Texas 77483

Ms. Iris J. Jones
Acting City Attorney
City of Austin
P. O. Box 1088
Austin, Texas 78767

Mr. J. C. Lanier
Director of Generation
City of Austin Electric Utility
721 Barton Springs Road
Austin, Texas 78704

Mr. S. L. Rosen
Vice President, Nuclear Engineering
and Construction
Houston Lighting & Power Company
P. O. Box 289
Wadsworth, Texas 77483

Mr. R. J. Costello
Mr. M. T. Hardt
City Public Service Board
P. O. Box 1771
San Antonio, Texas 78296

Mr. M. A. McBurnett
Manager, Operations Support Licensing
Houston Lighting and Power Company
P. O. Box 289
Wadsworth, Texas 77483

Jack R. Newman, Esq.
Newman & Holtzinger, P. C.
1615 L Street, NW
Washington, D.C. 20036

Mr. E. T. Molnar
Mr. L. W. Hurst
Bechtel Corporation
P. O. Box 2166
Houston, Texas 77252-2166

Melbert Schwartz, Jr., Esq.
Baker & Botts
One Shell Plaza
Houston, Texas 77002

Mr. R. P. Verret
Mr. D. E. Ward
Central Power and Light Company
P. O. Box 2121
Corpus Christi, Texas 78403

Doub, Muntzing and Glasgow
Attorneys at Law
Suite 400
808 Seventeenth Street, N.W.
Washington, D.C. 20006

INPO
Records Center
1100 Circle 75 Parkway
Atlanta, Georgia 30339-3064

Mr. Gerald E. Vaughn
Vice-President, Nuclear Operations
Houston Lighting & Power Company
P. O. Box 289
Wadsworth, Texas 77483

Mr. Donald P. Hall
Houston Lighting & Power Company

South Texas Project

cc:
Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Office of Executive Director
for Operations
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Joseph M. Hendrie
50 Bellport Lane
Bellport, New York 11713

Judge, Matagorda County
Matagorda County Courthouse
1700 Seventh Street
Bay City, Texas 77414

Licensing Representative
Houston Lighting and Power Company
Suite 610
Three Metro Center
Bethesda, Maryland 20814

Rufus S. Scott
Associate General Counsel
Houston Lighting & Power Company
P. O. Box 61867
Houston, Texas 77208

Bureau of Radiation Control
State of Texas
1101 West 49th Street
Austin, Texas 78756

R. W. Chewning, Vice President
Nuclear Assurance
Houston Lighting & Power Company
P. O. Box 289
Wadsworth, Texas 77483



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

HOUSTON LIGHTING & POWER COMPANY
CITY PUBLIC SERVICE BOARD OF SAN ANTONIO
CENTRAL POWER AND LIGHT COMPANY
CITY OF AUSTIN, TEXAS
DOCKET NO. 50-498
SOUTH TEXAS PROJECT, UNIT 1
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 13
License No. NPF-76

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Houston Lighting & Power Company* (HL&P) acting on behalf of itself and for the City Public Service Board of San Antonio (CPS), Central Power and Light Company (CPL), and City of Austin, Texas (COA) (the licensees) dated January 25, 1989, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9004190203 900403
PDR ADDCK 05000498
P PIC

*Houston Lighting & Power Company is authorized to act for the City Public Service Board of San Antonio, Central Power and Light Company and City of Austin, Texas and has exclusive responsibility and control over the physical construction, operation and maintenance of the facility.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. NPF-76 is hereby amended to read as follows:

2. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 13, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Frederick J. Heddon, Director
Project Directorate IV
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: April 3, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 13

FACILITY OPERATING LICENSE NO. NPF-76

DOCKET NO. 50-498

Replace the following pages of the Appendix A Technical Specifications with the attached pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change. The corresponding overleaf pages are also provided to maintain document completeness.

Remove

3/4 3-11

3/4 3-14

Insert

3/4 3-11

3/4 3-14

TABLE 4.3-1

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>		<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>ANALOG CHANNEL OPERATIONAL TEST</u>	<u>TRIP ACTUATING DEVICE OPERATIONAL TEST</u>	<u>ACTUATION LOGIC TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
1.	Manual Reactor Trip	N.A.	N.A.	N.A.	R(14)	N.A.	1, 2, 3*, 4*, 5*
2.	Power Range, Neutron Flux						
	a. High Setpoint	S	D(2, 4), M(3, 4), Q(4, 6), R(4, 5)	Q(17)	N.A.	N.A.	1, 2
	b. Low Setpoint	S	R(4)	S/U(1)	N.A.	N.A.	1***, 2
3.	Power Range, Neutron Flux, High Positive Rate	N.A.	R(4)	Q(17)	N.A.	N.A.	1, 2
4.	Power Range, Neutron Flux, High Negative Rate	N.A.	R(4)	Q(17)	N.A.	N.A.	1, 2
5.	Intermediate Range, Neutron Flux	S	R(4, 5)	S/U(1)	N.A.	N.A.	1***, 2
6.	Source Range, Neutron Flux	S	R(4, 5)	S/U(1), Q(9)(17)	N.A.	N.A.	2**, 3, 4, 5
7.	Extended Range, Neutron Flux	S	R(4)	Q(12, 17)	N.A.	N.A.	3, 4, 5
8.	Overtemperature ΔT	S	R	Q(17)	N.A.	N.A.	1, 2
9.	Overpower ΔT	S	R	Q(17)	N.A.	N.A.	1, 2
10.	Pressurizer Pressure --Low	S	R	Q(17)	N.A.	N.A.	1

TABLE 4.3-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>ANALOG CHANNEL OPERATIONAL TEST</u>	<u>TRIP ACTUATING DEVICE OPERATIONAL TEST</u>	<u>ACTUATION LOGIC TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
11. Pressurizer Pressure --High	S	R	Q(17)	N.A.	N.A.	1, 2
12. Pressurizer Water Level--High	S	R	Q(17)	N.A.	N.A.	1
13. Reactor Coolant Flow --Low	S	R	Q(17, 18)	N.A.	N.A.	1
14. Steam Generator Water Level--Low-Low	S	R	Q(17,18)	N.A.	N.A.	1, 2
15. Undervoltage - Reactor Coolant Pumps	N.A.	R	N.A.	Q(17)	N.A.	1
16. Underfrequency - Reactor Coolant Pumps	N.A.	R	N.A.	Q(17)	N.A.	1
17. Turbine Trip						
a. Low Emergency Trip Fluid Pressure	N.A.	R	N.A.	S/U(1, 10)	N.A.	1
b. Turbine Stop Valve Closure	N.A.	R	N.A.	S/U(1, 10)	N.A.	1
18. Safety Injection Input from ESFAS	N.A.	N.A.	N.A.	R	N.A.	1, 2

TABLE 4.3-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>ANALOG CHANNEL OPERATIONAL TEST</u>	<u>TRIP ACTUATING DEVICE OPERATIONAL TEST</u>	<u>ACTUATION LOGIC TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
19. Reactor Trip System Interlocks						
a. Intermediate Range Neutron Flux, P-6	N.A.	R(4)	R	N.A.	N.A.	2**
b. Low Power Reactor Trips Block, P-7	N.A.	R(4)	R	N.A.	N.A.	1
c. Power Range Neutron Flux, P-8	N.A.	R(4)	R	N.A.	N.A.	1
d. Power Range Neutron Flux, P-9	N.A.	R(4)	R	N.A.	N.A.	1
e. Power Range Neutron Flux, P-10	N.A.	R(4)	R	N.A.	N.A.	1, 2
f. Turbine Impulse Chamber Pressure, P-13	N.A.	R	R	N.A.	N.A.	1
20. Reactor Trip Breaker	N.A.	N.A.	N.A.	M(7, 11)	N.A.	1, 2, 3*, 4*, 5*
21. Automatic Trip and Interlock Logic	N.A.	N.A.	N.A.	N.A.	M(7)	1, 2, 3*, 4*, 5*
22. Reactor Trip Bypass Breaker	N.A.	N.A.	N.A.	M(15),R(16)	N.A.	1, 2, 3*, 4*, 5*

TABLE 4.3-1 (Continued)

TABLE NOTATIONS

*When the Reactor Trip System breakers are closed and the Control Rod Drive System is capable of rod withdrawal.

**Below P-6 (Intermediate Range Neutron Flux Interlock) Setpoint.

***Below P-10 (Low Setpoint Power Range Neutron Flux Interlock) Setpoint.

- (1) If not performed in previous 31 days.
- (2) Comparison of calorimetric to excore power indication above 15% of RATED THERMAL POWER. Adjust excore channel gains consistent with calorimetric power if absolute difference is greater than 2%. The provisions of Specification 4.0.4 are not applicable to entry into MODE 2 or 1.
- (3) Single point comparison of incore to excore AXIAL FLUX DIFFERENCE above 15% of RATED THERMAL POWER. Recalibrate if the absolute difference is greater than or equal to 3%. The provisions of Specification 4.0.4 are not applicable for entry into MODE 2 or 1.
- (4) Neutron detectors may be excluded from CHANNEL CALIBRATION.
- (5) Detector plateau curves shall be obtained and evaluated. If a low noise preamplifier is used with the Source Range Detector, no plateau curve is obtained. Instead, with the high voltage setting varied as recommended by the manufacturer, an initial discriminator bias curve shall be measured for each detector. Subsequent discriminator bias curves shall be obtained, evaluated and compared to the initial curves. For the Intermediate Range and Power Range Neutron Flux channels the provisions of Specification 4.0.4 are not applicable for entry into MODE 2 or 1.
- (6) Incore - Excore Calibration, above 75% of RATED THERMAL POWER. The provisions of Specification 4.0.4 are not applicable for entry into MODE 2 or 1.
- (7) Each train shall be tested at least every 62 days on a STAGGERED TEST BASIS.
- (8) (Not Used)
- (9) Quarterly surveillance in MODES 3*, 4*, and 5* shall also include verification that permissives P-6 and P-10 are in their required state for existing plant conditions by observation of the permissive annunciator window.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 13 TO

FACILITY OPERATING LICENSE NO. NPF-76

HOUSTON LIGHTING & POWER COMPANY

CITY PUBLIC SERVICE BOARD OF SAN ANTONIO

CENTRAL POWER AND LIGHT COMPANY

CITY OF AUSTIN, TEXAS

DOCKET NO. 50-498

SOUTH TEXAS PROJECT, UNIT 1

1.0 INTRODUCTION

By application dated January 25, 1989, Houston Lighting & Power Company, et. al., (the licensee) requested changes to the Technical Specifications (TS) (Appendix A to Facility Operating License No. NPF-76) for South Texas Project, Unit 1. The proposed changes would modify the calibration requirements for the source range neutron monitors to allow for the possible installation of a replacement low noise preamplifier in the instrumentation circuitry.

2.0 DISCUSSION

With present circuitry the channel calibration specified in TS Table 4.2-1 requires the development of high voltage plateau curves for each of the BF_3 proportional counters detector degradation. Upon replacement with the low-noise preamplifier, this TS requirement will be accomplished by varying discriminator bias over a specified range of applied detector high voltages and the recording of changes in the neutron count rate. A graph of count rate versus discriminator bias is then generated for which the bias operating point is then selected. Detector degradation is determined by downward deviation in the discriminator bias curve from that of previous curves.

3.0 EVALUATION

During the preoperational testing of South Texas Project (STP) Unit 2, two of source range neutron monitor preamplifiers failed their performance testing and required replacement. At that time all of the original design preamplifiers, which are the model presently installed in STP Unit 1, were replaced with a new low noise preamplifier that the manufacturer provided as a direct replacement and which had a reduced susceptibility to electromagnetic interference. This preamplifier replacement fulfilled a licensing commitment for STP Unit 2.

7004190213 700403
FDR ADOCK 05000498
P FDC

The NRC staff had previously concluded for STP Unit 2 that both methods of channel calibration for periodical assessment of the condition of the source range neutron detectors are acceptable (Section 7.2.2.5 of NUREG-0781, Supplement 6, Safety Evaluation of the operation of South Texas Project, Unit 2). The proposed channel calibration requirements for STP Unit 1 are the same as that previously approved for Unit 2. Thus, the staff likewise finds the incorporation of these alternate requirements to be similarly acceptable.

4.0 ENVIRONMENTAL CONSIDERATION

The amendment involves a change in a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and changes in surveillance requirements. The staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposures. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR Section 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

5.0 CONCLUSION

Based upon its evaluation of the proposed changes to the South Texas Project, Unit 1, Technical Specifications, the staff has concluded that: there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and such activities will be conducted in compliance with the Commission's regulations and the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public. The staff, therefore, concludes that the proposed changes are acceptable.

Date: April 3, 1990

Principal Contributor: P. Milano, NRR/DRSP