September 9, 1991 🥣

Docket Nos. 50-498 and 50-499

> Mr. Donald P. Hall Group Vice-President, Nuclear Houston Lighting & Power Company P. 0. Box 1700 Houston, Texas 77251

DISTRIBUTION:

Docket File NRC PDR Local PDR PDIV-2 Reading **BBoger** MVirailio EPeyton (2) GDick (2) OGC DHagan

GHill (8) Wanda Jones CGrimes PDIV-2 Plant File ACRS (10) GPA/PA ARM/LFMB AHowell, Region IV DSkav

Dear Mr. Hall:

SUBJECT: ISSUANCE OF AMENDMENT NOS. 27 AND 17 TO FACILITY OPERATING LICENSE NOS. NPF-76 AND NPF-80 - SOUTH TEXAS PROJECT. UNITS 1 AND 2 (TAC NOS. 79390, 79391, 74891 AND 74892)

The Commission has issued the enclosed Amendment Nos. 27 and 17 to Facility Operating License Nos. NPF-76 and NPF-80 for the South Texas Project, Units 1 and 2. The amendments consist of changes to the Technical Specifications (TSs) in response to your applications dated September 15, 1989 (ST-HL-AE-3208) and January 8, 1991 (ST-HL-AE-3635) as amended on May 23, 1991 (ST-HL-AE-3756).

The amendments revise the Technical Specifications (TS) by relocating several cycle-specific core operating limits from the TS to the Core Operating Limits Reports (COLR). The impacted TSs are amended to note that the limit has been relocated to the COLR and the reference to the Radial Peaking Factor Report is replaced by a reference to the COLR. Additionally, the COLR description in the Administrative Control section of the TS has been expanded to provide more information. Licensee use of the COLR has been previously approved in Amendment No. 9 (Unit 1) and Amendment No. 1 (Unit 2) to the respective licenses.

A copy of the Safety Evaluation supporting the amendments is also enclosed. The Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

Original Signed By

George F. Dick, Jr., Project Manager Project Directorate IV-2 Division of Reactor Projects - III/IV/V Office of Nuclear Reactor Regulation

9109230176 910909 PDR ADOCK 05000498 PDR

Enclosures:

- Amendment No. 27 to NPF-76 1.
- Amendment No. 17 to NPF-80 2.
- 3. Safety Evaluation

cc w/enclosures: See next page



					1.1		
OFC	: PDIV-2/LA	: PDIV-2	: PDIV-2/PM	: OGGAMATAN	PDIV-2/D	:	
NAME	: EPeyton	: DSkay Dim	GDick Jul	Mour	SBlack	2 :	
DATE	: 8/9/91	. <i>8/14</i> /91	.8/01/91		: 9/6/91	:	
	OFFICIAL RECOR	D COPY				CP^{I}	DECI 1

Mr. Donald P. Hall

September 9, 1991

cc w/enclosures: Senior Resident Inspector U.S. Nuclear Regulatory Commission P. O. Box 910 Bay City, Texas 77414

Mr. J. C. Lanier/M. B. Lee City of Austin Electric Utility Department P. O. Box 1088 Austin, Texas 78767

Mr. R. J. Costello Mr. M. T. Hardt City Public Service Board P. O. Box 1771 San Antonio, Texas 78296

Mr. D. E. Ward Mr. T. M. Puckett Central Power and Light Company P. O. Box 2121 Corpus Christi, Texas 78403

INPO Records Center 1100 Circle 75 Parkway Atlanta, Georgia 30339-3064

Regional Administrator, Region IV U.S. Nuclear Regulatory Commission 611 Ryan Plaza Drive, Suite 1000 Arlington, Texas 76011

Mr. Joseph M. Hendrie 50 Bellport Lane Bellport, New York 11713

Judge, Matagorda County Matagorda County Courthouse 1700 Seventh Street Bay City, Texas 77414

Mr. William J. Jump Manager, Nuclear Licensing Houston Lighting & Power Company P. O. Box 289 Wadsworth, Texas 77483 Jack R. Newman, Esq. Newman & Holtzinger, P.C. 1615 L Street, N.W. Washington, D.C. 20036

Licensing Representative Houston Lighting and Power Company Suite 610 Three Metro Center Bethesda, Maryland 20814

Bureau of Radiation Control State of Texas 1101 West 49th Street Austin, Texas 78756

Rufus S. Scott Associate General Counsel Houston Lighting & Power Company P. O. Box 61867 Houston, Texas 77208



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D.C. 20555

HOUSTON LIGHTING & POWER COMPANY

CITY PUBLIC SERVICE BOARD OF SAN ANTONIO

CENTRAL POWER AND LIGHT COMPANY

CITY OF AUSTIN, TEXAS

DOCKET NO. 50-498

SOUTH TEXAS PROJECT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 27 License No. NPF-76

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The applications for amendment by Houston Lighting & Power Company* (HL&P) acting on behalf of itself and for the City Public Service Board of San Antonio (CPS), Central Power and Light Company (CPL), and City of Austin, Texas (COA) (the licensees) dated September 15, 1989 and January 8, 1991, as amended on May 23, 1991, comply with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9109230182 910909 PDR ADDCK 05000498 P PDR

^{*}Houston Lighting & Power Company is authorized to act for the City Public Service Board of San Antonio, Central Power and Light Company and City of Austin, Texas and has exclusive responsibility and control over the physical construction, operation and maintenance of the facility.

- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. NPF-76 is hereby amended to read as follows:
 - 2. <u>Technical Specifications</u>

The Technical Specifications contained in Appendix A, as revised through Amendment No. 27, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Black USANNI

Suzanne C. Black, Director Project Directorate IV-2 Division of Reactor Projects - III/IV/V Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: September 9, 1991



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D.C. 20555

HOUSTON LIGHTING & POWER COMPANY

CITY PUBLIC SERVICE BOARD OF SAN ANTONIO

CENTRAL POWER AND LIGHT COMPANY

CITY OF AUSTIN, TEXAS

DOCKET NO. 50-499

SOUTH TEXAS PROJECT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 17 License No. NPF-80

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The applications for amendment by Houston Lighting & Power Company* (HL&P) acting on behalf of itself and for the City Public Service Board of San Antonio (CPS), Central Power and Light Company (CPL), and City of Austin, Texas (COA) (the licensees) dated September 15, 1989 and January 8, 1991, as amended on May 23, 1991, comply with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

^{*}Houston Lighting & Power Company is authorized to act for the City Public Service Board of San Antonio, Central Power and Light Company and City of Austin, Texas and has exclusive responsibility and control over the physical construction, operation and maintenance of the facility.

- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. NPF-80 is hereby amended to read as follows:
 - 2. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 17, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Jusginne Black

Suzanne C. Black, Director Project Directorate IV-2 Division of Reactor Projects - III/IV/V Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: September 9, 1991

ATTACHMENT TO LICENSE AMENDMENT NOS. 27 AND 17

FACILITY OPERATING LICENSE NOS. NPF-76 AND NPF-80

DOCKET NOS. 50-498 AND 50-499

Replace the following pages of the Appendix A Technical Specifications with the attached pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change. The corresponding overleaf pages are also provided to maintain document completeness.

REMOVE	INSERT
iv	iv
v	v
xix	xix
3/4 1-6	3/4 1-6
3/4 1-7	3/4 1-7
3/4 1-7a	3/4 1-7a
3/4 1-16	3/4 1-16
3/4 1-17	3/4 1-17
3/4 1-22	3/4 1-22
3/4 2-1	3/4 2-1
3/4 2-2	3/4 2-2
3/4 2-4	3/4 2-4
3/4 2-5	3/4 2-5
3/4 2-6	3/4 2-6
3/4 2-7	3/4 2-7
3/4 2-8	3/4 2-8
3/4 2-9	3/4 2-9
B 3/4 1-2	B 3/4 1-2
B 3/4 2-1	B 3/4 2-1
B 3/4 2-2	B 3/4 2-2
B 3/4 2-5	B 3/4 2-5
6-20	6-20
-	6-20a

2.0 SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

-

SECTION	PAGE
2.1 SAFETY LIMITS	
2.1.1 REACTOR CORE	
2.1.2 REACTOR CODIANT SYSTEM PRESSURE	2~1
FIGURE 2 1-1 PEACTOR CORE CATETY LINET - TOUR LOOP OF THE	2-1
FIGURE 2.1 I REACTOR CORE SAFETY LIMIT - FOUR LOOPS IN OPERATION	2-2
2.2 LIMITING SAFETY SYSTEM SETTINGS	
2.2.1 REACTOR TRIP SYSTEM INSTRUMENTATION SETPOINTS.	2-3
TABLE 2.2-1 REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS	2-4
	. • •
BASES	
SECTION	
	PAGE
2.1 SAFEIT LIMITS	
2.1.1 REACTOR CORE	B 2-1
2.1.2 REACTOR COOLANT SYSTEM PRESSURE	B 2-2
2 2 LIMITING CALETY SYSTEM CETTINGS	
E.E. LIMITING SAFELT STOLEM SELLINGS	
2.2.1 REACTOR TRIP SYSTEM INSTRUMENTATION SETPOINTS	B 2-3

iii

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

SECTION	PAGE
3/4.0 APPLICABILITY	. 3/4 0-1
3/4.1 REACTIVITY CONTROL SYSTEMS	
3/4.1.1 BORATION CONTROL	
Shutdown Margin - T _{avg} Greater Than 200°F	. 3/4 1-1
FIGURE 3.1-1 REQUIRED SHUTDOWN MARGIN VERSUS RCS CRITICAL BORON CONCENTRATION (MODES 1, 2, 3, AND 4)	. 3/4 1-3
Shutdown Margin - T Less Than or Equal to 200°F	. 3/4 1-4
CONCENTRATION (MODE 5)	. 3/4 1-5
Moderator Temperature Coefficient	. 3/4 1-6
-IGURE 3.1-2a BOL MODERATOR TEMPERATURE COEFFICIENT VERSUS POWER	. 3/4 1-7
Minimum Temperature for Criticality	. 3/4 1-8
3/4.1.2 BORATION SYSTEMS	
Flow Paths - Shutdown	. 3/4 1-9
Flow Paths - Operating	. 3/4 1-1
Charging Pumps - Shutdown	. 3/4 1-1
Charging Pumps - Operating	. 3/4 1-1
Borated Water Sources - Shutdown	. 3/4 1-1
Borated Water Sources - Operating	. 3/4 1-14
3/4.1.3 MOVABLE CONTROL ASSEMBLIES	
Group Height	. 3/4 1-10
ABLE 3.1-1 ACCIDENT ANALYSES REQUIRING REEVALUATION IN THE EVENT OF AN INOPERABLE FULL-LENGTH ROD	. 3/4 1-1
Position Indication Systems - Operating	3/4 1-19
Position Indication Systems - Shutdown	3/4 1-2
Rod Drop Time	$3/4 - 2^{-2}$
Shutdown Rod Insertion Limit	3/4 1-2
Control Rod Insertion Limits	2/A 1_2
	. J/H 1~2.

SOUTH TEXAS - UNITS 1 & 2

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

SECTION	PAGE
3/4.2 POWER DISTRIBUTION LIMITS	
3/4.2.1 AXIAL FLUX DIFFERENCE	3/4 2-1
FIGURE 3.2-1 AXIAL FLUX DIFFERENCE LIMITS AS A FUNCTION OF	07 1 L I
RATED THERMAL POWER	Deleted
3/4.2.2 HEAT FLUX HOT CHANNEL FACTOR - F _Q (Z)	3/4 2-5
FIGURE 3.2-2 K(Z) - NORMALIZED $F_Q(Z)$ AS A FUNCTION OF CORE HEIGHT.	Deleted
3/4.2.3 NUCLEAR ENTHALPY RISE HOT CHANNEL FACTOR	3/4 2-9
3/4.2.4 QUADRANT POWER TILT RATIO	3/4 2-10
3/4.2.5 DNB PARAMETERS	3/4 2-11
3/4.3 INSTRUMENTATION	
3/4.3.1 REACTOR TRIP SYSTEM INSTRUMENTATION	3/4 3-1
TABLE 3.3-1 REACTOR TRIP SYSTEM INSTRUMENTATION	3/4 3-2
TABLE 3.3-2 REACTOR TRIP SYSTEM INSTRUMENTATION RESPONSE TIMES	3/4 3-9
TABLE 4.3-1 REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE	.,
REQUIREMENTS	3/4 3-11
3/4.3.2 ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION	3/4 3-16
TABLE 3.3-3 ENGINEERED SAFETY FEATURES ACTUATION SYSTEM	
	3/4 3-18
TABLE 3.3-4 ENGINEERED SAFETY FEATURES ACTUATION SYSTEM	2/4 2-20
TABLE 3.3-5 ENGINEERED SAFFTY FFATURES RESPONSE TIMES	3/4 3-29
TABLE 4.3-2 ENGINEERED SAFETY FEATURES ACTUATION SYSTEM	3/4 3-3/
INSTRUMENTATION SURVEILLANCE REQUIREMENTS	3/4 3-42
3/4.3.3 MONITORING INSTRUMENTATION	
Radiation Monitoring for Plant Operations	3/4 3-50
TABLE 3.3-6 RADIATION MONITORING INSTRUMENTATION	
FOR PLANT OPERATIONS	3/4 3-51
TABLE 4.3-3 RADIATION MONITORING INSTRUMENTATION FOR PLANT OPERATIONS SURVEILLANCE REQUIREMENTS	3/4 3-53
Movable Incore Detectors	3/4 2-54
Seismic Instrumentation	3/4 2-55
TABLE 3.3-7 SEISMIC MONITORING INSTRUMENTATION	3/4 3-56

V

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

SECTION	PAGE
TABLE 4.3-4 SEISMIC MONITORING INSTRUMENTATION SURVEILLANCE	3/1 2-57
Motoonological Instrumentation	$3/4 \ 3^{-}5/$
	3/4 3-30
TABLE 3.3-8 METEOROLOGICAL MONITORING INSTRUMENTATION	3/4 3-59
REQUIREMENTS	3/4 3-60
Remote Shutdown System	3/4 3-61
TABLE 3.3-9 REMOTE SHUTDOWN SYSTEM	3/4 3-62
TABLE 4.3-6 REMOTE SHUTDOWN MONITORING INSTRUMENTATION	
SURVEILLANCE REQUIREMENTS	3/4 3-66
Accident Monitoring Instrumentation	3/4 3-67
TABLE 3.3-10 ACCIDENT MONITORING INSTRUMENTATION	3/4 3-68
TABLE 4.3-7 ACCIDENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS.	3/4 3-73
Chemical Detection Systems	3/4 3-75
TABLE 3.3-11 (This table number is not used.)	3/4 3-77
Radioactive Liquid Effluent Monitoring Instrumentation.	3/4 3-79
TABLE 3 3-12 RADIOACTIVE LIGHTD FEELUENT MONITORING INSTRUMENTATION	3/4 3-80
TABLE 4.3-8 PADIOACTIVE LIGHTD EFELIENT MONITORING	5/4 5 00
INSTRUMENTATION SURVEILLANCE REQUIREMENTS	3/4 3-82
Radioactive Gaseous Effluent Monitoring Instrumentation	3/4 3-84
TABLE 3.3-13 RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION	3/4 3-85
TABLE 4.3-9 RADIOACTIVE GASEOUS EFFLUENT MONITORING	
INSTRUMENTATION SURVEILLANCE REQUIREMENTS	3/4 3-87
3/4.3.4 TURBINE OVERSPEED PROTECTION	3/4 3-89

•

ADMINISTRATIVE CONTROLS

SECTION		PAGE
6.5.2 NUC	LEAR SAFETY REVIEW BOARD (NSRB)	
Fur	ction	6-9
Com	position	6-10
Alt	ernates	6-10
Con	sultants	6-10
Mee	ting Frequency	6-10
Quo	rum	6-10
Rev	iew	6-10
Aud	its	6-11
Rec	ords	6-12
6.5.3 TEC	HNICAL REVIEW AND CONTROL	
Act	ivities	6-12
6.6 REPOR	TABLE EVENT ACTION	6-13
6.7 SAFET	(LIMIT VIOLATION	6-13
6.8 PROCED	URES AND PROGRAMS	6-14
6.9 REPORT	ING REQUIREMENTS	
6.9.1 ROUT	INE REPORTS	6-16
Star	tup Report	6-16
Annu	al Reports	6-17
Annu	al Radiological Environmental Operating Report	6-17
Semi	annual Radioactive Effluent Release Report	6-18
Mont	hly Operating Reports	6-20
Core	Operating Limits Report	6-20
6.9.2 SPEC	IAL REPORTS	6-20a
6.10 RECOR	<u>D_RETENTION</u>	6-21

SOUTH TEXAS - UNITS 1 & 2

I

ADMIN	ISTRATIVE CONTROLS	
SECTI	ON	PAGE
<u>6.11</u>	RADIATION PROTECTION PROGRAM	6-22
<u>6.12</u>	HIGH RADIATION AREA	6-22
<u>6.13</u>	PROCESS CONTROL PROGRAM (PCP)	6-23
6.14	OFFSITE DOSE CALCULATION MANUAL (ODCM)	6-23
<u>6.15</u>	MAJOR CHANGES TO LIQUID, GASEOUS, AND SOLID RADWASTE TREATMENT SYSTEMS	6-24

MODERATOR TEMPERATURE COEFFICIENT

LIMITING CONDITION FOR OPERATION

3.1.1.3 The moderator temperature coefficient (MTC) shall be within the limits specified in the Core Operating Limits Report (COLR). The maximum upper limit shall be less than or equal to that shown in Figure 3.1-2a.

<u>APPLICABILITY</u>: Beginning of Life (BOL) limit - MODES 1 and 2* only**. End of Life (EOL) limit - MODES 1, 2, and 3 only**.

ACTION:

- a. With the MTC more positive than the BOL limit specified in the COLR, operation in MODES 1 and 2 may proceed provided:
 - Control rod withdrawal limits are established and maintained sufficient to restore the MTC to less positive than the BOL limit specified in the COLR within 24 hours or be in HOT STANDBY within the next 6 hours. These withdrawal limits shall be in addition to the insertion limits of Specification 3.1.3.6;
 - 2. The control rods are maintained within the withdrawal limits established above until a subsequent calculation verifies that the MTC has been restored to within its limit for the all rods withdrawn condition; and
 - 3. A Special Report is prepared and submitted to the Commission, pursuant to Specification 6.9.2, within 10 days, describing the value of the measured MTC, the interim control rod withdrawal limits, and the predicted average core burnup necessary for restoring the positive MTC to within its limit for the all rods withdrawn condition.
- b. With the MTC more negative than the EOL limit specified in the COLR, be in HOT SHUTDOWN within 12 hours.

^{*}With K_{eff} greater than or equal to 1.

^{**}See Special Test Exceptions Specification 3.10.3.

3/4

1-5



REQUIRED SHUTDOWN MARGIN VERSUS RCS CRITICAL BORON CONCENTRATION (MODE 5)

SURVEILLANCE REQUIREMENTS

4.1.1.3 The MTC shall be determined to be within its limits during each fuel cycle as follows:

- a. The MTC shall be measured and compared to the BOL limit specified in the COLR prior to initial operation above 5% of RATED THERMAL POWER, after each fuel loading; and
- b. The MTC shall be measured at any THERMAL POWER and compared to the 300 ppm surveillance limit specified in the COLR (all rods withdrawn, RATED THERMAL POWER condition) within 7 EFPD after reaching an equilibrium boron concentration of 300 ppm. In the event this comparison indicates the MTC is more negative than the 300 ppm surveillance limit specified in the COLR, the MTC shall be remeasured, and compared to the EOL MTC limit specified in the COLR, at least once per 14 EFPD during the remainder of the fuel cycle.



 \sim



Figure 3.1–2a

MINIMUM TEMPERATURE FOR CRITICALITY

LIMITING CONDITION FOR OPERATION

3.1.1.4 The Reactor Coolant System lowest operating loop temperature (T shall be greater than or equal to 561° F.

APPLICABILITY: MODES 1 and 2* **.

ACTION:

With a Reactor Coolant System operating loop temperature (T_{avg}) less than 561°F, restore T_{avg} to within its limit within 15 minutes or be in HOT STANDBY within the next 15 minutes.

SURVEILLANCE REOUIREMENTS

4.1.1.4 The Reactor Coolant System temperature (T_{avg}) shall be determined to be greater than or equal to 561°F:

- a. Within 15 minutes prior to achieving reactor criticality, and
- b. At least once per 30 minutes when the reactor is critical and the Reactor Coolant System T_{avg} is less than 571°F with the T_{avg} -Tref Deviation Alarm not reset.

*With K greater than or equal to 1.

**See Special Test Exceptions Specification 3.10.3.

SOUTH TEXAS - UNITS 1 & 2 3/4 1-8

SURVEILLANCE REQUIREMENTS

4.1.2.6 Each borated water source shall be demonstrated OPERABLE at least once per 7 days by:

- a. Verifying the boron concentration in the water,
- b. Verifying the contained borated water volume of the water source, and
- c. Verifying the Boric Acid Storage System solution temperature when it is the source of borated water.

3/4.1.3 MOVABLE CONTROL ASSEMBLIES

GROUP HEIGHT

LIMITING CONDITION FOR OPERATION

3.1.3.1 All full-length shutdown and control rods shall be OPERABLE and positioned within \pm 12 steps (indicated position) of their group step counter demand position.

APPLICABILITY: MODES 1* and 2*.

ACTION:

- a. With one or more full-length rods inoperable due to being immovable as a result of excessive friction or mechanical interference or known to be untrippable, determine that the SHUTDOWN MARGIN requirement of Specification 3.1.1.1 is satisfied within 1 hour and be in HOT STANDBY within 6 hours.
- b. With one full-length rod trippable but inoperable due to causes other than addressed by ACTION a., above, or misaligned from its group step counter demand height by more than \pm 12 steps (indicated position), POWER OPERATION may continue provided that within 1 hour:
 - 1. The rod is restored to OPERABLE status within the above alignment requirements, or
 - 2. The rod is declared inoperable and the remainder of the rods in the group with the inoperable rod are aligned to within ± 12 steps of the inoperable rod while maintaining the rod sequence and insertion limits as specified in the Core Operating Limits Report (COLR). The THERMAL POWER level shall be restricted pursuant to Specification 3.1.3.6 during subsequent operation, or
 - 3. The rod is declared inoperable and the SHUTDOWN MARGIN requirement of Specification 3.1.1.1 is satisfied. POWER OPERATION may then continue provided that:
 - A reevaluation of each accident analysis of Table 3.1-1 is performed within 5 days; this reevaluation shall confirm that the previously analyzed results of these accidents remain valid for the duration of operation under these conditions;
 - b) The SHUTDOWN MARGIN requirement of Specification 3.1.1.1 is determined at least once per 12 hours;

*See Special Test Exceptions Specifications 3.10.2 and 3.10.3.

SOUTH TEXAS - UNITS 1 & 2 3/4 1-16

5 Ui

LIMITING CONDITION FOR OPERATION

ACTION (Continued)

- c) A power distribution map is obtained from the movable incore detectors and $F_Q(Z)$ and $F_{\Delta H}^N$ are verified to be within their limits within 72 hours; and
- d) The THERMAL POWER level is reduced to less than or equal to 75% of RATED THERMAL POWER within the next hour and within the following 4 hours the High Neutron Flux Trip Setpoint is reduced to less than or equal to 85% of RATED THERMAL POWER.
- c. With more than one rod trippable but inoperable due to causes other than addressed by ACTION a. above, POWER OPERATION may continue provided that:
 - Within 1 hour, the remainder of the rods in the bank(s) with the inoperable rods are aligned to within ± 12 steps of the inoperable rods while maintaining the rod sequence and insertion limits as specified in the COLR. The THERMAL POWER level shall be restricted pursuant to Specification 3.1.3.6 during subsequent operation, and
 - 2. The inoperable rods are restored to OPERABLE status within 72 hours.
- d. With more than one rod misaligned from its group step counter demand height by more than \pm 12 steps (indicated position), be in HOT STANDBY within 6 hours.

SURVEILLANCE REOUIREMENTS

4.1.3.1.1 The position of each full-length rod shall be determined to be within the group demand limit by verifying the individual rod positions at least once per 12 hours except during time intervals when the rod position deviation monitor is inoperable, then verify the group positions at least once per 4 hours.

4.1.3.1.2 Each full-length rod not fully inserted in the core shall be determined to be OPERABLE by movement of at least 10 steps in any one direction at least once per 31 days.

TABLE 3.1-1

ACCIDENT ANALYSES REQUIRING REEVALUATION IN THE EVENT OF AN INOPERABLE FULL-LENGTH ROD

Rod Cluster Control Assembly Insertion Characteristics

Rod Cluster Control Assembly Misalignment

Loss of Reactor Coolant from Small Ruptured Pipes or from Cracks in Large Pipes Which Actuates the Emergency Core Cooling System

Single Rod Cluster Control Assembly Withdrawal at Full Power

Major Reactor Coolant System Pipe Ruptures (Loss-of-Coolant Accident)

Major Secondary Coolant System Pipe Rupture

Rupture of a Control Rod Drive Mechanism Housing (Rod Cluster Control Assembly Ejection)

ROD DROP TIME

LIMITING CONDITION FOR OPERATION

3.1.3.4 The individual full-length (shutdown and control) rod drop time from the fully withdrawn position shall be less than or equal to 2.8 seconds from beginning of decay of stationary gripper coil voltage to dashpot entry with:

- a. T_{avo} greater than or equal to 561°F, and
- b. All reactor coolant pumps operating.

APPLICABILITY: MODES 1 and 2.

ACTION:

With the drop time of any full-length rod determined to exceed the above limit, restore the rod drop time to within the above limit prior to proceeding to MODE 1 or 2.

SURVEILLANCE REQUIREMENTS

4.1.3.4 The rod drop time of full-length rods shall be demonstrated through measurement prior to reactor criticality:

- a. For all rods following each removal of the reactor vessel head,
- b. For specifically affected individual rods following any maintenance on or modification to the Control Rod Drive System which could affect the drop time of those specific rods, and
- c. At least once per 18 months.

SHUTDOWN ROD INSERTION LIMIT

LIMITING CONDITION FOR OPERATION

3.1.3.5 All shutdown rods shall be fully withdrawn, as specified in the Core Operating Limits Report (COLR).

APPLICABILITY: MODES 1* and 2* **.

ACTION:

With a maximum of one shutdown rod not fully withdrawn, except for surveillance testing pursuant to Specification 4.1.3.1.2, within 1 hour either:

- a. Fully withdraw the rod, or
- b. Declare the rod to be inoperable and apply Specification 3.1.3.1.

SURVEILLANCE REQUIREMENTS

- 4.1.3.5 Each shutdown rod shall be determined to be fully withdrawn:
 - a. Within 15 minutes prior to withdrawal of any rods in Control Bank A, B, C, or D during an approach to reactor criticality, and
 - b. At least once per 12 hours thereafter.

^{*}See Special Test Exceptions Specifications 3.10.2 and 3.10.3. **With K_{eff} greater than or equal to 1.

3/4.2.1 AXIAL FLUX DIFFERENCE

LIMITING CONDITION FOR OPERATION

3.2.1 The indicated AXIAL FLUX DIFFERENCE (AFD) shall be maintained within the target band (flux difference units) about the target flux difference as specified in the CORE OPERATING LIMITS REPORT (COLR).

The indicated AFD may deviate outside the above required target band at greater than or equal to 50% but less than 90% of RATED THERMAL POWER provided the indicated AFD is within the Acceptable Operation Limits specified in the COLR and the cumulative penalty deviation time does not exceed 1 hour during the previous 24 hours.

The indicated AFD may deviate outside the above required target band at greater than 15% but less than 50% of RATED THERMAL POWER provided the cumulative penalty deviation time does not exceed 1 hour during the previous 24 hours.

APPLICABILITY: MODE 1, above 15% of RATED THERMAL POWER.*

ACTION:

- a. With the indicated AFD outside of the required target band and with THERMAL POWER greater than or equal to 90% of RATED THERMAL POWER, within 15 minutes either:
 - 1. Restore the indicated AFD to within the target band limits, or
 - 2. Reduce THERMAL POWER to less than 90% of RATED THERMAL POWER.
- b. With the indicated AFD outside of the above required target band for more than 1 hour of cumulative penalty deviation time during the previous 24 hours or outside the Acceptable Operation Limits specified in the COLR and with THERMAL POWER less than 90% but equal to or greater than 50% of RATED THERMAL POWER, reduce:
 - 1. THERMAL POWER to less than 50% of RATED THERMAL POWER within 30 minutes, and
 - 2. The Power Range Neutron Flux* ** High Setpoint to less than or equal to 55% of RATED THERMAL POWER within the next 4 hours.

^{*}See Special Test Exceptions Specification 3.10.2.

^{**}Surveillance testing of the Power Range Neutron Flux Channel may be performed pursuant to Specification 4.3.1.1 provided the indicated AFD is maintained within the Acceptable Operation Limits specified in the COLR. A total of 16 hours operation may be accumulated with the AFD outside of the above required target band during testing without penalty deviation.

LIMITING CONDITION FOR OPERATION

ACTION (Continued)

c. With the indicated AFD outside of the required target band for more than 1 hour of cumulative penalty deviation time during the previous 24 hours and with THERMAL POWER less than 50% but greater than 15% of RATED THERMAL POWER, the THERMAL POWER shall not be increased equal to or greater than 50% of RATED THERMAL POWER until the indicated AFD is within the required target band.

SURVEILLANCE REQUIREMENTS

4.2.1.1 The indicated AFD shall be determined to be within its limits during POWER OPERATION above 15% of RATED THERMAL POWER by:

- a. Monitoring the indicated AFD for each OPERABLE excore channel:
 - 1) At least once per 7 days when the AFD Monitor Alarm is OPERABLE, and
 - 2) At least once per hour for the first 24 hours after restoring the AFD Monitor Alarm to OPERABLE status.
- b. Monitoring and logging the indicated AFD for each OPERABLE excore channel at least once per hour for the first 24 hours and at least once per 30 minutes thereafter, when the AFD Monitor Alarm is inoperable. The logged values of the indicated AFD shall be assumed to exist during the interval preceding each logging.

4.2.1.2 The indicated AFD shall be considered outside of its target band when two or more OPERABLE excore channels are indicating the AFD to be outside the target band. Penalty deviation outside of the above required target band shall be accumulated on a time basis of:

- a. One minute penalty deviation for each 1 minute of POWER OPERATION outside of the target band at THERMAL POWER levels equal to or above 50% of RATED THERMAL POWER, and
- b. One-half minute penalty deviation for each 1 minute of POWER OPERATION outside of the target band at THERMAL POWER levels between 15% and 50% of RATED THERMAL POWER.

4.2.1.3 The target flux difference of each OPERABLE excore channel shall be determined by measurement at least once per 92 Effective Full Power Days. The provisions of Specification 4.0.4 are not applicable.

4.2.1.4 The target flux difference shall be updated at least once per 31 Effective Full Power Days by either determining the target flux difference

SURVEILLANCE REQUIREMENTS (Continued)

pursuant to Specification 4.2.1.3 above or by linear interpolation between the most recently measured value and the predicted value at the end of the cycle life. The provisions of Specification 4.0.4 are not applicable.

FIGURE 3.2-1 HAS BEEN DELETED

.

3/4.2.2 HEAT FLUX HOT CHANNEL FACTOR - $F_{0}(Z)$

LIMITING CONDITION FOR OPERATION

3.2.2 $F_{\Omega}(Z)$ shall be limited by the following relationships:

$$F_Q(Z) \leq \frac{F_Q^{RTP}}{p} + K(Z) \text{ for } P > 0.5$$

$$F_Q(Z) \leq \frac{F_Q^{RTP}}{0.5}$$
 * K(Z) for P ≤ 0.5

Where: F_Q^{RTP} = the F_Q limit at RATED THERMAL POWER (RTP) specified in the Core Operating Limits Report (COLR).

$$P = \frac{\text{THERMAL POWER}}{\text{RATED THERMAL POWER}}, \text{ and}$$

K(Z) = the normalized $F_Q(Z)$ as a function of core height specified in the COLR.

APPLICABILITY: MODE 1.

ACTION:

With $F_0(Z)$ exceeding its limit:

- a. Reduce THERMAL POWER at least 1% for each 1% $F_Q(Z)$ exceeds the limit within 15 minutes and similarly reduce the Power Range Neutron Flux-High Trip Setpoint within the next 4 hours; POWER OPERATION may proceed for up to a total of 72 hours; subsequent POWER OPERATION may proceed provided the Overpower ΔT Trip Setpoint has been reduced at least 1% for each 1% $F_Q(Z)$ exceeds the limit.
- b. Identify and correct the cause of the out-of-limit condition prior to increasing THERMAL POWER above the reduced limit required by ACTION a., above; THERMAL POWER may then be increased provided $F_Q(Z)$ is demonstrated through incore mapping to be within its limit.

FIGURE 3.2-2 HAS BEEN DELETED

SURVEILLANCE REQUIREMENTS

4.2.2.1 The provisions of Specification 4.0.4 are not applicable.

- 4.2.2.2 F_{xy} shall be evaluated to determine if $F_Q(Z)$ is within its limit by:
 - a. Using the movable incore detectors to obtain a power distribution map at any THERMAL POWER greater than 5% of RATED THERMAL POWER,
 - b. Increasing the measured F_{XY} component of the power distribution map by 3% to account for manufacturing tolerances and further increasing the value by 5% to account for measurement uncertainties,
 - c. Comparing the F computed (F $_{xy}^{C}$) obtained in Specification 4.2.2.2b., above to:
 - 1) The F_{xy} limits for RATED THERMAL POWER (F_{xy}^{RTP}) for the appropriate measured core planes given in Specification 4.2.2.2e. and f., below, and
 - 2) The relationship:

 $F_{xy}^{L} = F_{xy}^{RTP} [1+PF_{xy}(1-P)],$

Where $F_{XY}^{\ L}$ is the limit for fractional THERMAL POWER operation expressed as a function of F_{XY}^{RTP} , PF_{xy} is the power factor multiplier for F_{xy} specified in the COLR, and P is the fraction of RATED THERMAL POWER at which F_{xy} was measured.

- d. Remeasuring F_{XV} according to the following schedule:
 - 1) When F_{xy}^{C} is greater than the F_{xy}^{RTP} limit for the appropriate measured core plane but less than the F_{xy}^{L} relationship, additional power distribution maps shall be taken and F_{xy}^{C} compared to F_{xy}^{RTP} and F_{xy}^{L} either:
 - a) Within 24 hours after exceeding by 20% of RATED THERMAL POWER or greater, the THERMAL POWER at which $F_{\rm XY}^{\ \ C}$ was last determined, or
 - b) At least once per 31 Effective Full Power Days (EFPD), whichever occurs first.

SOUTH TEXAS - UNITS 1 & 2

SURVEILLANCE REQUIREMENTS (Continued)

- 2) When the F_{xy}^{C} is less than or equal to the F_{xy}^{RTP} limit for the appropriate measured core plane, additional power distribution maps shall be taken and F_{xy}^{C} compared to F_{xy}^{RTP} and F_{xy}^{L} at least once per 31 EFPD.
- e. The F_{xy} limits used in the Constant Axial Offset Control analysis for RATED THERMAL POWER (F_{xy}^{RTP}) shall be provided for all core planes containing Bank "D" control rods and all unrodded core planes as specified in the COLR per Specification 6.9.1.6;
- f. The F_{xy} limits of Specification 4.2.2.2e., above, are not applicable in the following core planes regions as measured in percent of core height from the bottom of the fuel:
 - 1) Lower core region from 0 to 15%, inclusive,
 - 2) Upper core region from 85 to 100%, inclusive,
 - 3) Grid plane regions at 22.4 \pm 2%, 34.2 \pm 2%, 46.0 \pm 2%, 57.8 \pm 2%, 69.5 \pm 2% and 81.3 \pm 2%, inclusive, and
 - 4) Core plane regions within ± 2% of core height (± 3.36 inches) about the bank demand position of the Bank "D" control rods.
- g. With F_{xy}^{C} exceeding F_{xy}^{L} , the effects of F_{xy} on $F_{Q}(Z)$ shall be evaluated to determine if $F_{Q}(Z)$ is within its limits.

4.2.2.3 When $F_Q(Z)$ is measured for other than $F_{\chi\gamma}$ determinations, an overall measured $F_Q(Z)$ shall be obtained from a power distribution map and increased by 3% to account for manufacturing tolerances and further increased by 5% to account for measurement uncertainty.

3/4.2.3 NUCLEAR ENTHALPY RISE HOT CHANNEL FACTOR

LIMITING CONDITION FOR OPERATION

3.2.3 $F_{\Delta H}^{N}$ shall be less than $F_{\Delta H}^{RTP}[1.0 + PF_{\Delta H}(1-P)]$ Where: $F_{\Delta H}^{RPT} =$ the $F_{\Delta H}^{N}$ Limit at RATED THERMAL POWER (RTP) specified in the Core Operating Limits Report (COLR) $PF_{\Delta H} =$ the Power Factor Multiplier for $F_{\Delta H}^{N}$ specified in the COLR. P = THERMAL POWER

RATED THERMAL POWER

APPLICABILITY: MODE 1.

ACTION:

With F_{AH}^{N} exceeding its limit:

- a. Within 2 hours reduce the THERMAL POWER to the level where the LIMITING CONDITION FOR OPERATION is satisfied.
- b. Identify and correct the cause of the out-of-limit condition prior to increasing THERMAL POWER above the limit required by ACTION a., above; THERMAL POWER may then be increased, provided $F^{N}_{\Delta H}$ is demonstrated through incore mapping to be within its limit.

SURVEILLANCE REQUIREMENTS

4.2.3.1 The provisions of Specification 4.0.4 are not applicable.

4.2.3.2 $F_{\Delta H}^{N}$ shall be demonstrated to be within its limit prior to operation above 75% RATED THERMAL POWER after each fuel loading and at least once per 31 EFPD thereafter by:

- a. Using the movable incore detectors to obtain a power distribution map at any THERMAL POWER greater than 5% RATED THERMAL POWER.
- b. Using the measured value of $F^N_{\Delta H}$ which does not include an allowance for measurement uncertainty.

3/4.2.4 QUADRANT POWER TILT RATIO

LIMITING CONDITION FOR OPERATION

3.2.4 The QUADRANT POWER TILT RATIO shall not exceed 1.02.

APPLICABILITY: MODE 1, above 50% of RATED THERMAL POWER*.

ACTION:

With the QUADRANT POWER TILT RATIO determined to exceed 1.02:

- a. Within 2 hours reduce THERMAL POWER at least 3% from RATED THERMAL POWER for each 1% of indicated QUADRANT POWER TILT RATIO in excess of 1 and similarly reduce the Power Range Neutron Flux-High Trip Setpoint within the next 4 hours.
- b. Within 24 hours and every 7 days thereafter, verify that $F_Q(Z)$ (by F_{xy} evaluation) and $F_{\Delta H}^N$ are within their limits by performing Surveillance Requirements 4.2.2.2 and 4.2.3.2. THERMAL POWER and setpoint reductions shall then be in accordance with the ACTION statements of Specifications 3.2.2 and 3.2.3.

SURVEILLANCE REQUIREMENTS

4.2.4.1 The QUADRANT POWER TILT RATIO shall be determined to be within the limit above 50% of RATED THERMAL POWER by:

- a. Calculating the ratio at least once per 7 days when the alarm is OPERABLE, and
- b. Calculating the ratio at least once per 12 hours during steady-state operation when the alarm is inoperable.

4.2.4.2 The QUADRANT POWER TILT RATIO shall be determined to be within the limit when above 75% of RATED THERMAL POWER with one Power Range channel inoperable by using the movable incore detectors to confirm indicated QUADRANT POWER TILT RATIO at least once per 12 hours by either:

- a. Using the four pairs of symmetric thimble locations, or
- b. Using the movable incore detection system to monitor the QUADRANT POWER TILT RATIO subject to the requirements of Specification 3.3.3.2.

^{*}See Special Test Exceptions Specification 3.10.2.

BASES

3/4.1.1 BORATION CONTROL

3/4.1.1.1 and 3/4.1.1.2 SHUTDOWN MARGIN

A sufficient SHUTDOWN MARGIN ensures that: (1) the reactor can be made subcritical from all operating conditions, (2) the reactivity transients associated with postulated accident conditions are controllable within acceptable limits, and (3) the reactor will be maintained sufficiently subcritical to preclude inadvertent criticality in the shutdown condition.

SHUTDOWN MARGIN requirements vary throughout core life as a function of fuel depletion, RCS boron concentration, and RCS T avg. In MODES 1 and 2, the most restrictive condition occurs at EOL, with T avg at no load operating temperature, and is associated with a postulated steam line break accident and resulting uncontrolled RCS cooldown. In the analysis of this accident, a minimum SHUTDOWN MARGIN of 1.75% $\Delta k/k$ is required to control the reactivity transient. The 1.75% $\Delta k/k$ SHUTDOWN MARGIN is the design basis minimum for the 14-foot fuel using silver-indium-cadmium and/or Hafnium control rods (Ref. FSAR Table 4.3-3). Accordingly, the SHUTDOWN MARGIN requirement for MODES 1 and 2 is based upon this limiting condition and is consistent with FSAR safety anal-ysis assumptions. In MODES 3, 4, and 5, the most restrictive condition occurs at BOL, when the boron concentration is the greatest. In these modes, the required SHUTDOWN MARGIN is composed of a constant requirement and a variable requirement, which is a function of the RCS boron concentration. SHUTDOWN MARGIN requirement of 1.75% $\Delta k/k$ is based on an uncontrolled RCS cooldown from a steamline break accident. The variable SHUTDOWN MARGIN requirement is based on the results of a boron dilution accident analysis, where the SHUT-DOWN MARGIN is varied as a function of RCS boron concentration, to guarantee a minimum of 15 minutes for operator action after a boron dilution alarm, prior to a loss of all SHUTDOWN MARGIN.

The boron dilution analysis assumed a common RCS volume, and maximum dilution flow rate for MODES 3 and 4, and a different volume and flow rate for MODE 5. The MODE 5 conditions assumed limited mixing in the RCS and cooling with the RHR system only. In MODES 3 and 4 it was assumed that at least one reactor coolant pump was operating. If at least one reactor coolant pump is not operating in MODE 3 or 4, then the SHUTDOWN MARGIN requirements for MODE 5 shall apply.

3/4.1.1.3 MODERATOR TEMPERATURE COEFFICIENT

The limitations on moderator temperature coefficient (MTC) are provided to ensure that the value of this coefficient remains within the limiting condition assumed in the FSAR accident and transient analyses.

The MTC values of this specification are applicable to a specific set of plant conditions; accordingly, verification of MTC values at conditions other than those explicitly stated will require extrapolation to those conditions in order to permit an accurate comparison.

SOUTH TEXAS - UNITS 1 & 2 B 3/4 1-1

Unit 1 - Amendment No. 10

BASES

MODERATOR TEMPERATURE COEFFICIENT (Continued)

The most negative MTC, value equivalent to the most positive moderator density coefficient (MDC), was obtained by incrementally correcting the MDC used in the FSAR analyses to nominal operating conditions. These corrections involved subtracting the incremental change in the MDC associated with a core condition of all rods inserted (most positive MDC) to an all rods withdrawn condition and, a conversion for the rate of change of moderator density with temperature at RATED THERMAL POWER conditions. This value of the MDC was then transformed into the limiting EOL MTC value specified in the Core Operating Limits Report (COLR). The 300 ppm surveillance MTC value represents a conservative value (with corrections for burnup and soluble boron) at a core condition of 300 ppm equilibrium boron concentration and is obtained by making these corrections to the limiting EOL MTC value.

The Surveillance Requirements for measurement of the MTC at the beginning and near the end of the fuel cycle are adequate to confirm that the MTC remains within its limits since this coefficient changes slowly due principally to the reduction in RCS boron concentration associated with fuel burnup.

3/4.1.1.4 MINIMUM TEMPERATURE FOR CRITICALITY

This specification ensures that the reactor will not be made critical with the Reactor Coolant System average temperature less than $561^{\circ}F$. This limitation is required to ensure: (1) the moderator temperature coefficient is within its analyzed temperature range, (2) the trip instrumentation is within its normal operating range, (3) the pressurizer is capable of being in an OPERABLE status with a steam bubble, and (4) the reactor vessel is above its minimum RT_{NDT} temperature.

3/4.1.2 BORATION SYSTEMS

The Boron Injection System ensures that negative reactivity control is available during each mode of facility operation. The components required to perform this function include: (1) borated water sources, (2) charging pumps, (3) separate flow paths, (4) boric acid transfer pumps, and (5) an emergency power supply from OPERABLE diesel generators.

With the RCS average temperature above 350° F, a minimum of two boron injection flow paths are required to ensure single functional capability in the event an assumed failure renders one of the flow paths inoperable. The boration capability of either flow path is sufficient to provide a SHUTDOWN MARGIN from expected operating conditions of 1.75% $\Delta k/k$ after xenon decay and cooldown to 200°F. The maximum expected boration capability requirement occurs at EOL from full power equilibrium xenon conditions and requires 27,000 gallons of 7000 ppm borated water from the boric acid storage system or 458,000 gallons of 2500 ppm borated water from the refueling water storage tank (RWST). The RWST volume is an ECCS requirement and is more than adequate for the required boration capability.

Unit 1 - Amendment No. 27 Unit 2 - Amendment No. 17

BASES

The specifications of this section provide assurance of fuel integrity during Condition I (Normal Operation) and II (Incidents of Moderate Frequency) events by: (1) maintaining the minimum DNBR in the core greater than or equal to 1.30 during normal operation and in short-term transients, and (2) limiting the fission gas release, fuel pellet temperature, and cladding mechanical properties to within assumed design criteria. In addition, limiting the peak linear power density during Condition I events provides assurance that the initial conditions assumed for the LOCA analyses are met and the ECCS acceptance criteria limit of 2200°F is not exceeded.

The definitions of certain hot channel and peaking factors as used in these specifications are as follows:

- $F_Q(Z)$ Heat Flux Hot Channel Factor, is defined as the maximum local heat flux on the surface of a fuel rod at core elevation Z divided by the average fuel rod heat flux, allowing for manufacturing tolerances on fuel pellets and rods;
- $F_{\Delta H}^{N}$ Nuclear Enthalpy Rise Hot Channel Factor, is defined as the ratio of the integral of linear power along the rod with the highest integrated power to the average rod power; and
- $F_{xy}(Z)$ Radial Peaking Factor, is defined as the ratio of peak power density to average power density in the horizontal plane at core elevation Z.

3/4.2.1 AXIAL FLUX DIFFERENCE

The limits on AXIAL FLUX DIFFERENCE (AFD) assure that the $F_0(Z)$ upper bound envelope of the F_0 limit specified in the Core Operating Limits Report (COLR) times the normalized axial peaking factor is not exceeded during either normal operation or in the event of xenon redistribution following power changes.

Target flux difference is determined at equilibrium xenon conditions. The full-length rods may be positioned within the core in accordance with their respective insertion limits and should be inserted near their normal position for steady-state operation at high power levels. The value of the target flux difference obtained under these conditions divided by the fraction of RATED THERMAL POWER is the target flux difference at RATED THERMAL POWER for the associated core burnup conditions. Target flux differences for other THERMAL POWER levels are obtained by multiplying the RATED THERMAL POWER value by the appropriate fractional THERMAL POWER level. The periodic updating of the target flux difference value is necessary to reflect core burnup considerations.

BASES

AXIAL FLUX DIFFERENCE (Continued)

Although it is intended that the plant will be operated with the AFD within the target band required by Specification 3.2.1 about the target flux difference, during rapid plant THERMAL POWER reductions, control rod motion will cause the AFD to deviate outside of the target band at reduced THERMAL POWER levels. This deviation will not affect the xenon redistribution sufficiently to change the envelope of peaking factors which may be reached on a subsequent return to RATED THERMAL POWER (with the AFD within the target band) provided the time duration of the deviation is limited. Accordingly, a 1-hour penalty deviation limit cumulative during the previous 24 hours is provided for operation outside of the target band but within the limits specified in the COLR while at THERMAL POWER levels between 50% and 90% of RATED THERMAL POWER. For THERMAL POWER levels between 15% and 50% of RATED THERMAL POWER, deviations of the AFD outside of the target band are less significant. The penalty of 2 hours actual time reflects this reduced significance.

Provisions for monitoring the AFD on an automatic basis are derived from the plant process computer through the AFD Monitor Alarm. The computer determines the 1-minute average of each of the OPERABLE excore detector outputs and provides an alarm message immediately if the AFD for two or more OPERABLE excore channels are outside the target band and the THERMAL POWER is greater than 90% of RATED THERMAL POWER. During operation at THERMAL POWER levels between 50% and 90% and between 15% and 50% RATED THERMAL POWER, the computer outputs an alarm message when the penalty deviation accumulates beyond the limits of 1 hour and 2 hours, respectively.

Figure B 3/4 2-1 shows a typical monthly target band.

3/4.2.2 and 3/4.2.3 HEAT FLUX HOT CHANNEL FACTOR and NUCLEAR ENTHALPY RISE HOT CHANNEL FACTOR

The limits on heat flux hot channel factor and nuclear enthalpy rise hot channel factor ensure that: (1) the design limits on peak local power density and minimum DNBR are not exceeded and (2) in the event of a LOCA the peak fuel clad temperature will not exceed the 2200°F ECCS acceptance criteria limit.

Each of these is measurable but will normally only be determined periodically as specified in Specifications 4.2.2 and 4.2.3. This periodic surveillance is sufficient to ensure that the limits are maintained provided:

- a. Control rods in a single group move together with no individual rod insertion differing by more than \pm 12 steps, indicated, from the group demand position;
- Control rod groups are sequenced with overlapping groups as described in Specification 3.1.3.6;

BASES

HEAT FLUX HOT CHANNEL FACTOR and NUCLEAR ENTHALPY RISE HOT CHANNEL FACTOR (Continued)

When an F_Q measurement is taken, an allowance for both experimental error and manufacturing tolerance must be made. An allowance of 5% is appropriate for a full-core map taken with the Incore Detector Flux Mapping System, and a 3% allowance is appropriate for manufacturing tolerance.

The Radial Peaking Factor, $F_{XY}(Z)$, is measured periodically to provide assurance that the Hot Channel Factor, $F_Q(Z)$, remains within its limit. The F_{XY} limit for RATED THERMAL POWER (F_{XY}) as provided in the Core Operating Limits Report (COLR) per Specification 6.9.1.6 was determined from expected power control manuevers over the full range of burnup conditions in the core.

3/4.2.4 QUADRANT POWER TILT RATIO

The QUADRANT POWER TILT RATIO limit assures that the radial power distribution satisfies the design values used in the power capability analysis. Radial power distribution measurements are made during STARTUP testing and periodically during power operation.

The limit of 1.02, at which corrective action is required, provides DNB and linear heat generation rate protection with x-y plane power tilts. A limit of 1.02 was selected to provide an allowance for the uncertainty associated with the indicated power tilt.

The 2-hour time allowance for operation with a tilt condition greater than 1.02 is provided to allow identification and correction of a dropped or misaligned control rod. In the event such action does not correct the tilt, the margin for uncertainty on F_Q is reinstated by reducing the maximum allowed power by 3% for each percent of tilt in excess of 1.

For purposes of monitoring QUADRANT POWER TILT RATIO when one excore detector is inoperable, the moveable incore detectors are used to confirm that the normalized symmetric power distribution is consistent with the QUADRANT POWER TILT RATIO. The incore detector monitoring is done with a full incore flux map or two sets of four symmetric thimbles. The two sets of four symmetric thimbles is a unique set of eight detector locations. These locations are C-8, E-5, E-11, H-3, H-13, L-5, L-11, N-8.

3/4.2.5 DNB PARAMETERS

The limits on the DNB-related parameters assure that each of the parameters are maintained within the normal steady-state envelope of operation assumed in the transient and accident analyses. The limits are consistent with the

BASES

3/4.2.5 DNB PARAMETERS (Continued)

initial FSAR assumptions and have been analytically demonstrated adequate to maintain a minimum DNBR of greater than or equal to the design limit throughout each analyzed transient. The indicated $T_{\rm avg}$ value of 598°F and the indicated pressurizer pressure value of 2201 psig are provided assuming that the readings

from four channels will be averaged before comparing with the required limit. The flow requirement (395,000 gpm) includes a measurement uncertainty of 3.5%.

The 12-hour periodic surveillance of these parameters through instrument readout is sufficient to ensure that the parameters are restored within their limits following load changes and other expected transient operation.

ADMINISTRATIVE CONTROLS

SEMIANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT (Continued)

in Appendix B shall be supplemented with three additional categories: class of solid wastes (as defined by 10 CFR Part 61), type of container (e.g., LSA, Type A, Type B, Large Quantity) and SOLIDIFICATION agent or absorbent (e.g., cement, urea formaldehyde).

The Semiannual Radioactive Effluent Release Report to be submitted within 60 days after January 1 of each year shall include an annual summary of hourly meteorological data collected over the previous year. This annual summary may be either in the form of an hour-by-hour listing on magnetic tape of wind speed, wind direction, atmospheric stability, and precipitation (if measured), or in the form of joint frequency distributions of wind speed, wind direction. and atmospheric stability.* This same report shall include an assessment of the radiation doses due to the radioactive liquid and gaseous effluents released from the unit or station during the previous calendar year. This same report shall also include an assessment of the radiation doses from radioactive liquid and gaseous effluents to MEMBERS OF THE PUBLIC due to their activities inside the SIIE BOUNDARY (Figures 5.1-3 and 5.1-4) during the report period. All assumptions used in making these assessments, i.e., specific activity, exposure time, and location, shall be included in these reports. The meteorological conditions concurrent with the time of release of radioactive materials in gaseous effluents, as determined by sampling frequency and measurement, shall be used for determining the gaseous pathway doses. The assessment of radiation doses shall be performed in accordance with the methodology and parameters in the OFFSITE DOSE CALCULATION MANUAL (ODCM).

The Semiannual Radioactive Effluent Release Report to be submitted within 60 days after January 1 of each year shall also include an assessment of radiation doses to the likely most exposed MEMBER OF THE PUBLIC from reactor releases and other nearby uranium fuel cycle sources, including doses from primary effluent pathways and direct radiation, for the previous calendar year to show conformance with 40 CFR Part 190, "Environmental Radiation Protection Standards for Nuclear Power Operation." Acceptable methods for calculating the dose contribution from liquid and gaseous effluents are given in Regulatory Guide 1.109, Rev. 1, October 1977.

The Semiannual Radioactive Effluent Release Reports shall include a list and description of unplanned releases from the site to UNRESTRICTED AREAS of radioactive materials in gaseous and liquid effluents made during the reporting period.

The Semiannual Radioactive Effluent Release Reports shall include any changes made during the reporting period to the PROCESS CONTROL PROGRAM and the ODCM, pursuant to Specifications 6.13 and 6.14, respectively, as well as any major change to Liquid, Gaseous, or Solid Radwaste Treatment Systems pursuant to Specification 6.15. It shall also include a listing of new locations for dose calculations and/or environmental monitoring identified by the Land Use Census pursuant to Specification 3.12.2.

^{*}In lieu of submission with the Semiannual Radioactive Effluent Release Report, the licensee has the option of retaining this summary of required meteorological data on site in a file that shall be provided to the NRC upon request.

ADMINISTRATIVE CONTROLS

SEMIANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT (Continued)

The Semiannual Radioactive Effluent Release Reports shall also include the following: an explanation as to why the inoperability of liquid or gaseous effluent monitoring instrumentation was not corrected within the time specified in Specification 3.3.3.10 or 3.3.3.11, respectively; and description of the events leading to liquid holdup tanks or gas storage tanks exceeding the limits of Specification 3.11.1.4 or 3.11.2.6, respectively.

MONTHLY OPERATING REPORTS

6.9.1.5 Routine reports of operating statistics and shutdown experience, including documentation of all challenges to the PORVs or safety valves, shall be submitted on a monthly basis to the Director, Office of Resource Management, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, with a copy to the Regional Administrator of the Regional Office of the NRC, no later than the 15th of each month following the calendar month covered by the report.

CORE OPERATING LIMITS REPORT

- 6.9.1.6.a Core operating limits shall be established and documented in the CORE OPERATING LIMITS REPORT before each reload cycle, or any part of a reload cycle for the following:
 - 1. Moderator Temperature Coefficient BOL and EOL limits, and 300 ppm surveillance limit for Specification 3/4.1.1.3,
 - 2. Shutdown Bank Insertion Limit for Specification 3/4.1.3.5,
 - 3. Control Bank Insertion Limits for Specification 3/4.1.3.6,
 - 4. Axial Flux Difference limits and target band for Specification 3/4.2.1,
 - 5. Heat Flux Hot Channel Factor, K(Z), Power Factor Multiplier, and F_{xy}^{RTP} , for Specification 3/4.2.2, and
 - 6. Nuclear Enthalpy Rise Hot Channel Factor, and Power Factor Multiplier for Specification 3/4.2.3.

The CORE OPERATING LIMITS REPORT shall be maintained available in the Control Room.

6.9.1.6.b The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC in:

 WCAP 9272-P-A, "WESTINGHOUSE RELOAD SAFETY EVALUATION METHODOLOGY", July, 1985 (W Proprietary).

(Methodology for Specification 3.1.1.3 - Moderator Temperature Coefficient, 3.1.3.5 - Shutdown Rod Insertion Limit, 3.1.3.6 -Control Bank Insertion Limits, 3.2.1 - Axial Flux Difference, 3.2.2 - Heat Flux Hot Channel Factor, and 3.2.3 - Nuclear Enthalpy Rise Hot Channel Factor.)

ADMINISTRATIVE CONTROLS

CORE OPERATING LIMITS REPORT (Continued)

2. WCAP 8385, "POWER DISTRIBUTION AND LOAD FOLLOWING PROCEDURES TOPICAL REPORT", September, 1974 (\underline{W} Proprietary).

(Methodology for Specification 3.2.1 - Axial Flux Difference (Constant Axial Offset Control).)

 Westinghouse letter NS-TMA-2198, T. M. Anderson (Westinghouse) to K. Kniel (Chief of Core Performance Branch, NRC) January 31, 1980 -Attachment: Operation and Safety Analysis Aspects of an Improved Load Follow Package.

(Methodology for Specification 3.2.1 - Axial Flux Difference (Constant Axial Offset Control). Approved by NRC Supplement No. 4 to NUREG-0422 January, 1981 Docket Nos. 50-369 and 50-370.)

 NUREG-0800, Standard Review Plan, U.S. Nuclear Regulatory Commission, Section 4.3, Nuclear Design, July, 1981. Branch Technical Position CPB 4.3-1, Westinghouse Constant Axial Offset Control (CAOC), Rev. 2, July 1981.

(Methodology for Specification 3.2.1 - Axial Flux Difference (Constant Axial Offset Control).)

5. WCAP 9220-P-A, Rev. 1, "WESTINGHOUSE ECCS EVALUATION MODEL-1981 VERSION", February 1982 (<u>W</u> Proprietary).

(Methodology for Specification 3.2.2 - Heat Flux Hot Channel Factor.)

6. WCAP 9561-P-A, ADD. 3, Rev. 1, "BART A-1: A COMPUTER CODE FOR THE BEST ESTIMATE ANALYSIS OF REFLOOD TRANSIENTS - SPECIAL REPORT: THIMBLE MODELING W ECCS EVALUATION MODEL", July, 1986, (W Proprietary).

(Methodology for Specification 3.2.2 - Heat Flux Hot Channel Factor.)

- 6.9.1.6.c The core operating limits shall be determined so that all applicable limits (e.g., fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, and transient and accident analysis limits) of the safety analysis are met.
- 6.9.1.6.d The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements thereto, shall be provided upon issuance, for each reload cycle, to the NRC Document Control Desk, with copies to the Regional Administrator and Resident Inspector.

SPECIAL REPORTS

6.9.2 Special reports shall be submitted to the Regional Administrator of the Regional Office of the NRC within the time period specified for each report.



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NOS. 27 AND 17 TO

FACILITY OPERATING LICENSE NOS. NPF-76 AND NPF-80

HOUSTON LIGHTING & POWER COMPANY

CITY PUBLIC SERVICE BOARD OF SAN ANTONIO

CENTRAL POWER AND LIGHT COMPANY

CITY OF AUSTIN, TEXAS

DOCKET NOS. 50-498 AND 50-499

SOUTH TEXAS PROJECT, UNITS 1 AND 2

1.0 INTRODUCTION

By letters dated September 15, 1989, and January 8, 1991, as amended by letter dated May 23, 1991, Houston Lighting & Power Company (HL&P) (the licensee) proposed changes to the Technical Specifications (TS) for the South Texas Project Units 1 and 2 (STP). The proposed changes would modify additional specifications which have cycle-specific parameter limits by replacing the values of those limits with a reference to a Core Operating Limits Report (COLR). The use of the COLR for STP was previously approved by the NRC. Guidance on the proposed changes was developed by NRC on the basis of the review of a lead plant proposal submitted by Duke Power Company for the Oconee plant. This guidance was provided to all power reactor licensees and applicants by Generic Letter 88-16, "Removal of Cycle-Specific Parameter Limits from Technical Specifications," dated October 4, 1988. The May 23, 1991, letter provided clarifying information that did not alter the action noticed or change the initial proposed no significant hazards consideration determination.

2.0 EVALUATION

The licensee's proposed additional changes to the TS are in accordance with the guidance provided by Generic Letter 88-16 and are addressed below.

(1) In addition to the approved cycle-specific core operating limits, in Amendment No. 9 (Unit 1) and Amendment No. 1 (Unit 2) dated July 31, 1989, the following specifications were revised to replace the values of cycle-specific parameter limits with a reference to the COLR that provides these limits.

9109230183 910909 PDR ADOCK 05000498 P PDR (a) Specification 3.1.1.3 and Surveillance Requirement 4.1.1.3

The moderator temperature coefficient (MTC) limits for this specification and for this requirement are specified in the COLR.

(b) Specification 3.1.3.5

••••••

The shutdown rod insertion limit for this specification is specified in the COLR.

(c) Specification 3.2.1

The axial flux difference limits and target band for this specification are specified in the COLR.

(d) Specification 3.2.2 and Surveillance Requirement 4.2.2

The heat flux hot channel factor (F_0) limit at rated thermal power, the normalized F_0 limit as a function of core height K(z), and the Fxy limits for rated thermal power for this specification and for this surveillance requirement are specified in the COLR.

(e) Specification 3.2.3

The nuclear enthalpy rise hot channel factor (F_{H}^{N}) for this specification is specified in the COLR.

The Bases for the affected specifications have been modified by the licensee to include appropriate reference to the COLR. Based on its review, the staff concludes that the changes to these Bases are acceptable.

- (2) Specification 6.9.1.6, Core Operating Limits Report, of the Administrative Controls section of the TS, is revised to include currently proposed TS changes in Specification 6.9.1.6.a and to add additional NRC approved methodologies in Specification 6.9.1.6.b to support the values of cyclespecific parameter limits that are applicable for the current fuel cycle. The approved methodologies are the following:
 - (a) WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," July 1985 (<u>W</u> Proprietary).

(Methodology for Specification 3.1.1.3 - Moderator Temperature Coefficient, 3.1.3.5 - Shutdown Rod Insertion Limit, 3.1.3.6 -Control Bank Insertion Limits, 3.2.1 - Axial Flux Difference, 3.2.2 - Heat Flux Hot Channel Factor, and 3.2.3 - Nuclear Enthalpy Rise Hot Channel Factor). (b) WCAP-8385, "Power Distribution and Load Following Procedures Topical Report," September 1974 (<u>W</u> Proprietary).

(Methodology for Specification 3.2.1 - Axial Flux Difference [Constant Axial Offset Control]).

(c) Westinghouse letter NS-TMA-2198, T.M. Anderson (Westinghouse) to K. Kniel (Chief of Core Performance Branch, NRC) January 31, 1980 -Attachment: Operation and Safety Analysis Aspects of an Improved Load Follow Package.

(Methodology for Specification 3.2.1 - Axial Flux Difference [Constant Axial Offset Control]. Approved by NRC Supplement No. 4 to NUREG-0422, January 1981, Docket Nos. 50-369 and 50-370.)

(d) NUREG-0800, Standard Review Plan, U.S. Nuclear Regulatory Commission, Section 4.3, Nuclear Design, July 1981. Branch Technical Position CPB 4.3-1, Westinghouse Constant Axial Offset Control (CAOC), Rev. 2, July 1981.

(Methodology for Specification 3.2.1 - Axial Flux Difference [Constant Axial Offset Control]).

(e) WCAP-9220-P-A, Rev. 1, "Westinghouse ECCS Evaluation Model-1981 Version," February 1982 (<u>W</u> Proprietary).

(Methodology for Specification 3.2.2 - Heat Flux Hot Channel Factor.)

(f) WCAP-9561-P-A, Add. 3, Rev. 1, "BART A-1: A Computer Code for the Best Estimate Analysis of Reflood Transients - Special Report: Thimble Modeling <u>W</u> ECCS Evaluation Model," July 1986, (<u>W</u> Proprietary).

(Methodology for Specification 3.2.2 - Heat Flux Hot Channel Factor.)

Finally, the specification requires that all changes in cycle-specific parameter limits be documented in the COLR before each reload cycle or remaining part of a reload cycle and submitted upon issuance to NRC.

On the basis of the review of the above items, the NRC staff concludes that the licensee provided an acceptable response to those items as addressed in the NRC guidance in Generic Letter 88-16 on modifying cycle-specific parameters limits in TS. Because plant operation continues to be limited in accordance with the values of cycle-specific parameter limits that are established using NRC approved methodologies, the NRC staff concludes that the proposed changes are acceptable.

3.0 STATE CONSULTATION

1 a 🖕

In accordance with the Commission's regulations, the Texas State official was notified of the proposed issuance of the amendments. The State official had no comments.

4.0 ENVIRONMENTAL CONSIDERATION

The amendments change a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. Commission has previously issued a proposed finding that the amendments involve The no significant hazards consideration, and there has been no public comment on such finding (56 FR 9380). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). These amendments also relate to changes in recordkeeping or reporting requirements. Accordingly, with respect to these items, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(10). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

5.0 CONCLUSION

The Commission has concluded, based on the consideration discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: T. Huang

Date: September 9, 1991