Docket Nos. 50-498 and 50-499

> Mr. Donald P. Hall Group Vice-President, Nuclear Houston Lighting & Power Company P. O. Box 1700 Houston, Texas 77251

Dear Mr. Hall:

SUBJECT: ISSUANCE OF AMENDMENT NOS. 36 AND 27 TO FACILITY OPERATING LICENSE NOS. NPF-76 AND NPF-80 - SOUTH TEXAS PROJECT, UNITS 1 AND 2 (TAC NOS. M81398 AND M81399)

The Commission has issued the enclosed Amendment Nos. 36 and 27 to Facility Operating License Nos. NPF-76 and NPF-80 for the South Texas Project, Units 1 and 2. The amendments consists of changes to the Technical Specifications (TSs) in response to your application dated August 23, 1991, as supplemented by letter dated January 24, 1992.

The amendments change the Appendix A Technical Specifications by removing TS Table 4.4-5 which provides the schedule for reactor vessel material specimen withdrawal. Guidance on the proposed change was provided by Generic Letter 91-01, "Removal of the Schedule for the Withdrawal of Reactor Vessel Material Specimens from Technical Specifications."

A copy of our related Safety Evaluation supporting the amendments is also enclosed. The Notice of Issuance will be included in the Commission's next biweekly <u>Federal Register</u> notice.

Sincerely,

Original Signed By

DISTRIBUTION:

Docket File

NRC/PDR

BBoger

DHagan

Local PDR

PDIV-2 RF

MVirgilio

AHowell, RGN-IV OGC

ARM/LFMB

TBergman

George F. Dick, Jr., Senior Project Manager Project Directorate IV-2 Division of Reactor Projects - III/IV/V Office of Nuclear Reactor Regulation

GHill (8)

PDIV-2 PF

ACRS (10)

GDick (2)

TDunning

CGrimes

EPeyton

Wanda Jones

Enclosures:

- 1. Amendment No. 36 to NPF-76
- 2. Amendment No. 27 to NPF-80
- 3. Safety Evaluation

cc w/enclosures: See next page

9205210195 920506 PDR ADDCK 05000498 P PDR PDR

<u>NRC FILE CENTER COPY</u>

OFFIC	E PDIV-2/LA	PDIV-2/PM	PDIV-2/	OGC M7	PDIV-200	
NAME	EPeyton	GDick:nbh h	SFTanders	MZOBLAR	SBlack	
DATE	4/15/92	4//6/92	4/15/92	4/27/92	514/92] ^'i/

cc w/enclosures: Mr. J. Tapia Senior Resident Inspector U.S. Nuclear Regulatory Commission P.O. Box 910 Bay City, Texas 77414

Mr. J. C. Lanier/M. B. Lee City of Austin Electric Utility Department P. O. Box 1088 Austin, Texas 78767

Mr. K. J. Fiedler Mr. M. T. Hardt City Public Service Board P. O. Box 1771 San Antonio, Texas 78296

Mr. D. E. Ward Mr. T. M. Puckett Central Power and Light Company P. O. Box 2121 Corpus Christi, Texas 78403

INPO Records Center 1100 Circle 75 Parkway Atlanta, Georgia 30339-3064

Regional Administrator, Region IV U.S. Nuclear Regulatory Commission 611 Ryan Plaza Drive, Suite 1000 Arlington, Texas 76011

Mr. Joseph M. Hendrie 50 Bellport Lane Bellport, New York 11713

Judge, Matagorda County Matagorda County Courthouse 1700 Seventh Street Bay City, Texas 77414

Mr. William J. Jump Manager, Nuclear Licensing Houston Lighting & Power Company P. O. Box 289 Wadsworth, Texas 77483 Jack R. Newman, Esq. Newman & Holtzinger, P.C. 1615 L Street, N.W. Washington, D.C. 20036

Licensing Representative Houston Lighting and Power Company Suite 610 Three Metro Center Bethesda, Maryland 20814

Bureau of Radiation Control State of Texas 1101 West 49th Street Austin, Texas 78756

Rufus S. Scott Associate General Counsel Houston Lighting & Power Company P. O. Box 61867 Houston, Texas 77208



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

HOUSTON LIGHTING & POWER COMPANY

CITY PUBLIC SERVICE BOARD OF SAN ANTONIO

CENTRAL POWER AND LIGHT COMPANY

CITY OF AUSTIN, TEXAS

DOCKET NO. 50-498

SOUTH TEXAS PROJECT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 36 License No. NPF-76

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Houston Lighting & Power Company^{*} (HL&P) acting on behalf of itself and for the City Public Service Board of San Antonio (CPS), Central Power and Light Company (CPL), and City of Austin, Texas (COA) (the licensees) dated August 23, 1991, as supplemented by letter dated January 24, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

^{*} Houston Lighting & Power Company is authorized to act for the City Public Service Board of San Antonio, Central Power and Light Company and City of Austin, Texas and has exclusive responsibility and control over the physical construction, operation and maintenance of the facility.

- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. NPF-76 is hereby amended to read as follows:
 - 2. <u>Technical Specifications</u>

The Technical Specifications contained in Appendix A, as revised through Amendment No. 36 , and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective as of its date of issuance and to be implemented within 7 days of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Suzanne C. Black

Suzanne C. Black, Director Project Directorate IV-2 Division of Reactor Projects - III/IV/V Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: May 6, 1992



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

HOUSTON LIGHTING & POWER COMPANY

CITY PUBLIC SERVICE BOARD OF SAN ANTONIO

CENTRAL POWER AND LIGHT COMPANY

CITY OF AUSTIN, TEXAS

DOCKET NO. 50-499

SOUTH TEXAS PROJECT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 27 License No. NPF-80

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Houston Lighting & Power Company^{*} (HL&P) acting on behalf of itself and for the City Public Service Board of San Antonio (CPS), Central Power and Light Company (CPL), and City of Austin, Texas (COA) (the licensees) dated August 23, 1991, as supplemented by letter dated January 24, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

^{*} Houston Lighting & Power Company is authorized to act for the City Public Service Board of San Antonio, Central Power and Light Company and City of Austin, Texas and has exclusive responsibility and control over the physical construction, operation and maintenance of the facility.

- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. NPF-80 is hereby amended to read as follows:
 - 2. <u>Technical Specifications</u>

The Technical Specifications contained in Appendix A, as revised through Amendment No. 27, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective as of its date of issuance and to be implemented within 7 days of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Insprare C. Black

Suzanne C. Black, Director Project Directorate IV-2 Division of Reactor Projects - III/IV/V Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: May 6, 1992

ATTACHMENT TO LICENSE AMENDMENT NOS. 36 AND 27

FACILITY OPERATING LICENSE NOS. NPF-76 AND NPF-80

DOCKET NOS. 50-498 AND 50-499

Replace the following pages of the Appendix A Technical Specifications with the attached pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change. The corresponding overleaf pages are also provided to maintain document completeness.

REMOVE	<u>INSERT</u>
viii	viii
3/4 4-31	3/4 4-31
3/4 4-34	
B 3/4 4-8	B 3/4 4-8
B 3/4 4-15	B 3/4 4-15
B 3/4 4-15	B 3/4 4-

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

SECTION	
3/4.4 REACTOR COOLANT SYSTEM	PAGE
3/4.4.1 REACTOR COOLANT LOOPS AND COOLANT CIRCULATION	
Startup and Power Operation Hot Standby Hot Shutdown Cold Shutdown - Loops Filled Cold Shutdown - Loops Not Filled	3/4 4-1 3/4 4-2 3/4 4-3 3/4 4-5
3/4.4.2 SAFETY VALVES	3/4 4-6
Shutdown Operating	3/4 4-7 3/4 4-8
3/4.4.3 PRESSURIZER	3/4 4-9
3/4.4.4 RELIEF VALVES	3/4 4-10
	3/4 4-12
DURING INSERVICE INSPECTION	2/1 1-17
TABLE 4.4-2 STEAM GENERATOR TUBE INSPECTION.	3/4 4-1/
3/4.4.6 REACTOR COOLANT SYSTEM LEAKAGE	3/4 4-10
Leakage Detection Systems Operational Leakage	3/4 4-19 3/4 4-20
TABLE 3.4-1 REACTOR COOLANT SYSTEM PRESSURE ISOLATION VALVES	3/4 4-22
3/4.4.7 CHEMISTRY	3/4 4-23
TABLE 3.4-2 REACTOR COOLANT SYSTEM CHEMISTRY LIMITS	3/4 4-24
TABLE 4.4-3 REACTOR COOLANT SYSTEM CHEMISTRY LIMITS SURVEILLANCE	
3/4.4.8 SPECIFIC ACTIVITY	3/4 4-25
FIGURE 3. 4-1 DOSE FOUTVALENT T-121 DEACTOR COOL ANT CREATER	3/4 4-26
ACTIVITY LIMIT VERSUS PERCENT OF RATED THERMAL POWER WITH THE REACTOR COOLANT SPECIFIC ACTIVITY >1 µCi/gram	
TABLE A 4-A PEACTOR COLLANT OFFICIETO ACTIVITY AND A	3/4 4-28
PROGRAM.	3/4 4-29
3/4.4.9 PRESSURE/TEMPERATURE LIMITS	5/7 7 63
Reactor Coolant System	3/4 4-31
FIGURE 3.4-2 REACTOR COOLANT SYSTEM HEATUP LIMITATIONS -	
APPLICABLE UP 10 32 EFPY	3/4 4-32

<u>INDEX</u>

.

LIMITING COND	ITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENT	S
<u>SECTION</u>		<u>PAGE</u>
FIGURE 3.4-3	REACTOR COOLANT SYSTEM COOLDOWN LIMITATIONS - APPLICABLE UP TO 32 EFPY	3/4 4-33
TABLE 4.4-5	(This table number not used)	3/4 4-34
	Pressurizer	3/4 4-35
	Overpressure Protection Systems	3/4 4-36
FIGURE 3.4-4	NOMINAL MAXIMUM ALLOWABLE PORV SETPOINT FOR THE COLD OVERPRESSURE SYSTEM	3/4 4-38
3/4.4.10	STRUCTURAL INTEGRITY	3/4 4-39
3/4.4.11	REACTOR VESSEL HEAD VENTS	3/4 4-40
3/4.5 EMERGE	NCY CORE COOLING SYSTEMS	
3/4.5.1	ACCUMULATORS	3/4 5-1
3/4.5.2	ECCS SUBSYSTEMS – T_{avg} GREATER THAN OR EQUAL	3/4 5-3
3/4 5 3	ECCS SUBSYSTEMS – T \downarrow LESS THAN 350°E	3/4 5-6
571.0.0	ECCS SUBSYSTEMS – T_{avg} LESS THAN OR EQUAL	5/4 J=0
0 / A F A		3/4 5-8
3/4.5.4	(Inis specification number is not used)	3/4 5-9
3/4.5.5	REFUELING WATER STORAGE TANK	3/4 5-10
3/4.5.6	RESIDUAL HEAT REMUVAL (RHR) SYSTEM	3/4 5-11
3/4.6 LUNIAI	NMENI SYSTEMS	
3/4.6.1	PRIMARY CONTAINMENT	
	Containment Integrity	3/4 6-1
	Lontainment Leakage	3/4 6-2
	Containment Air Locks	3/4 6-5
	Internal Pressure	3/4 6-7
	Air Temperature	3/4 6-8
	Containment Structural Integrity	3/4 6-9
	Containment Ventilation System	3/4 6-12
3/4.6.2	DEPRESSURIZATION AND COOLING SYSTEMS	
	Containment Spray System	3/4 6-14
	Spray Additive System	3/4 6-15
	Containment Cooling System	3/4 6-17

SOUTH TEXAS - UNITS 1 & 2 viii

ii

Unit 1 - Amendment No. 36 Unit 2 - Amendment No. 27

3/4.4.9 PRESSURE/TEMPERATURE LIMITS

REACTOR COOLANT SYSTEM

LIMITING CONDITION FOR OPERATION

3.4.9.1 The Reactor Coolant System (except the pressurizer) temperature and pressure shall be limited in accordance with the limit lines shown on Figures 3.4-2 and 3.4-3 during heatup, cooldown, criticality, and inservice leak and hydrostatic testing with:

- a. A maximum heatup of 100°F in any 1-hour period,
- b. A maximum cooldown of 100°F in any 1-hour period, and
- c. A maximum temperature change of less than or equal to 10°F in any 1hour period during inservice hydrostatic and leak testing operations above the heatup and cooldown limit curves.

APPLICABILITY: At all times.

ACTION:

With any of the above limits exceeded, restore the temperature and/or pressure to within the limit within 30 minutes; perform an engineering evaluation to determine the effects of the out-of-limit condition on the structural integrity of the Reactor Coolant System; determine that the Reactor Coolant System remains acceptable for continued operation or be in at least HOT STANDBY within the next 6 hours and reduce the RCS T_{avg} and pressure to less than 200°F and 500 psig, respectively, within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.4.9.1.1 The Reactor Coolant System temperature and pressure shall be determined to be within the limits at least once per 30 minutes during system heatup, cooldown, and inservice leak and hydrostatic testing conditions.

4.4.9.1.2 The reactor vessel material irradiation surveillance specimens shall be removed and examined, to determine changes in material properties, as required by 10 CFR Part 50, Appendix H. The results of these examinations shall be used to update Figures 3.4-2 and 3.4-3.

SOUTH TE	EXAS –	UNITS	1 &	2	3

3/4 4-31

Unit 1 - Amendment No. 36 Unit 2 - Amendment No. 27

MATERIAL PROPERTY BASIS

CONTROLLING MATERIAL - RV INTERMEDIATE SHELL R-1606-3 COPPER CONTENT: CONSERVATIVELY ASSUMED AS 0.10 WT%

RT_{NDT} INITIAL: 10°F RT_{NDT} AFTER 32 EFPY 1/4, 91°F 3/4T, 64°F

CURVE APPLICABLE FOR HEATUP RATES UP TO 100"/HR FOR THE SERVICE PERIOD UP TO 32 EFPY AND CONTAINS MARGINS OF 10"F AND 60 PSIG FOR POSSIBLE INSTRUMENT ERRORS



FIGURE 3.4-2

REACTOR COOLANT SYSTEM HEATUP LIMITATIONS - APPLICABLE UP TO 32 EFPY

SOUTH TEXAS - UNITS 1 & 2

MATERIAL PROPERTY BASIS

5.1

CONTROLLING MATERIAL - RV INTERMEDIATE SHELL R-1606-3 COPPER CONTENTS: CONSERVATIVELY ASSUMED AS 0.10 WTX RT_{NDT} INITIAL: 10°F RT_{NDT} AFTER 32 EFPY 1/4, 91°F 3/4T, 64°F

SINGLE CURVE APPLICABLE FOR COOLDOWN RATES UP TO 100°/HR FOR THE SERVICE PERIOD UP TO 32 EFPY. AND CONTAINS MARGINS OF 10°F AND 60 PSIG FOR POSSIBLE INSTRUMENT ERRORS



FIGURE 3.4-3

REACTOR COOLANT SYSTEM COOLDOWN LIMITATIONS - APPLICABLE UP TO 32 EFPY

SOUTH TEXAS - UNITS 1 & 2

(This table number not used)

SOUTH TEXAS - UNITS 1 & 2 3/4 4-34

.

Unit 1 - Amendment No. 36 Unit 2 - Amendment No. 27

BASES

PRESSURE TEMPERATURE LIMITS (Continued)

- a. Allowable combinations of pressure and temperature for specific temperature change rates are below and to the right of the limit lines shown. Limit lines for cooldown rates between those presented may be obtained by interpolation; and
- b. Figures 3.4-2 and 3.4-3 define limits to assure prevention of non-ductile failure only. For normal operation, other inherent plant characteristics, e.g., pump heat addition and pressurizer heater capacity, may limit the heatup and cooldown rates that can be achieved over certain pressure-temperature ranges.
- These limit lines shall be calculated periodically using methods provided below,
- 3. The secondary side of the steam generator must not be pressurized above 200 psig if the temperature of the steam generator is below 70°F,
- 4. The pressurizer heatup and cooldown rates shall not exceed 100°F/h and 200°F/h, respectively. The spray shall not be used if the temperature difference between the pressurizer and the spray fluid is greater than 621°F, and
- 5. System preservice hydrotests and inservice leak and hydrotests shall be performed at pressures in accordance with the requirements of ASME Boiler and Pressure Vessel Code, Section XI.

The fracture toughness properties of the ferritic materials in the reactor vessel are determined in accordance with the NRC Standard Review Plan, ASTM E185-73, and in accordance with additional reactor vessel requirements. These properties are then evaluated in accordance with Appendix G of the 1976 Summer Addenda to Section III of the ASME Boiler and Pressure Vessel Code and the calculation methods described in WCAP-7924-A, "Basis for Heatup and Cooldown Limit Curves," April 1975.

Heatup and cooldown limit curves are calculated using the most limiting value of the nil-ductility reference temperature, RT_{NDT} , at the end of 32 effective full power years (EFPY) of service life. The 32 EFPY service life period is chosen such that the limiting RT_{NDT} at the 1/4T location in the core region is greater than the RT_{NDT} of the limiting unirradiated material. The selection of such a limiting RT_{NDT} assures that all components in the Reactor Coolant System will be operated conservatively in accordance with applicable Code requirements.

The reactor vessel materials have been tested to determine their initial RT_{NDT} ; the results of these tests are shown in Tables B 3/4.4-la and B 3/4.4-lb. Reactor operation and resultant fast neutron (E greater than 1 MeV) irradiation

I

BASES

PRESSURE/TEMPERATURE LIMITS (Continued)

can cause an increase in the RT_{NDT} . Therefore, an adjusted reference temperature, based upon the fluence, copper content, and phosphorus content of the material in question, can be predicted using Figure B 3/4.4-1 and the value of ΔRT_{NDT} computed by Regulatory Guide 1.99, Revision 1, "Effects of Residual Elements on Predicted Radiation Damage to Reactor Vessel Materials." The heatup and cooldown limit curves of Figures 3.4-2 and 3.4-3 include predicted adjustments for this shift in RT_{NDT} at the end of 32 EFPY as well as adjustments for possible errors in the pressure and temperature sensing instruments.

Values of ΔRT_{NDT} determined in this manner may be used until the results from the material surveillance program, evaluated according to ASTM E185, are available. Capsules will be removed in accordance with the requirements of ASTM E185-73 and 10 CFR Part 50, Appendix H. The results obtained from the surveillance specimens can be used to predict future radiation damage to the reactor vessel material by using the lead factor and the withdrawal time of the capsule. The heatup and cooldown curves must be recalculated when the ΔRT_{NDT} determined from the surveillance capsule exceeds the calculated ΔRT_{NDT} for the equivalent capsule radiation exposure.

Allowable pressure-temperature relationships for various heatup and cooldown rates are calculated using methods derived from Appendix G in Section III of the ASME Boiler and Pressure Vessel Code as required by Appendix G to 10 CFR Part 50, and these methods are discussed in detail in WCAP-7924-A.

The general method for calculating heatup and cooldown limit curves is based upon the principles of the linear elastic fracture mechanics (LEFM) technology. In the calculation procedures a semielliptical surface defect with a depth of one-quarter of the wall thickness, T, and a length of 3/2T is assumed to exist at the inside of the vessel wall as well as at the outside of the vessel wall. The dimensions of this postulated crack, referred to in Appendix G of ASME Section III as the reference flaw, amply exceed the current capabilities of inservice inspection techniques. Therefore, the reactor operation limit curves developed for this reference crack are conservative and provide sufficient safety margins for protection against nonductile failure. To assure that the radiation embrittlement effects are accounted for in the calculation of the limit curves, the most limiting value of the nil-ductility reference temperature, RT_{MDT} , is used and this includes the radiation-induced shift, ΔRT_{NDT} , corresponding to the end of the period for which heatup and cooldown curves are generated.

The ASME approach for calculating the allowable limit curves for various heatup and cooldown rates specifies that the total stress intensity factor, K_I , for the combined thermal and pressure stresses at any time during heatup or cooldown cannot be greater than the reference stress intensity factor, K_{IR} , for the metal temperature at that time. K_{IR} is obtained from the reference

SOUTH TEXAS - UNITS 1 & 2

B 3/4 4-8

Unit 1 - Amendment No. 36 Unit 2 - Amendment No. 27

BASES

LOW TEMPERATURE OVERPRESSURE PROTECTION (Continued)

overshoot beyond the PORV Setpoint which can occur as a result of time delays in signal processing and valve opening, instrument uncertainties, and single failure. To ensure that mass and heat input transients more severe than those assumed cannot occur, Technical Specifications require lockout of all high head safety injection pumps while in MODE 5 and MODE 6 with the reactor vessel head on. All but one high head safety injection pump are required to be locked out in MODE 4. Technical Specifications also require lockout of the positive displacement pump and all but one charging pump while in MODES 4, 5, and 6 with the reactor vessel head installed and disallow start of an RCP if secondary temperature is more than 50°F above primary temperature.

The Maximum Allowed PORV Setpoint for the COMS will be updated based on the results of examinations of reactor vessel material irradiation surveillance specimens performed as required by 10 CFR Part 50, Appendix H.

3/4.4.10 STRUCTURAL INTEGRITY

The inservice inspection and testing programs for ASME Code Class 1, 2, and 3 components ensure that the structural integrity and operational readiness of these components will be maintained at an acceptable level throughout the life of the plant. These programs are in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR 50.55a(g) except where specific written relief has been granted by the Commission pursuant to 10 CFR 50.55a(g)(6)(i).

Components of the Reactor Coolant System were designed to provide access to permit inservice inspections in accordance with Section XI of the ASME Boiler and Pressure Vessel Code, 1974 Edition and Addenda through Winter 1975.

3/4.4.11 REACTOR VESSEL HEAD VENTS

Reactor vessel head vents are provided to exhaust noncondensible gases and/or steam from the Reactor Coolant System that could inhibit natural circulation core cooling. The OPERABILITY of at least two reactor vessel head vent paths ensures that the capability exists to perform this function.

The valve redundancy of the reactor vessel head vent paths serves to minimize the probability of inadvertent or irreversible actuation while ensuring that a single failure of a vent valve, power supply, or control system does not prevent isolation of the vent path.

The function, capabilities, and testing requirements of the reactor vessel head vents are consistent with the requirements of Item II.B.1 of NUREG-0737, "Clarification of TMI Action Plan Requirements," November 1980.



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NOS. 36 AND 27 TO

FACILITY OPERATING LICENSE NOS. NPF-76 AND NPF-80

HOUSTON LIGHTING & POWER COMPANY

CITY PUBLIC SERVICE BOARD OF SAN ANTONIO

CENTRAL POWER AND LIGHT COMPANY

CITY OF AUSTIN, TEXAS

DOCKET NOS. 50-498 AND 50-499

SOUTH TEXAS PROJECT, UNITS 1 AND 2

1.0 INTRODUCTION

By application dated August 23, 1991 (ST-HL-AE-3844), Houston Lighting & Power Company, et.al., (the licensee) requested changes to the Technical Specifications (TS) (Appendix A to Facility Operating License Nos. NPF-76 and NPF-80) for the South Texas Project, Units 1 and 2. The proposed changes would remove TS Table 4.4-5 providing the schedule for reactor vessel material specimen withdrawal. Guidance on the proposed TS change was provided by Generic Letter 91-01, "Removal of the Schedule for the Withdrawal of Reactor Vessel Material Specimens from Technical Specifications," of January 4, 1990. The licensee's January 24, 1992, letter requested a 7-day implementation period following the date of issuance of the license amendments.

2.0 EVALUATION

Technical Specification 3/4.4.9, "Pressure/Temperature Limits" contains a Limiting Condition for Operation for the reactor coolant system (RCS) that limits the rate of change in temperature and pressure to values consistent with the fracture toughness requirements of the American Society of Mechanical Engineers (ASME) Code and Appendix G to Part 50 of Title 10 of the Code of Federal Regulations (10 CFR Part 50). Changes in the values of these limits are necessary because the fracture toughness properties of ferritic materials in the reactor vessel change as a function of the reactor operating time (neutron fluence).

For this reason, the TS include a Surveillance Requirement, TS 4.4.9.1.2, to require the removal and examination of the irradiated specimens of reactor vessel material. The licensee examines the specimens to determine the changes

in material properties in accordance with the requirements of Appendix H to 10 CFR Part 50. Table 4.4-5 identifies the material specimens and specifies the schedule for removal of each specimen.

The removal of the schedule for withdrawing material specimens from the TS will eliminate the necessity of a license amendment to make changes to this schedule. However, Section I.B.3 of Appendix H to 10 CFR Part 50 requires the submittal of a proposed withdrawal schedule for material specimens to the U.S. Nuclear Regulatory Commission (NRC) and approval by the NRC before implementation. Hence, adequate regulatory controls exist to control changes to this schedule without the necessity of subjecting it to the license amendment process by including it in TS.

The licensee has provided a commitment to include this schedule in the next revision of the Updated Safety Analysis Report (USAR). In addition, the licensee will include any subsequent NRC-approved revisions to this schedule in an update of the USAR. The inclusion of the withdrawal schedule in the USAR provides a source for this information that is readily available as a reference for NRC inspectors and other staff use. Finally, the surveillance requirements for removing material specimens and the bases section for this specification remain unchanged except for the removal of the reference to Table 4.4-5.

The licensee has proposed a change to TS 4.4.9.2 that is consistent with the guidance provided in Generic Letter 91-01 for the removal of Table 4.4-5 from the TS. The NRC has reviewed this matter and finds that the proposed changes to the TS for South Texas Projects, Units 1 and 2 are acceptable.

3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Texas State official was notified of the proposed issuance of the amendment. The State official had no comments.

4.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and changes surveillance requirements. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant on such finding (57 FR 9445). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: Scott Flanders, PDIV-2/NRR Thomas Dunning, OTSB/NRR

Date: May 6, 1992