

Docket Nos. 50-498
and 50-499

November 24, 1992

Mr. Donald P. Hall
Group Vice-President, Nuclear
Houston Lighting & Power Company
P. O. Box 1700
Houston, Texas 77251

Dear Mr. Hall:

SUBJECT: ISSUANCE OF AMENDMENT NOS. 46 AND 35 TO FACILITY OPERATING
LICENSE NOS. NPF-76 AND NPF-80 - SOUTH TEXAS PROJECT, UNITS 1 AND 2
(TAC NOS. M77927 AND M77928)

The Commission has issued the enclosed Amendment Nos. 46 and 35 to Facility Operating License Nos. NPF-76 and NPF-80 for the South Texas Project, Units 1 and 2. The amendments consist of changes to the Technical Specifications (TSs) in response to your application dated October 12, 1990, as supplemented by letter dated January 24, 1991; and superseded by letters dated October 25, 1991 and June 16, 1992.

The amendments change the Appendix A Technical Specifications by deleting Table 5.7-1 (Component Cycle or Transient Limits). Cyclic/transient occurrences identified in the Updated Final Safety Analysis Report, Table 3.9-8, which include those components listed in TS Table 5.7-1, would be tracked through administrative procedures. The change is intended to resolve discrepancies between Table 5.7-1 and the Updated Final Safety Analysis Report which were previously identified by the staff during the 1988 review of the South Texas Project draft Technical Specifications.

A copy of our related Safety Evaluation is enclosed. The Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

Original Signed By

George F. Dick, Jr., Senior Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

9212110156 921124
PDR ADOCK 05000498
PDR

Enclosures:

1. Amendment No. 46 to NPF-76
2. Amendment No. 35 to NPF-80
3. Safety Evaluation

cc w/enclosures:

See next page 090011

FOR THE COMMISSION COPY

OFFICE	PDIV-2/LA	PDIV-2/PM	OGC - NLO	PDIV-2/D	
NAME	EPeyton	GDick:nb	MZOBLEW	SBlack	
DATE	11/4/92	11/13/92	11/19/92	11/20/92	

Document Name: M77927&.GD;
c:\wp\stp

one minor
correction

AFD/11

Mr. Donald P. Hall

- 2 -

November 24, 1992

cc w/enclosures:

Mr. J. Tapia
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 910
Bay City, Texas 77414

Mr. J. C. Lanier/M. B. Lee
City of Austin
Electric Utility Department
P. O. Box 1088
Austin, Texas 78767

Mr. K. J. Fiedler
Mr. M. T. Hardt
City Public Service Board
P. O. Box 1771
San Antonio, Texas 78296

Mr. D. E. Ward
Mr. T. M. Puckett
Central Power and Light Company
P. O. Box 2121
Corpus Christi, Texas 78403

INPO
Records Center
1100 Circle 75 Parkway
Atlanta, Georgia 30339-3064

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Mr. Joseph M. Hendrie
50 Bellport Lane
Bellport, New York 11713

Judge, Matagorda County
Matagorda County Courthouse
1700 Seventh Street
Bay City, Texas 77414

Mr. William J. Jump
Manager, Nuclear Licensing
Houston Lighting and Power Company
P. O. Box 289
Wadsworth, Texas 77483

Jack R. Newman, Esq.
Newman & Holtzinger, P.C.
1615 L Street, N.W.
Washington, D.C. 20036

Licensing Representative
Houston Lighting and Power Company
Suite 610
Three Metro Center
Bethesda, Maryland 20814

Bureau of Radiation Control
State of Texas
1101 West 49th Street
Austin, Texas 78756

Rufus S. Scott
Associate General Counsel
Houston Lighting and Power Company
P. O. Box 61867
Houston, Texas 77208

Mr. Donald P. Hall

- 3 -

November 24, 1992

DISTRIBUTION:

Docket File
NRC/PDR
Local PDR
PDIV-2 Reading File
JRoe
MVirgilio
EPeyton
GDick (2)
OPA
GHill (8)
Wanda Jones
CGrimes
PDIV-2 Plant File
ACRS (10)
OC/LFMB
AHowell, RGN-IV
DHagan
OGC
MMcBrearty



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

HOUSTON LIGHTING & POWER COMPANY
CITY PUBLIC SERVICE BOARD OF SAN ANTONIO
CENTRAL POWER AND LIGHT COMPANY
CITY OF AUSTIN, TEXAS
DOCKET NO. 50-498
SOUTH TEXAS PROJECT, UNIT 1
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 46
License No. NPF-76

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Houston Lighting & Power Company* (HL&P) acting on behalf of itself and for the City Public Service Board of San Antonio (CPS), Central Power and Light Company (CPL), and City of Austin, Texas (COA) (the licensees) dated June 16, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

* Houston Lighting & Power Company is authorized to act for the City Public Service Board of San Antonio, Central Power and Light Company and City of Austin, Texas and has exclusive responsibility and control over the physical construction, operation and maintenance of the facility.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. NPF-76 is hereby amended to read as follows:

2. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 46, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective as of its date of issuance to be implemented within 7 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Suzanne C. Black, Director
Project Directorate IV-2
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: November 24, 1992



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

HOUSTON LIGHTING & POWER COMPANY
CITY PUBLIC SERVICE BOARD OF SAN ANTONIO
CENTRAL POWER AND LIGHT COMPANY
CITY OF AUSTIN, TEXAS
DOCKET NO. 50-499
SOUTH TEXAS PROJECT, UNIT 2
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 35
License No. NPF-80

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Houston Lighting & Power Company* (HL&P) acting on behalf of itself and for the City Public Service Board of San Antonio (CPS), Central Power and Light Company (CPL), and City of Austin, Texas (COA) (the licensees) dated June 16, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

* Houston Lighting & Power Company is authorized to act for the City Public Service Board of San Antonio, Central Power and Light Company and City of Austin, Texas and has exclusive responsibility and control over the physical construction, operation and maintenance of the facility.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. NPF-80 is hereby amended to read as follows:

2. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 35, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective as of its date of issuance to be implemented within 7 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

for *S. C. Black*
Suzanne C. Black, Director
Project Directorate IV-2
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: November 24, 1992

ATTACHMENT TO LICENSE AMENDMENT NOS. 46 AND 35

FACILITY OPERATING LICENSE NOS. NPF-76 AND NPF-80

DOCKET NOS. 50-498 AND 50-499

Replace the following pages of the Appendix A Technical Specifications with the attached pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change. The corresponding overleaf pages are also provided to maintain document completeness.

REMOVE

xvii
5-16
5-17
6-16

6-21

INSERT

xvii
5-16

6-16
6-16a
6-21

INDEX

DESIGN FEATURES

<u>SECTION</u>	<u>PAGE</u>
<u>5.1 SITE</u>	
5.1.1 EXCLUSION AREA	5-1
5.1.2 LOW POPULATION ZONE	5-1
5.1.3 MAP DEFINING UNRESTRICTED AREAS AND SITE BOUNDARY FOR RADIOACTIVE GASEOUS AND LIQUID EFFLUENTS	5-1
<u>5.2 CONTAINMENT</u>	
5.2.1 CONFIGURATION	5-1
5.2.2 DESIGN PRESSURE AND TEMPERATURE	5-1
FIGURE 5.1-1 EXCLUSION AREA	5-2
FIGURE 5.1-2 LOW POPULATION ZONE	5-3
FIGURE 5.1-3 UNRESTRICTED AREA AND SITE BOUNDARY FOR RADIOACTIVE GASEOUS EFFLUENTS	5-4
FIGURE 5.1-4 UNRESTRICTED AREA AND SITE BOUNDARY FOR RADIOACTIVE LIQUID EFFLUENTS	5-5
<u>5.3 REACTOR CORE</u>	
5.3.1 FUEL ASSEMBLIES	5-6
5.3.2 CONTROL ROD ASSEMBLIES	5-6
<u>5.4 REACTOR COOLANT SYSTEM</u>	
5.4.1 DESIGN PRESSURE AND TEMPERATURE	5-6
5.4.2 VOLUME	5-6
<u>5.5 METEOROLOGICAL TOWER LOCATION</u>	
<u>5.6 FUEL STORAGE</u>	
5.6.1 CRITICALITY	5-6
5.6.2 DRAINAGE	5-9
5.6.3 CAPACITY	5-9
FIGURE 5.6.1 MINIMUM BURNUP FOR CATEGORY 2 FUEL	5-10
FIGURE 5.6-2 MINIMUM IFBA CONTENT FOR CATEGORY 3 FUEL	5-11
FIGURE 5.6-3 MINIMUM BURNUP FOR CATEGORY 3 FUEL	5-12
FIGURE 5.6-4 MINIMUM BURNUP FOR CATEGORY 4 FUEL	5-13
FIGURE 5.6-5 REGION 1 CLOSE PACKED AND CHECKERBOARD FUEL STORAGE	5-14
FIGURE 5.6-6 REGION 2 CLOSE PACKED AND CHECKERBOARD FUEL STORAGE	5-15
<u>5.7 COMPONENT CYCLIC OR TRANSIENT LIMIT</u>	
	5-16

INDEX

ADMINISTRATIVE CONTROLS

<u>SECTION</u>	<u>PAGE</u>
<u>6.1 RESPONSIBILITY</u>	6-1
<u>6.2 ORGANIZATION</u>	
6.2.1 OFFSITE AND ONSITE ORGANIZATIONS.....	6-1
6.2.2 UNIT STAFF.....	6-1
TABLE 6.2-1 MINIMUM SHIFT CREW COMPOSITION-TWO UNITS WITH TWO SEPARATE CONTROL ROOMS.....	6-4
6.2.3 INDEPENDENT SAFETY ENGINEERING GROUP (ISEG)	
Function.....	6-6
Composition.....	6-6
Responsibilities.....	6-6
Records.....	6-5
6.2.4 SHIFT TECHNICAL ADVISOR.....	6-6
<u>6.3 (Not Used)</u>	
<u>6.4 TRAINING</u>	6-7
<u>6.5 REVIEW AND AUDIT</u>	6-7
6.5.1 PLANT OPERATIONS REVIEW COMMITTEE (PORC)	
Function.....	6-7
Composition.....	6-7
Alternates.....	6-7
Meeting Frequency.....	6-7
Quorum.....	6-7
Responsibilities.....	6-8
Records.....	6-9

Region 2 Close Packed and Checkerboard Fuel Storage




Figure 5.6-6

DESIGN FEATURES

5.7 COMPONENT CYCLIC OR TRANSIENT LIMIT

5.7.1 The components of the reactor coolant system are designed and shall be maintained within limits addressed in the Component Cyclic and Transient Limit Program as required by specification 6.8.3f.

ADMINISTRATIVE CONTROLS

PROCEDURES AND PROGRAMS (Continued)

- 1) Preventive maintenance and periodic visual inspection requirements, and
- 2) Integrated leak test requirements for each system at refueling cycle intervals or less.

b. In-Plant Radiation Monitoring

A program which will ensure the capability to accurately determine the airborne iodine concentration in vital areas under accident conditions. This program shall include the following:

- 1) Training of personnel,
- 2) Procedures for monitoring, and
- 3) Provisions for maintenance of sampling and analysis equipment.

c. Secondary Water Chemistry

A program for monitoring of secondary water chemistry to inhibit steam generator tube degradation. This program shall include:

- 1) Identification of a sampling schedule for the critical variables and control points for these variables,
- 2) Identification of the procedures used to measure the values of the critical variables,
- 3) Identification of process sampling points, which shall include monitoring the discharge of the condensate pumps for evidence of condenser in-leakage,
- 4) Procedures for the recording and management of data,
- 5) Procedures defining corrective actions for all off-control point chemistry conditions, and
- 6) A procedure identifying: (a) the authority responsible for the interpretation of the data, and (b) the sequence and timing of administrative events required to initiate corrective action.

d. Post-Accident Sampling

A program which will ensure the capability to obtain and analyze reactor coolant, radioactive iodines and particulates in plant gaseous effluents, and containment atmosphere samples under accident conditions. The program shall include the following:

- 1) Training of personnel,
- 2) Procedures for sampling and analysis, and
- 3) Provisions for maintenance of sampling and analysis equipment.

ADMINISTRATIVE CONTROLS

PROCEDURES AND PROGRAMS (Continued)

e. Accident Monitoring Instrumentation

A program which will ensure the capability to monitor plant variables and systems operating status during and following an accident. This program shall include those instruments provided to indicate system operating status and furnish information regarding the release of radioactive materials (Category 2 and 3 instrumentation as defined in Regulatory Guide 1.97, Revision 2) and provide the following:

- 1) Preventive maintenance and periodic surveillance of instrumentation,
- 2) Pre-planned operating procedures and backup instrumentation to be used if one or more monitoring instruments become inoperable, and
- 3) Administrative procedures for returning inoperable instruments to OPERABLE status as soon as practicable.

f. Component Cyclic or Transient Limit

The Component Cyclic and Transient Limit Program provides controls to track cyclic/transient plant conditions to assure that the cumulative fatigue usage factor does not exceed 1.0 for those components for which fatigue analysis was performed in accordance with Section III of the American Society of Mechanical Engineers Boiler and Pressure Vessel Code. The cyclic and transient limits used in the design are identified in the Updated Final Safety Analysis Report.

6.9 REPORTING REQUIREMENTS

ROUTINE REPORTS

6.9.1 In addition to the applicable reporting requirements of Title 10, Code of Federal Regulations, the following reports shall be submitted to the Regional Administrator of the Regional Office of the NRC unless otherwise noted.

STARTUP REPORT

6.9.1.1 A summary report of plant startup and power escalation testing shall be submitted following: (1) receipt of an Operating License, (2) amendment to the license involving a planned increase in power level, (3) installation of fuel that has a different design or has been manufactured by a different fuel supplier, and (4) modifications that may have significantly altered the nuclear, thermal, or hydraulic performance of the unit.

ADMINISTRATIVE CONTROLS

STARTUP REPORT (Continued)

The Startup Report shall address each of the tests identified in the Final Safety Analysis Report and shall include a description of the measured values of the operating conditions or characteristics obtained during the test program and a comparison of these values with design predictions and specifications. Any corrective actions that were required to obtain satisfactory operation shall also be described. Any additional specific details required in license conditions based on other commitments shall be included in this report.

Startup Reports shall be submitted within: (1) 90 days following completion of the Startup Test Program, (2) 90 days following resumption or commencement of commercial power operation, or (3) 9 months following initial criticality, whichever is earliest. If the Startup Report does not cover all three events (i.e., initial criticality, completion of Startup Test Program, and resumption or commencement of commercial operation), supplementary reports shall be submitted at least every 3 months until all three events have been completed.

ADMINISTRATIVE CONTROLS

6.10 RECORD RETENTION

6.10.1 In addition to the applicable record retention requirements of Title 10, Code of Federal Regulations, the following records shall be retained for at least the minimum period indicated.

6.10.2 The following records shall be retained for at least 5 years:

- a. Records and logs of unit operation covering time interval at each power level;
- b. Records and logs of principal maintenance activities, inspections, repair, and replacement of principal items of equipment related to nuclear safety;
- c. ALL REPORTABLE EVENTS;
- d. Records of surveillance activities, inspections, and calibrations required by these Technical Specifications;
- e. Records of changes made to the procedures required by Specification 6.8.1;
- f. Records of radioactive shipments;
- g. Records of sealed source and fission detector leak tests and results; and
- h. Records of annual physical inventory of all sealed source material of record.

6.10.3 The following records shall be retained for the duration of the unit Operating License:

- a. Records and drawing changes reflecting unit design modifications made to systems and equipment described in the Final Safety Analysis Report;
- b. Records of new and irradiated fuel inventory, fuel transfers, and assembly burnup histories;
- c. Records of radiation exposure for all individuals entering radiation control areas;
- d. Records of gaseous and liquid radioactive material released to the environs;
- e. Records of transient or operational cycles for those unit components identified in the UFSAR;
- f. Records of reactor tests and experiments;
- g. Records of training and qualification for current members of the unit staff;
- h. Records of inservice inspections performed pursuant to these Technical Specifications;
- i. Records of quality assurance activities required by the Operational Quality Assurance Plan;

ADMINISTRATIVE CONTROLS

RECORD RETENTION (Continued)

- j. Records of reviews performed for changes made to procedures or equipment or reviews of tests and experiments pursuant to 10 CFR 50.59;
- k. Records of meetings of the PORC and the NSRB;
- l. Records of the service lives of all hydraulic and mechanical snubbers required by Specification 3.7.9 including the date at which the service life commences and associated installation and maintenance records;
- m. Records of secondary water sampling and water quality; and
- n. Records of analyses required by the Radiological Environmental Monitoring Program that would permit evaluation of the accuracy of the analysis at a later date. This should include procedures effective at specified times and QA records showing that these procedures were followed.

6.11 RADIATION PROTECTION PROGRAM

6.11.1 Procedures for personnel radiation protection shall be prepared consistent with the requirements of 10 CFR Part 20 and shall be approved, maintained, and adhered to for all operations involving personnel radiation exposure.

6.12 HIGH RADIATION AREA

6.12.1 Pursuant to paragraph 20.203(c)(5) of 10 CFR Part 20, in lieu of the "control device" or "alarm signal" required by paragraph 20.203(c), each high radiation area, as defined in 10 CFR Part 20, in which the intensity of radiation is equal to or less than 1000 mR/h at 45 cm (18 in.) from the radiation source or from any surface which the radiation penetrates shall be barricaded and conspicuously posted as a high radiation area and entrance thereto shall be controlled by requiring issuance of a Radiation Work Permit (RWP). Individuals qualified in radiation protection procedures (e.g., Health Physics Technician) or personnel continuously escorted by such individuals may be exempt from the RWP issuance requirement during the performance of their assigned duties in high radiation areas with exposure rates equal to or less than 1000 mR/h, provided they are otherwise following plant radiation protection procedures for entry into such high radiation areas. Any individual or group of individuals permitted to enter such areas shall be provided with or accompanied by one or more of the following:

- a. A radiation monitoring device which continuously indicates the radiation dose rate in the area; or
- b. A radiation monitoring device which continuously integrates the radiation dose rate in the area and alarms when a preset integrated dose is received. Entry into such areas with this monitoring device may be made after the dose rate levels in the area have been established and personnel have been made knowledgeable of them; or
- c. An individual qualified in radiation protection procedures with a radiation dose rate monitoring device, who is responsible for providing positive control over the activities within the area and shall perform periodic radiation surveillance at the frequency specified by the Health and Safety Services Manager in the RWP.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NOS. 46 AND 35 TO

FACILITY OPERATING LICENSE NOS. NPF-76 AND NPF-80

HOUSTON LIGHTING & POWER COMPANY

CITY PUBLIC SERVICE BOARD OF SAN ANTONIO

CENTRAL POWER AND LIGHT COMPANY

CITY OF AUSTIN, TEXAS

DOCKET NOS. 50-498 AND 50-499

SOUTH TEXAS PROJECT, UNITS 1 AND 2

1.0 INTRODUCTION

By application dated October 12, 1990, Houston Lighting & Power Company, et.al., (the licensee) requested changes to the Technical Specifications (Appendix A to Facility Operating License Nos. NPF-76 and NPF-80) for the South Texas Project, Units 1 and 2. The October 12, 1990 application was supplemented by letter dated January 24, 1991 and superseded by letters of October 26, 1991 and June 16, 1992. The proposed changes would delete Technical Specification (TS) Table 5.7-1 (Component Cycle or Transient Limits). Cyclic/transient occurrences identified in the Updated Final Safety Analysis Report, Table 3.9-8, which include those listed in TS Table 5.7-1, would be tracked through administrative procedures. The change is intended to resolve discrepancies between Table 5.7-1 and the Updated Final Safety Analysis Report (UFSAR) which were previously identified by the staff during the 1988 review of the South Texas Project (STP) draft Technical Specifications (TS).

2.0 DISCUSSION AND EVALUATION

Specification 5.7.1 of the STP TS states that, "The components identified in Table 5.7-1 are designed and shall be maintained within the cyclic or transient limits of Table 5.7-1." This table lists cyclic and transient operating conditions which are assumed to occur over the service lifetime of the plant, and which are considered to be sufficiently severe or frequent to be of possible significance to the fatigue life of reactor coolant system (RCS) components. The licensee must monitor the occurrence of these cyclic/transient conditions to ensure that the components of the RCS are not subjected to conditions that are more severe than those which were considered in the component fatigue analyses which were performed to comply with Section III of the American Society of Mechanical Engineers Boiler and Pressure Vessel Code (ASME Section III).

During the review of the draft TS for STP Unit 2, the staff noted that the STP UFSAR Table 3.9-8, "Summary of Reactor Coolant System Design Transients," lists more transients than does TS Table 5.7-1. The staff was concerned that specifying and tracking only those cyclic and transient conditions listed in Table 5.7-1 would not provide adequate information to ensure that the components of the RCS are maintained within the design bases. Based on this concern, the staff requested that the Houston Lighting and Power Company provide justification for the adequacy of Table 5.7-1 as guidance for monitoring plant transients. In response, the licensee committed to develop a plant procedure to ensure that the appropriate RCS cyclic and transient occurrences are monitored. The staff accepted the commitment in Supplement 6 of NUREG-0781, "Safety Evaluation Report Related to the Operation of South Texas Project, Unit 2" dated December 1988. By letter dated May 31, 1989, the licensee stated that Plant Engineering Procedure OPEP02-ZE-0001, Revision 1, had been implemented to ensure that all fatigue-significant transients listed in TS Table 5.7-1 and UFSAR Table 3.9-8 were properly monitored.

The licensee proposed to delete TS Table 5.7-1, and augment TS Section 6, Administrative Controls, to include a component cyclic and transient limit program. The licensee indicated that the component cyclic and transient limit program will be implemented by STP Plant Procedure OPEP02-ZE-0001, Revision 1. In its submittal, the licensee stated that the proposed change is administrative, and will have no impact on plant operation or safety. The licensee further stated that the proposed change is an improvement to the TS and consistent with the NRC policy for improving the TS (52 FR 3788, February 6, 1987).

The staff agrees that the current TS Table 5.7-1 does not provide a complete list of RCS cyclic/transient occurrences, and is inconsistent with the UFSAR. The staff has reviewed the licensee's proposed change and supporting information, and finds that it is adequate to ensure that RCS fatigue-significant cyclic/transient occurrences are properly monitored. The removal of TS Table 5.7-1 in the manner described will not eliminate the licensee's responsibility to ensure that the cyclic/transient limits of the RCS are properly maintained, nor will it change the plant's design bases or operating procedures. The staff finds that the licensee's proposed amendment eliminates the discrepancy between TS Table 5.7-1 and the UFSAR and is an improvement to the current STP TS.

3.0 SUMMARY

The staff has reviewed the licensee's proposed TS amendment for STP Units 1 and 2, and has determined that it is adequate to ensure proper monitoring of RCS fatigue-significant transients. The proposed change eliminates the discrepancy between TS Table 5.7-1 and the UFSAR, and thus it is an improvement to the current STP TS. Therefore, the staff finds that the proposed amendment is acceptable for STP Units 1 and 2.

4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Texas State official was notified of the proposed issuance of the amendment. The State official had no comments.

5.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding (55 FR 53072, 56 FR 66920, and 57 FR 47140). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: M. McBrearty

Date: November 24, 1992