



TXU Energy
Comanche Peak Steam
Electric Station
P.O. Box 1002 (E01)
Glen Rose, TX 76043
Tel: 254 897 8920
Fax: 254 897 6652
lance.terry@txu.com

C. Lance Terry
Senior Vice President &
Principal Nuclear Officer

Ref: GL 97-05

CPSES-200201911
Log # TXX-02086
File # 10010

May 1, 2002

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

**SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NO. 50-446
COMPLETION OF GENERIC LETTER 95-07 ACTIVITIES FOR UNIT 2**

- REF: 1. Generic Letter 95-07, "Pressure Locking and Thermal Binding of Safety Related Power Operated Gate Valves," dated August 17, 1995
2. TXU Electric letter logged TXX-01001 from Mr. C. L. Terry to NRC dated January 22, 2001

Gentlemen:

On August 17, 1995, the NRC issued Generic Letter 95-07, "Pressure Locking and Thermal Binding of Safety Related Power Operated Gate Valves" (Reference 1). In response to the requirements of the Generic Letter, TXU Generation Company LP (TXU Energy) committed to modify the Residual Heat Removal System crosstie isolation valves 1/2-8716-A/B (Reference 2).

The purpose of this letter is to inform you that the committed activities for Unit 2 have now been completed. It is expected that the corresponding activities for Unit 1 will be completed during the ninth refueling outage (1RF09).

This communication contains no new licensing basis commitments regarding CPSES Units 1 and 2.

A056

A member of the **STARS** (Strategic Teaming and Resource Sharing) Alliance

Callaway • Comanche Peak • Diablo Canyon • Palo Verde • South Texas Project • Wolf Creek

TXX-020286

Page 2 of 2


If you have any questions concerning this transmittal please contact Bob Dacko at (254) 897-0122.

Sincerely,

TXU Generation Company LP

By: TXU Generation Management Company LLC,
Its General Partner

C. L. Terry
Senior Vice President and Principal Nuclear Officer

By: 
Roger D. Walker
Regulatory Affairs Manager

BSD/bd

c - E. W. Merschoff, Region IV
W. D. Johnson, Region IV
D. H. Jaffe, NRR
Resident Inspectors, CPSES