

MARCH 10 1978

Docket No. 50-298

Nebraska Public Power District
ATTN: Mr. J. M. Pilant, Director
Licensing & Quality Assurance
P. O. Box 499
Columbus, Nebraska 68601

Gentlemen:

On January 31, 1978, we issued Amendment No. 41 to License No. DPR-46 for the Cooper Nuclear Station. Through an oversight, a portion of the items for section 6.3 was omitted. To correct this error, enclosed is page 226a which should be added to your Technical Specifications.

Sincerely,

Original signed by

George Lear, Chief
Operating Reactors Branch #3
Division of Operating Reactors

Enclosure:
Page 226a for Technical
Specifications

DISTRIBUTION:

Docket TBAbernathy
NRC PDR JRBuchanan
Local PDR ACRS (16)
ORB#3 Rdg File
VStello Xtra Copies
KRGoller
SSheppard
JMcGough
GLear
V Rooney
OELD
OI&E (5)
DEisenhut
BJones

OFFICE ➤	ORB#3	ORB#3	ORB#3			
SURNAME ➤	SSheppard	V Rooney:acr	GLear			
DATE ➤	3/ 8 /78	3/ 8 /78	3/ 10 /78			

Nebraska Public Power District - 2 -

cc w/enclosures:

Mr. G. D. Watson, General Counsel
Nebraska Public Power District
P. O. Box 499
Columbus, Nebraska 68601

Mr. Arthur C. Gehr, Attorney
Snell & Wilmer
400 Security Building
Phoenix, Arizona 85004

Cooper Nuclear Station
ATTN: Mr. L. Lessor
Station Superintendent
P. O. Box 98
Brownville, Nebraska 68321

Auburn Public Library
118 - 15th Street
Auburn, Nebraska 68305

Director
Department of Environmental Control
Executive Building, 2nd Floor
Lincoln, Nebraska 68509

Mr. William Siebert, Commissioner
Nemaha County Board of Commissioners
Nemaha County Courthouse
Auburn, Nebraska 68305

Chief, Energy Systems Analyses
Branch (AW-459)
Office of Radiation Programs
U. S. Environmental Protection Agency
Room 645, East Tower
401 M Street, S. W.
Washington, D. C. 20460

U. S. Environmental Protection Agency
Region VII
ATTN: EIS COORDINATOR
1735 Baltimore Avenue
Kansas City, Missouri 64108

6.3 (cont'd.)

- 6.3.5 In lieu of the "control device" or "alarm signal" required by Paragraph 20.203 (c) (2) of 10 CFR 20 each High Radiation Area (100 mrem/hr or greater) shall be barricaded and conspicuously posted as a High Radiation Area and entrance thereto shall be controlled by requiring notification and permission of the shift supervisor. Any individual or group of individuals permitted to enter such areas shall be provided with a radiation monitoring device which continuously indicates the radiation dose rate in the area.
- 6.3.6 All procedures described in 6.3.2, 6.3.3, & 6.3.4 above, and changes thereto, shall be reviewed by the Station Operations Review Committee and approved by the Station Superintendent prior to implementation, except as provided for in 6.3.7 below.
- 6.3.7 Temporary changes to procedures which do not change the intent of the original procedure may be made, provided such changes are approved by two members of the operating staff holding SRO licenses. Such changes shall be documented and subsequently reviewed by the Station Superintendent within one month.
- 6.3.8 Drills of the Emergency Plan procedures shall be conducted semi-annually, including a check of communications with offsite support groups. Drills on the procedures specified in 6.3.2.A, B, and C above shall be conducted as part of the retraining program.

REFERENCE

1. SAR Subsection XIII-6.