

February 26, 1987

Docket No. 50-298

Mr. George A. Trevors, Division
Manager - Nuclear Support
Nebraska Public Power District
Post Office Box 499
Columbus, Nebraska 68601

Dear Mr. Trevors:

On February 3, 1987, the Commission issued Amendment No. 107 to Facility Operating License No. DPR-46 for the Cooper Nuclear Station. This amendment revised Page 168, TABLE 3.7.1, of the Appendix A Technical Specifications to state that the Main Steam Line Drain Header Containment Isolation Valves are normally open.

The table had previously been revised in Amendment No. 103, issued November 10, 1986, to delete the reactor vessel head spray isolation valves. Amendment 107 inadvertently restored the head spray valves to the table. Therefore we are forwarding the attached corrected page.

We regret any inconvenience the error may have created.

Sincerely,

Original Signed by

William O. Long, Project Manager
BWR Project Directorate No. 2
Division of BWR Licensing

Enclosure:
As stated

cc w/enclosure
See next page

DISTRIBUTION

| | | | |
|-------------|--------------|---------------|------------|
| Docket File | SNorris | BGrimes | OPA |
| NRC PDR | WLong | TBarnhart (4) | LFMB |
| LPDR | OGC-Bethesda | WJones | Plant File |
| EButcher | LJHarmon | DVassallo | RBernero |
| NThompson | ELJordan | ACRS (10) | JParlow |

OFFICIAL RECORD COPY

| | | |
|----------|----------|----------|
| DBL:PD#2 | DBL:PD#2 | DBL:PD#2 |
| SNorris | WLong | DMiller |
| 2/26/87 | 2/26/87 | 2/26/87 |

8703030514 870226
PDR ADDCK 05000298
P PDR

Mr. George A. Trevors
Nebraska Public Power District

Cooper Nuclear Station

cc:

Mr. G. D. Watson, General Counsel
Nebraska Public Power District
Post Office Box 4999
Columbus, Nebraska 68601

Mr. Arthur C. Gehr, Attorney
Snell & Wilmer
3100 Valley Center
Phoenix, Arizona 85073

Cooper Nuclear Station
ATTN: Mr. G. Horn, Division
Manager of Nuclear Operations
Post Office Box 98
Brownville, Nebraska 68321

Director
Nebraska Department of Environmental
Control
Post Office Box 94877
State House Station
Lincoln, Nebraska 68509

Mr. William Siebert, Commissioner
Nemaha County Board of Commissioners
Nemaha County Courthouse
Auburn, Nebraska 68305

Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Box 218
Brownville, Nebraska 68321

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

H. Ellis Simmons, Director
Division of Radiological Health
Department of Health
301 Centennial Mall, South
Post Office Box 95007
Lincoln, Nebraska 68509

COOPER NUCLEAR STATION
TABLE 3.7.1 (Page 1)
PRIMARY CONTAINMENT ISOLATION VALVES

| Valve & Steam | Number of Power Operated Valves | | Maximum Operating Time (Sec) (1) | Normal Position (2) | Action On Initiating Signal (3) |
|--|------------------------------------|----------|--|------------------------|---------------------------------------|
| | Inboard | Outboard | | | |
| Main Steam Isolation Valves | | | | | |
| MS-AO-80- A,B,C, & D | 4 | | 3 < T < 5 | 0 | GC |
| MS-AO-86- A,B,C, & D | | 4 | 3 < T < 5 | 0 | GC |
| Drywell Floor Drain Iso. Valves | | | | | |
| RW-AO-82, RW-AC-83 | 1 | 1 | 15 | 0 | GC |
| Drywell Equipment Drain | | | | | |
| Iso. Valves RW-AO-94, RW-AO-95 | 1 | 1 | 15 | 0 | GC |
| Main Steam Line Drain | | | | | |
| Valves MS-MO-74, MS-MO-77 | 1 | 1 | 30 | 0 | GC |
| Reactor Water Sample Valves | | | | | |
| RRV-740AV, RRV-741AV | 1 | 1 | 15 | 0 | GC |
| Reactor Water Cleanup System | | | | | |
| Iso. Valves RWCU-MO-15, RWCU-MO-18 | 1 | 1 | 60 | 0 | GC |
| RHR Suction Cooling Iso. | | | | | |
| Valve RHR-MO-17, RHR-MO-18 | 1 | 1 | 40 | C | SC |
| RHR Discharge to Radwaste | | | | | |
| Iso. Valves RHR-MO-57, RHR-MO-67 | 1 | 1 | 20 | C | SC |
| Suppression Chamber Purge & Vent PC-245AV, PC-230MV | | | | | |
| | | 2 | 15 | C | SC |
| Suppression Chamber N ₂ Supply | | | | | |
| PC-237AV, PC-233MV | | 2 | 15 | C | SC |

8703030519 870226
PDR ADOCK 05000298
PDR