

PROP

General Information or Other (PAR)

Event # 38909

Rep Org: ROCKWELL AUTOMATION		Notification Date / Time: 05/09/2002 16:30 (EDT)	
Supplier: ROCKWELL AUTOMATION		Event Date / Time: 05/09/2002 (EDT)	
		Last Modification: 05/09/2002	
Region: 2		Docket #:	
City: FLOWERY BRANCH		Agreement State: Yes	
County:		License #:	
State: GA			
NRC Notified by: JAMES THIGPEN		Notifications: VERN HODGE	
HQ Ops Officer: RICH LAURA		NRR	
Emergency Class: NON EMERGENCY			
10 CFR Section:			
21.21 UNSPECIFIED PARAGRAPH			

PART 21 ISSUE ON ELECTRIC MOTORS

Rockwell Automations report a potential defect involving insufficient slot fill in electric motor windings used to drive fan assemblies. They have contacted Hayden Company located in New Philadelphia, Ohio who was supplied with these motors. The motors may be in use at commercial nuclear power plants.

.....