



FirstEnergy Nuclear Operating Company

Beaver Valley Power Station
Route 168
P.O. Box 4
Shippingport, PA 15077-0004

L. W. Pearce
Site Vice President

724-682-5234
Fax: 724-643-8069

May 15, 2002
L-02-059

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555-0001

**Subject: Beaver Valley Power Station, Unit No. 1 and No. 2
BV-1 Docket No. 50-334, License No. DPR-66
BV-2 Docket No. 50-412, License No. NPF-73
2001 Annual Environmental Report, Radiological**

The enclosed Year 2001 Annual Radiological Environmental Operating Report for Beaver Valley Power Station (BVPS) Units 1 and 2 is being forwarded, in accordance with BVPS Technical Specification 6.9.2. The report indicates that the Environmental Monitoring Program outlined in the BVPS Offsite Dose Calculation Manual for Units 1 and 2 was followed throughout 2001. The program results demonstrate the adequacy of radioactive effluent control at the Beaver Valley Power Station and that the operations of Units 1 and 2 did not adversely affect the surrounding environment.

The findings of this report are summarized in the Executive Summary which is presented at the beginning of the report. Some observations from the report include the following:

- Based on the analytical results of environmental samples during 2001, the Beaver Valley Power Station reporting levels were not exceeded.
- Year 2001 analytical results continue to be at or below the pre-operational (1974-75) baseline results.
- Based on the estimated dose to individuals from the natural background radiation exposure, the incremental increase in total body dose to the 50-mile population (approximately 4 million) from the operation of BVPS Units 1 and 2, is less than 0.0001% of the annual background dose.

IE 25
A009

Beaver Valley Power Station, Unit No. 1 and No. 2
2001 Annual Environmental Report, Radiological
L-02-059
Page 2

If you have any questions regarding this submittal, please contact Mr. Larry R. Freeland,
Manager, Regulatory Affairs/Corrective Action at 724-682-5284.

Sincerely,




L. W. Pearce

Enclosure

c: Mr. D. S. Collins, Project Manager
Mr. D. M. Kern, Sr. Resident Inspector
Mr. H. J. Miller, NRC Region I Administrator

FENOC
Beaver Valley Power Station - Units 1 & 2

**Annual Radiological
Environmental Operating Report**
Calendar Year - 2001



**BEAVER VALLEY POWER STATION
UNITS 1 AND 2
LICENSES DPR-66 AND NPF-73
2001 ANNUAL RADIOLOGICAL
ENVIRONMENTAL OPERATING REPORT**

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

EXECUTIVE SUMMARY

This document is a detailed report of the 2001 Beaver Valley Power Station Radiological Environmental Monitoring Program (REMP). Radioactivity levels in the vicinity of Unit 1 and Unit 2 from January 1 through December 31, 2001 in air, water, shoreline sediment, milk, fish, food crops, vegetation, and direct radiation measurement have been analyzed, evaluated, and summarized. The results of the REMP are intended to supplement the results of the radiological effluent monitoring by verifying that the measurable concentration of radioactive materials and levels of radiation are not higher than expected on the basis of the effluent measurement and modeling of the environmental exposure pathways.

Radiation and radioactivity in the environment is monitored within a 10 mile radius of the site. Two types of samples are taken. The first type, control samples, are collected from areas that are beyond measurable influence of Beaver Valley Power Station. These samples are used as reference data. Normal background radiation levels, or radiation present due to causes other than Beaver Valley Power Station, can thus be compared to the environment surrounding the nuclear power station. Indicator samples are the second sample type obtained. These samples show how much radiation is contributed to the environment by the site. Indicator samples are taken from areas close to the station where any plant contribution will be at the highest concentration. In 2001, samples were taken from over 60 sites around Beaver Valley Power Station that included the aquatic, atmospheric and terrestrial environments. More than 2400 analyses were performed on these samples. The environmental program for 2001 is outlined in Table 2-1.

In 1974 and 1975, prior to station operation, samples were collected and analyzed to determine the amount of radioactivity present in the area. The resulting values are used as a "pre-operational baseline". Current analysis results from the indicator samples are compared to both current control sample values and the pre-operational baseline to determine if changes in radioactivity levels are attributable to station operations. The 2001 analytical results and pre-operational baseline results are summarized in Table 2-2 and Table 2-3.

A report is required to be submitted to the Nuclear Regulatory Commission when the level of radioactivity in an environmental sampling medium exceeds the limits specified in the Offsite Dose Calculation Manual (ODCM) when averaged over any calendar quarter. Also, when more than one of the radionuclides are detected in the sampling medium, this report shall be submitted if:

$$\frac{\text{Concentration (1)}}{\text{Limit Level (1)}} + \frac{\text{Concentration (2)}}{\text{Limit Level (2)}} + \dots \geq 1.0$$

Based on the analytical results of environmental samples during 2001, the Beaver Valley Power Station reporting levels were not exceeded.

Positive results attributable to the Beaver Valley Power Station were consistent with station data of authorized radioactive discharges and were within limits permitted by the NRC license. Other radioactivity detected was attributable to naturally occurring radionuclides, previous nuclear weapons tests, other man-made sources, and to the normal statistical fluctuation for activities near the lower limit of detection (LLD).

Beaver Valley Power Station 2001 Annual Radiological Environmental Operating Report

In 2001, the radioactivity releases from BVPS Units 1 and 2 did not exceed the effluent limits identified in the Beaver Valley Power Station Operating License Technical Specification/Offsite Dose Calculation Manual (ODCM). Based on the estimated dose to individuals from the natural background radiation exposure, the incremental increase in total body dose to the 50 mile population (approximately 4 million), from the operation of Beaver Valley Power Station Units 1 and 2, is less than 0.0001% of the annual background dose. The National Academy of Sciences 1990 BEIR Report shows that the typical dose to an individual from background (natural radiation exposure including radon) is an estimated average of 296 mrem per year.

Analytical results are divided into four ODCM required categories based on exposure pathways: Airborne, direct radiation, ingestion and waterborne. Each of these pathways is described below:

- The airborne exposure pathway includes airborne iodine and airborne particulates. The 2001 results were similar to previous years. There was no notable increase in natural products and no detectable fission products or other radionuclides in the airborne particulate media during the year.
- The direct exposure pathway measures environmental radiation doses by use of thermoluminescent dosimeters (TLDs). TLD results have indicated a stable trend and compare well with previous years.
- The ingestion exposure pathway includes milk, fish, and food product (leafy vegetable) samples. For milk samples, strontium-90 (Sr-90), attributable to past atmospheric nuclear weapons testing, was detected at levels similar to the past five years. The gamma spectroscopy counting only indicated positive results for potassium-40 (K-40) at average environmental levels. Iodine-131 (I-131) was detected in four (4) milk samples at slightly above LLD levels. No other radionuclides were identified.
- The fish samples taken indicated below LLD levels in each of the samples. Vegetation samples revealed naturally occurring K-40 at average environmental levels.
- The waterborne exposure pathway includes drinking water, surface (river) water, and river sediment. Water samples were analyzed for tritium and gamma-emitting radionuclides. Tritium was identified in one of twenty samples. The positive result was near typical lower limit of detection for tritium (H-3) analysis. Gamma analysis of samples indicated no gamma-emitting radionuclides above detection limits except one sample had naturally occurring radium-226 (Ra-226) and another sample had thorium-228 (Th-228). I-131 analysis of weekly samples (151 total) indicated 90 positive results. None of the positive results exceeded the reporting level. It was also noted that the surface water samples, which are upstream of the plant and considered outside the influence of the site had similar results to the downstream drinking water samples.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

- Sediment samples are taken from three locations, upstream of the site, at the discharge point of liquid releases and downstream of the site. Analysis of samples indicated naturally occurring radionuclides K-40 and Ra-226 in all results. Small amounts of cesium-137 (Cs-137) from previous nuclear weapons tests was also detected in five of the six samples (including the Control location) at levels consistent with previous years. The samples from the discharge point of the site also indicated small amounts of other radionuclides, including cobalt-58 (Co-58), and cobalt-60 (Co-60) which are consistent with authorized station liquid discharges.
- In addition to the required samples discussed above, groundwater, precipitation, soil, and feedcrops were also taken. Results were consistent with previous years and no degrading trends were identified.

The environmental monitoring program outlined in the Beaver Valley Power Station ODCM for Units 1 and 2 was followed throughout 2001. The REMP results demonstrate the adequacy of radioactive effluent control at the Beaver Valley Power Station and that the operations of Units 1 and 2 did not adversely affect the surrounding environment.

It should be noted that the environmental monitoring program includes sampling sites in addition to the required sites set forth in the ODCM. These include five (5) air sampling sites, one (1) surface water site, three (3) ground water sites, three (3) precipitation sites, two (2) sediment sites, one (1) local large dairy, and one (1) milk animal feed site.

It should also be noted that there was a change in REMP analysis lab vendors following first quarter. This was a common process activity for the BVPS REMP.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

TABLE OF CONTENTS

EXECUTIVE SUMMARY	ii
SECTION 1 - INTRODUCTION	
A. Scope and Objectives of the Program.....	1-1
B. Description of the Beaver Valley Site	1-1
SECTION 2 - ENVIRONMENTAL MONITORING PROGRAM	
A. Environmental Radioactivity Monitoring Program	2-1
1. Program Description.....	2-1
2. Summary of Results	2-7
3. Quality Control Program	2-7
4. Program Changes	2-7
B. Air Monitoring.....	2-21
1. Characterization of Air and Meteorology.....	2-21
2. Air Sampling Program and Analytical Techniques	2-21
3. Results and Conclusions	2-23
C. Monitoring of Sediments and Soils.....	2-26
1. Characterization of Stream Sediments and Soils.....	2-26
2. Sampling Program and Analytical Techniques	2-26
3. Results and Conclusions	2-28
D. Monitoring of Feedcrops and Food Products	2-29
1. Characterization of Farm Products	2-29
2. Sampling Program and Analytical Techniques	2-29
3. Results and Conclusions	2-31
E. Monitoring of Local Cows Milk.....	2-32
1. Description - Milch Animal Locations	2-32
2. Sampling Program and Analytical Techniques	2-32
3. Results and Conclusions	2-34
F. Environmental Radiation Monitoring.....	2-37
1. Description of Regional Background Radiation and Sources.....	2-37
2. Locations and Analytical Procedures.....	2-37
3. Results and Conclusions	2-38
G. Monitoring of Fish	2-41
1. Description	2-41
2. Sampling Program and Analytical Techniques	2-41
3. Results and Conclusions	2-41

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

TABLE OF CONTENTS (Continued)

SECTION 2 - ENVIRONMENTAL MONITORING PROGRAM (continued)

H.	Monitoring of Surface, Drinking, Ground Waters and Precipitation	2-43
1.	Description of Water Sources.....	2-43
2.	Sampling and Analytical Techniques.....	2-44
3.	Results and Conclusions.....	2-47
I.	Estimates of Radiation Dose to Man	2-49
1.	Pathways to Man - Calculational Models	2-49
2.	Results of Calculated Radiation Dose to Man - Liquid Releases	2-50
3.	Results of Calculated Radiation Dose to Man - Atmospheric Releases	2-52
4.	Conclusions.....	2-54

SECTION 3 - LAND USE CENSUS..... 3-1

**SECTION 4 - QUALITY CONTROL PROGRAM / INTERLABORATORY
COMPARISON PROGRAM**

A.	Quality Control Program.....	4-1
1.	Split Sample Program (Contractor Laboratory - QC Laboratory)	4-1
2.	Duplicate Sample Program (Contractor Laboratory - QC Laboratory)	4-2
B.	Interlaboratory Comparison Program.....	4-3
1.	Contractor Lab	4-3
C.	Conclusions	4-4

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

LIST OF TABLES

Table 2-1	-	Operational Radiological Environmental Monitoring Program	2-2
Table 2-2	-	Environmental Monitoring Program Results	2-8
Table 2-3	-	Pre-Operational Environmental Radiological Monitoring Program Summary.....	2-18
Table 2-4	-	Results of Calculated Individual and Population Radiation Dose to Man – Liquid Releases	2-51
Table 2-5	-	Results of Calculated Radiation Dose to Man - Atmospheric Releases	2-53
Table 3-1	-	Location of Nearest Residence, Garden, and Milch Animal	3-2
Table 4-1	-	Quality Control Data Contractor/Quality Control Laboratory Comparison Split Surface Water Samples, Site 2.1	4-5
Table 4-2	-	Quality Control Data Contractor/Quality Control Laboratory Comparison Split Drinking Water Samples, Site 4	4-6
Table 4-3	-	Quality Control Data Contractor/Quality Control Laboratory Comparison Split Milk Samples, Site 25.....	4-7
Table 4-4	-	Quality Control Data Contractor/Quality Control Laboratory Comparison Split Feed, Food, Sediment and Soil Samples	4-8
Table 4-5	-	Quality Control Data Contractor/Quality Control Laboratory Comparison Duplicate (Co-located) Air Particulate and Charcoal Filter Samples, Sites 30 and 30A	4-9
Table 4-6	-	Quality Control Data Contractor/Quality Control Laboratory Comparison Duplicate (Co-located) Air Particulate Samples (Gamma) (pCi/Cu Meter).....	4-10
Table 4-7	-	Quality Control Data Contractor/Quality Control Laboratory Comparison Thermoluminescent Dosimeters - mR/day	4-11
Table 4-8	-	Interlaboratory Comparison Program Independent Laboratory/Contractor Laboratory Comparison Spiked Water Samples (pCi/l)	4-12
Table 4-9	-	Interlaboratory Comparison Program Independent Laboratory/Contractor Laboratory Comparison Spiked Milk Samples (pCi/l)	4-14
Table 4-10	-	Interlaboratory Comparison Program Contractor/Quality Control Laboratory Comparison Spiked Air Particulate/Charcoal Filters.....	4-16

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

LIST OF FIGURES

Figure 1-1	- Geographical Map and Principal Communities in 50-mile Radius of the Beaver Valley Power Station	1-3
Figure 2-1	- Air Sampling Stations	2-22
Figure 2-2	- Average Concentration of Gross Beta in Air Particulates.....	2-25
Figure 2-3	- Environmental Monitoring Locations - Shoreline Sediments and Soil.....	2-27
Figure 2-4	- Environmental Monitoring Program - Feedcrop and Food Product Locations.....	2-30
Figure 2-5	- Environmental Monitoring Locations - Milk	2-33
Figure 2-6	- TLD Locations	2-39
Figure 2-7	- Environmental Monitoring Program - Fish Sampling Locations.....	2-42
Figure 2-8	- Environmental Monitoring Stations Locations - Ground, Surface Water, Drinking Water and Precipitation	2-46

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

SECTION 1 - INTRODUCTION

A. Scope and Objectives of the Program

The environmental program consists of environmental monitoring for radioactivity in the vicinity of the Beaver Valley Power Station. Environmental sampling and analyses included air, water, milk, vegetation, river sediments, fish, and ambient radiation levels in areas surrounding the site. The results of these media are assessed to determine impacts of the plant operation on the environment. The Annual Radiological Environmental Report for the Beaver Valley Power Station summarizes the radiological environmental program conducted by the FirstEnergy Nuclear Operating Company in 2001.

B. Description of the Beaver Valley Site

The Beaver Valley Power Station is located on the south bank of the Ohio River in the Borough of Shippingport, Beaver County, Pennsylvania, on a 501 acre tract of land. The site is approximately one mile from Midland, Pennsylvania; five miles from East Liverpool, Ohio; and twenty-five miles from Pittsburgh, Pennsylvania. Figure 1-1 shows the site location in relation to the principal population centers. Population density in the immediate vicinity of the site is relatively low. The population within a five mile radius of the plant is approximately 18,000 and the only area within the radius of concentrated population is the Borough of Midland, Pennsylvania, with a population of approximately 3,320.

The site lies in a valley along the Ohio River. It extends from the river (elevation 665 feet above sea level) to a ridge along the border south of the Beaver Valley Power Station at an elevation of 1,160 feet. Plant ground level is approximately 735 feet above sea level.

The Beaver Valley Power Station is on the Ohio River at river mile 34.8, at a location on the New Cumberland Pool that is 3.3 river miles downstream from Montgomery Lock and Dam, and 19.4 miles upstream from New Cumberland Lock and Dam. The Pennsylvania-Ohio-West Virginia border is located 5.2 river miles downstream from the site. The river flow is regulated by a series of dams and reservoirs on the Beaver, Allegheny, Monongahela and Ohio Rivers and their tributaries. For 2001, the flow ranged from a minimum monthly average of 9,100 cubic feet per second (CFS) to a maximum monthly average of 67,900 CFS. The mean flow for 2001 was 29,783 CFS.

Water temperature of the Ohio River varies from 32°F to 84°F, the minimum temperatures occur in January and/or February and maximum temperatures in July and August. Water quality in the Ohio River at the site location is affected primarily by the water quality of the Allegheny, Monongahela and Beaver rivers.

The climate of the area may be classified as humid continental. Annual precipitation is approximately 36 inches, typical yearly temperatures vary from approximately -3°F to 95°F with an annual average temperature of 52.3°F. The predominant wind direction is typically from the southwest in summer and from the northwest in winter.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

The basic features of the Beaver Valley Power Station Units 1 and 2 are tabulated below:


	<u>Beaver Valley Unit 1</u>	<u>Beaver Valley Unit 2</u>
Maximum Power Level	2652 – megawatts thermal 2689 – megawatts thermal (upgraded in October)	2652 – megawatts thermal 2689 – megawatts thermal (upgraded in October)
Type of Power	PWR	PWR
No. of Reactor Coolant Loops	3	3
No. of Steam Generators & Type	3 - Vertical	3 - Vertical
Steam Used by Main Turbine	Saturated	Saturated

The units utilize two separate systems (primary and secondary) for transferring heat from the source (the reactor) to the receiving component (turbine-generator). Because the two systems are isolated from each other, primary and secondary waters do not mix; therefore, radioactivity in the primary system water is normally isolated from the secondary system. Reactor coolant in the primary system is pumped through the reactor core and steam generators by means of reactor coolant pumps. Heat is given up from the primary system to the secondary system in the steam generators, where steam is formed and delivered to the main unit turbine, which drives the electrical generator. The steam is condensed after passing through the turbine, and returned to the steam generators to begin another steam/water cycle.

Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report

Figure 1-1

Geographical Map and Principal Communities
in 50-mile Radius of the Beaver Valley Power Station



**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

SECTION 2 - ENVIRONMENTAL MONITORING PROGRAM

A. Environmental Radioactivity Monitoring Program

1. Program Description

The program consists of monitoring water, air, soil, river bottoms, vegetation and foodcrops, cows milk, ambient radiation levels in areas surrounding the site, and aquatic life as summarized in Table 2-1. Further description of each portion of the program (Sampling Methods, Sample Analysis, Discussion and Results) are included in Sections 2-B through 2-I of this report.

2-B - Air Monitoring

2-C - Monitoring of Sediments and Soils

2-D - Monitoring of Feedcrops and Food Products

2-E - Monitoring of Local Cows Milk

2-F - Environmental Radiation Monitoring

2-G - Monitoring of Fish

2-H - Monitoring of Surface, Drinking, Ground Waters and Precipitation

2-I - Estimates of Radiation Dose to Man

Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report

Table 2-1

Operational Radiological Environmental Monitoring Program

Type of Sample	Sample Points	Sector	Miles	Sample Point Description	Sample Frequency	Sample Preparation	Analysis
1 Air Particulate and Radioiodine	13	11	1.4	Meyer's Farm	Continuous sampling with sample collection at least weekly	Weekly AP	Gross Beta (b)
	30	4	0.5	Shippingport (S.S.)		Weekly Charcoal	I-131
	46.1	3	2.3	Industry, Rt. 68 – Garage		Quarterly Composite (c)	Gamma - scan
	32	15	0.8	Midland (S.S.)			
	48(a)	10	16.3	Weirton, W.Va., - Weirton Water Tower, Collier Way			
	51	5	8.0	Aliquippa (S.S.)			
	47	14	4.9	East Liverpool, Oh. - Water Treatment Plant			
	27	7	6.1	Brunton's Farm			
	28	1	8.6	Sherman's Farm			
	29B	3	8.0	Beaver Valley Geriatric Center			
2 Direct Radiation	30	4	0.5	Shippingport (S.S.)	Continuous (TLD)	Quarterly (i)	Gamma Dose
	13	11	1.4	Meyer's Farm			
	46	3	2.5	Industry, Midway Dr.			
	32	15	0.8	Midland (S.S.)			
	48(a)	10	16.3	Weirton, W.Va. - Weirton Water Tower, Collier Way			
	45.1	6	1.9	Raccoon Twp., Kennedy's Corners			
	51	5	8.0	Aliquippa (S.S.)			
	47	14	4.9	East Liverpool, Oh. - Water Treatment Plant			
	70	1	3.4	North of Western Beaver School – Engle Rd.			
	80	9	8.2	Raccoon Park Office (Rt. 18)			
	81	9	3.6	Milkcreek United Pres. Church			
	82	9	6.9	Hanover Municipal Bldg.			
	83	10	4.2	735 Mill Creek Rd.			
	14	11	2.5	Hookstown			
	84	11	8.3	Hancock Parks & Recreation Complex			
	85	12	5.7	Rts. 8 & 30 Intersection			
	86	13	6.2	E. Liverpool, Oh. 1090 Ohio Ave.			
92	12	2.8	Georgetown Rd. (S.S.)				

Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report

Table 2-1 (Continued)

Operational Radiological Environmental Monitoring Program

Types of Sample	Sample Points	Sector	Miles	Sample Point Description	Sample Frequency	Sample Preparation	Analysis
2 Direct Radiation (continued)	87	14	7.0	Calcutta, Oh. - Calcutta Smith's Ferry Rd. & Valley Dr.	Continuous (TLD)	Quarterly (i)	Gamma-Dose
	88	15	2.8	Midland Heights - 110 Summit Rd.			
	89	15	4.8	Ohioville, 488 Smith's Ferry Rd.			
	90	16	5.2	Opposite Fairview School			
	10	3	1.0	Shippingport Boro			
	45	5	2.2	Rt. 18 & Anderson St.			
	60	13	2.5	444 Hill Rd.			
	93	16	1.1	Midland, Sunrise Hills			
	95	10	2.3	832 McCleary Rd.			
	28	1	8.6	Sherman's Farm			
	71	2	6.0	Brighton Twp. First West.			
	72	3	3.3	Industry, Logan Park			
	29B	3	8.0	Beaver Valley Geriatric Center			
	73	4	2.5	618 Squirrel Run Rd.			
	74	4	7.0	CCBC - 137 Poplar Ave.			
	75	5	4.1	117 Holt Road			
	76	6	3.8	Raccoon Elementary School			
	77	6	5.6	3614 Green Garden Rd			
	59	6	1.0	236 Green Hill Rd.			
	78	7	2.7	Raccoon Mun. Bldg.			
	27	7	6.1	Brunton's Farm			
79	8	4.4	Rt. 151 & Pross Ln.				
15	14	3.7	Georgetown Post Office				
46.1	3	2.3	Industry, Rt. 168 - Garage				
91	2	3.9	Pine Grove Rd and Doyle Rd				
94	8	2.2	McCleary Rd. & Pole Cat Hollow Rd.				
3 Surface Water	49(a)	3	5.0	Upstream Side of Montgomery Dam	Weekly Grab Sample (h)	Weekly Sample from Site 49	I-131
	2.1	14	1.5	Downstream (Midland) J&L	Weekly, Intermittent Composite Sample (h)	Monthly composite of Weekly Sample (c)	Gamma-scan
	5	14	4.9	East Liverpool, Oh. - Water Treatment Plant (raw water)	Daily Grab Sample Only - Collected Weekly (h)		
						Quarterly Composite (c)	H-3

Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report

Table 2-1 (Continued)

Operational Radiological Environmental Monitoring Program

Type of Sample		Sample Points	Sector	Miles	Sample Point Description	Sample Frequency	Sample Preparation	Analysis
4	Groundwater	14	11	2.5	Hookstown	Semi-Annual	Semi-Annual	Gamma-scan H-3
		15	14	3.7	Georgetown			
		11	3	0.8	Shippingport Boro			
5	Drinking	4	15	1.3	Midland, Water Treatment Plant	Intermittent (d) Sample Collected Weekly	Weekly Composite	I-131
		5	14	4.9	East Liverpool, Oh. - Water Treatment Plant		Monthly Composite (d)	Gamma-scan
							Quarterly Composite (d)	H-3
6	Shoreline Sediment	2A	13	0.2	BVPS Outfall Discharge	Semi-Annual	Semi-Annual	Gamma-scan
		49(a)	3	5.0	Upstream side of Montgomery Dam			
		50	12	11.8	Upstream side of New Cumberland Dam			
7	Milk	25	10	2.1	Searight's Farm	Weekly (e)	Weekly sample from Searight's only	I-131
		.	10	10.4	Windsheimer's Farm	Biweekly (f) when animals are on pasture; monthly at other times.	Biweekly (grazing)	Gamma-scan Sr-89, Sr-90, I-131
		.					Monthly (indoors)	
		.						
		96(a)	7	6.1	Brunton's Farm			
27								

* BVPS ODCM, Appendix C, Table 3.12-1 requires three (3) dairies to be selected on basis of highest potential thyroid dose using milch census data. See Section 2-E for specific locations sampled.

Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report

Table 2-1 (Continued)

Operational Radiological Environmental Monitoring Program

	Type of Sample	Sample Points	Sector	Miles	Sample Point Description	Sample Frequency	Sample Preparation	Analysis
8	Fish	2A	13	0.2	BVPS Outfall Discharge	Semi-Annual	Composite of edible parts by species (g)	Gamma-scan
		49(a)	3	5.0	Upstream side of Montgomery Dam			
9	Food Crops (Shippingport) (Georgetown) (Industry)	10	3	1.0	Three locations within 5 miles selected by BVPS. Weirton, W.Va.	Annual at harvest if available	Composite of each sample species	Gamma-scan I-131 on green leafy vegetables
		15	14	3.7				
		46	3	2.5				
		48(a)	10	16.3				
10	Feedstuff and Summer Forage	25	10	2.1	Searight's Farm	Monthly	Monthly	Gamma-scan
11	Soil	13	11	1.4	Meyer's Farm	Every 3 years (1994, 1997, etc.)	12 Core Samples 3" Deep (2" Dia. at each location) (approx. 10' radius)	Gamma-scan
		30	4	0.5	Shippingport (S.S.)			
		46	3	2.5	Industry, Midway Dr.			
		32	15	0.8	Midland (S.S.)			
		48A(a)	10	15.6	Weirton, W.Va. - Weirton Water Tower, E. Belleview Dr.			
		51	5	8.0	Aliquippa (S.S.)			
		47	14	4.9	E. Liverpool, Oh. - Water Treatment Plant			
		27	7	6.1	Brunton's Farm			
		22	8	0.3	South of BVPS Transmission Line			
29A	3	8.3	Nicol's Farm					
12	Precipitation	30	4	0.5	Shippingport (S.S.)	Weekly grab samples when available	Quarterly Composite (c)	Gamma-scan, H-3
		47	14	4.9	East Liverpool, Oh. - Water Treatment Plant			
		48	10	16.3	Weirton, W.Va. - Weirton Water Tower, Collier Way			

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Table 2-1 - Notations

Operational Radiological Environmental Monitoring Program (Continued)

Notes:

- (a) Control sample station: These are locations which are presumed to be outside the influence of plant effluents.
- (b) Particulate samples are not counted within 24 hours after filter change. Perform gamma isotopic analysis on each sample when gross beta is > 10 times the yearly mean of control samples.
- (c) Analysis composites are well mixed actual samples prepared of equal portions from each shorter term samples from each location.
- (d) Composite samples are collected at intervals not exceeding 2 hours.
- (e) Weekly milk sample from Searight's Dairy is analyzed for I-131 only.
- (f) Milk samples are collected bi-weekly when animals are in pasture and monthly at other times.
- (g) The fish samples will contain whatever species are available. If the available sample size permits, then the sample will be separated according to species and compositing will provide one sample of each species. If the available size is too small to make separation by species practical, then edible parts of all fish in the sample will be mixed to give one sample.
- (h) Composite samples are obtained by collecting an aliquot at intervals not exceeding 2 hours at location 2.1. A weekly grab sample is obtained from daily composited grab samples obtained by the water treatment plant operator at location 5. For location 49, a weekly grab sample is obtained by a field technician.
- (i) Two (2) TLDs are collected quarterly from each monitoring location.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

2. Summary of Results

All results of this monitoring program are summarized in Table 2-2. This table is prepared in the format specified by NRC Regulatory Guide 4.8 and in accordance with Beaver Valley Power Station Offsite Dose Calculation Manual. Summaries of results of analysis of each media are discussed in Sections 2-B through 2-H and an assessment of radiation doses are given in Section 2-I. Table 2-3 summarizes Beaver Valley Power Station preoperational ranges for the various sampling media during the years 1974 and 1975. Comparisons of preoperational data with operational data indicate the ranges of values are generally in good agreement for both periods of time.

Activity detected was attributed to naturally occurring radionuclides, BVPS effluents, previous nuclear weapons tests or to the normal statistical fluctuation for activities near the lower limit of detection (LLD).

The conclusion from all program data is that the operation of the Beaver Valley Power Station has resulted in no significant changes to the environment.

3. Quality Control Program

The Quality Control Program implemented by the Beaver Valley Power Station to assure reliable performance by the contractor and the supporting QC data are presented and discussed in Section 4 of this report.

4. Program Changes

The following changes were implemented in the 2001 sampling program.

None

Environmental Monitoring Program Results

Table 2-2

ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY
Name of Facility Beaver Valley Power Station Unit 1 and 2 **Docket No.** 50-334/50-412
Location of Facility Beaver, Pennsylvania **Reporting Period** Annual 2001
 (County, State)

Medium of Pathway Sampled (Unit of Measurement)	Type and Total Number of Analysis Performed	Lower Limit of Detection * (LLD)	All Indicator Locations ** Mean (f) ** Range	Location with Highest Annual Mean Name Distance and Directions	** Mean (f) ** Range	Control Locations ** Mean (f) ** Range	Number of Nonroutine Reported Measurements***
						Weirton, WV No. 48	
Water Precipitation (pCi/l)	Gamma (12)						
	Mn-54	5	LLD	--	--	--	0
	Fe-59	10	LLD	--	--	--	0
	Co-58	5	LLD	--	--	--	0
	Co-60	5	LLD	--	--	--	0
	Zn-65	10	LLD	--	--	--	0
	Zr/Nb-95	5	LLD	--	--	--	0
	Cs-134	5	LLD	--	--	--	0
	Cs-137	5	LLD	--	--	--	0
Ba/La-140	10	LLD	--	--	--	0	
	H-3 (12)	200	410 (4/12) (242-577)	30, Shippingport, (S.S.) 0.5 mi ENE	410 (4/4) (242-577)	LLD	0

* Nominal Lower Limit of Detection (LLD)
 ** Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (f)
 *** Nonroutine reported measurements are defined in Regulatory Guide 4.8 (December 1975).

ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY
Name of Facility Beaver Valley Power Station Unit 1 and 2 Docket No. 50-334/50-412
Location of Facility Beaver, Pennsylvania Reporting Period Annual 2001
 (County, State)

Medium of Pathway Sampled (Unit of Measurement)	Type and Total Number of Analysis Performed	Lower Limit of Detection * (LLD)	All Indicator Locations ** Mean (f) ** Range	Location with Highest Annual Mean Name Distance and Directions	** Mean (f) ** Range	Control Locations ** Mean (f) ** Range	Number of Nonroutine Reported Measurements***
Groundwater (pCi/l)	H-3 (6)	200	214 (1/4)	11, Shippingport Boro 0.8 mi NE	214 (1/6)	LLD	0
	Gamma (6)					Georgetown, PA No. 15	
	Mn-54	5	LLD	--	--	--	0
	Fe-59	10	LLD	--	--	--	0
	Co-58	5	LLD	--	--	--	0
	Co-60	5	LLD	--	--	--	0
	Zn-65	10	LLD	--	--	--	0
	Zr/Nb-95	5	LLD	--	--	--	0
	Cs-134	5	LLD	--	--	--	0
	Cs-137	5	LLD	--	--	--	0
Ba/La-140	10	LLD	--	--	--	0	

* Nominal Lower Limit of Detection (LLD)

** Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (f)

*** Nonroutine reported measurements are defined in Regulatory Guide 4.8 (December 1975).

ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY
Name of Facility Beaver Valley Power Station Unit 1 and 2 Docket No. 50-334/50-412
Location of Facility Beaver, Pennsylvania Reporting Period Annual 2001
 (County, State)

Medium of Pathway Sampled (Unit of Measurement)	Type and Total Number of Analysis Performed	Lower Limit of Detection * (LLD)	All Indicator Locations ** Mean (f) ** Range	Location with Highest Annual Mean Name Distance and Directions ** Mean (f) ** Range	Control Locations ** Mean (f) ** Range	Number of Nonroutine Reported Measurements***	
Drinking Water (pCi/l)	I-131 (100)	1.0 / 0.5 (1)	0.81 (58/100) (0.20-1.90)	4, Midland Water Treatment Plant 1.3 mi NNW	0.84 (29/50) (0.40-1.90)	--	0
	H-3 (8)	200	LLD		LLD	--	0
	Gamma (24)						
	Mn-54	5	LLD	--	--	--	0
	Fe-59	10	LLD	--	--	--	0
	Co-58	5	LLD	--	--	--	0
	Co-60	5	LLD	--	--	--	0
	Zn-65	30 / 10 (1)	LLD	--	--	--	0
	Zr/Nb-95	15 / 5 (1)	LLD	--	--	--	0
	Cs-134	5	LLD	--	--	--	0
Cs-137	5	LLD	--	--	--	0	
Ba/La-140	15 / 10 (1)	LLD	--	--	--	0	

(1) LLD for first vendor (1st Quarter 2001) / LLD for second vendor (remainder of 2001).

* Nominal Lower Limit of Detection (LLD)
 ** Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (f)
 *** Nonroutine reported measurements are defined in Regulatory Guide 4.8 (December 1975).

ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY
Name of Facility Beaver Valley Power Station Unit 1 and 2 Docket No. 50-334/50-412
Location of Facility Beaver, Pennsylvania Reporting Period Annual 2001
 (County, State)

Medium of Pathway Sampled (Unit of Measurement)	Type and Total Number of Analysis Performed	Lower Limit of Detection * (LLD)	All Indicator Locations ** Mean (f) ** Range	Location with Highest Annual Mean Name Distance and Directions ** Mean (f) ** Range	Control Locations ** Mean (f) ** Range	Number of Nonroutine Reported Measurements***
Surface Water (pCi/l)	I-131 (51)	1.0 / 0.5 (1)	1.01 (32/51) (0.30-3.70)	One Sample Location	49, Upstream side of Montgomery Dam One sample location	0
	H-3 (12)	200	209 (1/12)	2.1, Downstream Midland - J&L 1.5 mi WNW	209 (1/4) LLD	0
	Gamma (36)					
	Mn-54	5	LLD	--	--	0
	Fe-59	15 / 10 (1)	LLD	--	--	0
	Co-58	5	LLD	--	--	0
	Co-60	5	LLD	--	--	0
	Zn-65	30 / 10 (1)	LLD	--	--	0
	Zr/Nb-95	15 / 5 (1)	LLD	--	--	0
	Cs-134	5	LLD	--	--	0
	Cs-137	5	LLD	--	--	0
	Ba/La-140	15	LLD	--	--	0
	Ra-226	(a)	66 (1/12)	49, Upstream side, of Montgomery Dam 5.0 mi NE	66 (1/12) 66 (1/12)	0
	Th-228	(a)	0.84 (1/12)	49, Upstream side, of Montgomery Dam 5.0 mi NE	0.84 (1/12) 0.84 (1/12)	0

(1) LLD for first vendor (1st Quarter 2001) / LLD for second vendor (remainder of 2001).

(a) LLD for this nuclide for water not required by ODCM.

* Nominal Lower Limit of Detection (LLD)

** Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (f)

*** Nonroutine reported measurements are defined in Regulatory Guide 4.8 (December 1975).

Table 2-2 (Continued)

Environmental Monitoring Program Results

ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY
Name of Facility Beaver Valley Power Station Unit 1 and 2 **Docket No.** 50-334/50-412
Location of Facility Beaver, Pennsylvania **Reporting Period** Annual 2001
(County, State)

Medium of Pathway Sampled (Unit of Measurement)	Type and Total Number of Analysis Performed	Lower Limit of Detection * (LLD)	All Indicator Locations ** Mean (f) ** Range	Location with Highest Annual Mean Name Distance and Directions	** Mean (f) ** Range	Control Locations ** Mean (f) ** Range	Number of Nonroutine Reported Measurements***
Sediment (pCi/g) (dry weight)	Gamma (6)			Montgomery Dam No. 49			
	K-40	(a)	11.07 (6/6) (7.10-15.80)	49, Upstream side of Montgomery Dam 5.0 mi NE	14.20 (2/2) (12.60-15.80)	Same as High Location	0
	Co-58	(a)	0.22 (2/6) (0.20-0.23)	2A, BVPS Outfall 0.2 mi W	0.22 (2/2) (0.20-0.23)	None Detected	0
	Co-60	(a)	0.82 (2/6) (0.70-0.93)	2A, BVPS Outfall 0.2 mi W	0.82 (2/6) (0.70-0.93)	None Detected	0
	Cs-134	0.06	--	--	--	None Detected	0
	Cs-137	0.08	0.13 (5/6) (0.07-0.16)	2A, BVPS Outfall 0.2 mi W & 49, Upstream side of Montgomery Dam 5.0 mi NE	0.15 (4/4) (0.14-0.16)	Same as High Location	0
	Ra-226	(a)	1.85 (6/6) (1.21-2.35)	49, Upstream side of Montgomery Dam 5.0 mi NE	2.26 (2/2) (2.16-2.35)	Same as High Location	0

(a) LLD for this nuclide for Sediment not required by ODCM

* Nominal Lower Limit of Detection (LLD)
** Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (f)
*** Nonroutine reported measurements are defined in Regulatory Guide 4.8 (December 1975).

ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY
Name of Facility Beaver Valley Power Station Unit 1 and 2 Docket No. 50-334/50-412
Location of Facility Beaver, Pennsylvania Reporting Period Annual 2001
 (County, State)

Medium of Pathway Sampled (Unit of Measurement)	Type and Total Number of Analysis Performed	Lower Limit of Detection * (LLD)	All Indicator Locations ** Mean (f) ** Range	Location with Highest Annual Mean Name Distance and Directions	** Mean (f) ** Range	Control Locations ** Mean (f) ** Range	Number of Nonroutine Reported Measurements***
						Windsheimer No. 96	
Milk (pCi/l)	I-131 (146)	1.0 / 0.5 (1)	0.6 (4/146) (0.4-0.8)	27, Brunton's Farm 6.1 mi SE	0.7 (3/18) (0.5-0.8)	0.4 (1/18)	0
	Sr-89 (126)	2.0	LLD				
	Sr-90 (126)	0.7	1.9 (116/126) (0.6-5.1)	69 Collins 3.5 mi SE	3.5 (18/18) (1.5-5.1)	1.6 (19/21) (0.6-4.6)	0
	Gamma (126)						
	K-40	(a)	1429 (126/126) (1079/2048)	69 Collins 3.5 mi SE	1729 (18/18) (1350-2048)	1484 (21/21) (1290-1608)	0
	Cs-134	5	LLD	--	--	--	0
	Cs-137	5	LLD	--	--	--	0
Ba/La-140	15 / 10 (1)	LLD	--	--	--	0	

(1) LLD for first vendor (1st Quarter 2001) / LLD for second vendor (remainder of 2001).
 (a) LLD for this nuclide for Milk not required by ODCM

* Nominal Lower Limit of Detection (LLD)
 ** Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (f)
 *** Nonroutine reported measurements are defined in Regulatory Guide 4.8 (December 1975).

ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY
Name of Facility Beaver Valley Power Station Unit 1 and 2 Docket No. 50-334/50-412
Location of Facility Beaver, Pennsylvania Reporting Period Annual 2001
 (County, State)

Medium of Pathway Sampled (Unit of Measurement)	Type and Total Number of Analysis Performed	Lower Limit of Detection * (LLD)	All Indicator Locations ** Mean (f) ** Range	Location with Highest Annual Mean Name Distance and Directions ** Range	Control Locations		Number of Nonroutine Reported Measurements***
					** Mean (f) ** Range	** Mean (f) ** Range	
						Weirton, WV No. 48	
Food and Garden Crops (pCi/g) (wet weight)	I-131 (4)	0.06	LLD	--	--	--	0
	Gamma (4)						
	K-40	(a)	3.0 (4/4) (1.8-5.2)	46, Industry, Midway Dr. 2.5 mi NE	5.2 (1/1)	2.6 (1/1)	0
	Cs-134	0.06	LLD	--	--	--	0
	Cs-137	0.06	LLD	--	--	--	0

Environmental Monitoring Program Results

Table 2-2 (Continued)

Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report

(a) LLD for this nuclide for Food and Garden Crops not required by ODCM

* Nominal Lower Limit of Detection (LLD)

** Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (f)

*** Nonroutine reported measurements are defined in Regulatory Guide 4.8 (December 1975).

Table 2-2 (Continued)

Environmental Monitoring Program Results

ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY
Name of Facility Beaver Valley Power Station Unit 1 and 2 Docket No. 50-334/50-412
Location of Facility Beaver, Pennsylvania Reporting Period Annual 2001
 (County, State)

Medium of Pathway Sampled (Unit of Measurement)	Type and Total Number of Analysis Performed	Lower Limit of Detection * (LLD)	All Indicator Locations ** Mean (f) ** Range	Location with Highest Annual Mean Name Distance and Directions	** Mean (f) ** Range	Control Locations ** Mean (f) ** Range	Number of Nonroutine Reported Measurements***
Upstream Montgomery Dam No. 49							
Fish (pCi/g) (wet weight)	Gamma (8)						
	Mn-54	0.05	LLD	--	--	--	0
	Fe-59	0.10	LLD	--	--	--	0
	Co-58	0.05	LLD	--	--	--	0
	Co-60	0.05	LLD	--	--	--	0
	Zn-65	0.10	LLD	--	--	--	0
	Cs-134	0.05	LLD	--	--	--	0
	Cs-137	0.06	LLD	--	--	--	0

* Nominal Lower Limit of Detection (LLD)
 ** Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (f)
 *** Nonroutine reported measurements are defined in Regulatory Guide 4.8 (December 1975).

ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY
Name of Facility Beaver Valley Power Station Unit 1 and 2 Docket No. 50-334/50-412
Location of Facility Beaver, Pennsylvania Reporting Period Annual 2001
 (County, State)

Medium of Pathway Sampled (Unit of Measurement)	Type and Total Number of Analysis Performed	Lower Limit of Detection * (LLD)	All Indicator Locations ** Mean (f) ** Range	Location with Highest Annual Mean Name Distance and Directions	** Mean (f) ** Range	Control Locations ** Mean (f) ** Range	Number of Nonroutine Reported Measurements***
External Radiation (mR/day)	Gamma (174)	0.05	0.19 (174/174) (0.11-0.26)	84, Hancock Co. Parks & Recreation Center 8.3 mi SW	0.23 (4/4) (0.20-0.26)	Weirton, WV No. 48 0.21 (4/4) (0.16-0.24)	0
Feed and Forage (pCi/g) (wet)	Gamma (12)						
	Bc-7	(a)	1.2 (7/12) (0.8-2.3)	One sample location	--	One sample location	0
	K-40	(a)	13.2 (12/12) (9.0-17.5)	One sample location	--	One sample location	0
	I-131	(a)	None Detected	One sample location	--	One sample location	0
	Cs-134	(a)	None Detected	One sample location	--	One sample location	0
	Cs-137	(a)	None Detected	One sample location	--	One sample location	0

(a) LLD for this nuclide for Feed and Forage not required by ODCM

* Nominal Lower Limit of Detection (LLD)
 ** Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (f)
 *** Nonroutine reported measurements are defined in Regulatory Guide 4.8 (December 1975).

ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY
Name of Facility Beaver Valley Power Station Unit 1 and 2 Docket No. 50-334/50-412
Location of Facility Beaver, Pennsylvania Reporting Period Annual 2001
 (County, State)

Environmental Monitoring Program Results

Table 2-2 (Continued)

Medium of Pathway Sampled (Unit of Measurement)	Type and Total Number of Analysis Performed	Lower Limit of Detection * (LLD)	All Indicator Locations ** Mean (f) ** Range	Location with Highest Annual Mean Name Distance and Directions ** Mean (f) ** Range	Control Locations ** Mean (f) ** Range	Number of Nonroutine Reported Measurements***	
					Weirton, WV No. 48		
Air Particulate and Radioiodine (X10-3 pCi/Cu.M.)	Gross Beta (530)	2	23 (530/530) (8-56)	32, Midland (S.S.) 0.8 mi NW	24 (53/53) (11-50)	23 (53/53) (8-45)	0
	I-131(530)	0.04	LLD	--	--	0	
	Gamma (40)						
	Be-7	(a)	63 (40/40) (37-87)	51, Aliquippa, Sub Station 8.0 mi E	67 (4/4) (48-87)	62 (4/4) (50-77)	0
	Cs-134	0.8/0.5 (1)	LLD	--	--	0	
	Cs-137	0.7/0.5 (1)	LLD	--	--	0	

(1) LLD for first vendor (1st Quarter 2001) / LLD for second vendor (remainder of 2001).

(a) LLD for this nuclide for Air Particulate not required by ODCM

* Nominal Lower Limit of Detection (LLD)

** Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (f)

*** Nonroutine reported measurements are defined in Regulatory Guide 4.8 (December 1975).

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Table 2-3

Pre-Operational Environmental Radiological Monitoring Program Summary

Name of Facility Beaver Valley Power Station Docket No. 50-334

Location of Facility Beaver, Pennsylvania Reporting Level CY 1974 - 1975
(County) (State)

Pre-Operational Program Summary (Combined 1974 - 1975)

Medium or Pathway Sampled (Unit of Measurement)	Analysis and Total Number of Analysis Performed	Lower Limit of Detection (LLD)	All Indicator Locations Mean, (f) Range		
Sediments pCi/g (dry)	Gross Alpha (0)	--	--	--	--
	Gross Beta (33)	1	18	(33/33)	5 - 30
	Sr-90 (0)	--	--	--	--
	U-234, 235, 238 (0)	--	--	--	--
	Gamma (33)	--	13	(33/33)	2 - 30
	K-40	1.5	13	(33/33)	2 - 30
	Cs-137	0.1	0.4	(21/33)	0.1 - 0.6
	Zr/Nb-95	0.05	0.8	(12/33)	0.2 - 3.2
	Ce-144	0.3	0.5	(3/33)	0.4 - 0.7
	Ru-106(a)	0.3	1.5	(3/33)	1.3 - 1.8
Others	--	--	< LLD	--	--
Foodstuff pCi/g (dry)	Gamma (8)	--	--	--	--
	K-40	1	33	(8/8)	10 - 53
	Cs-137	0.1	0.2	(1/8)	--
	Zr/Nb-95	0.05	0.2	(1/8)	--
	Ru-106(a)	0.3	0.8	(1/8)	--
Others	--	--	< LLD	--	--
Feedstuff pCi/g (dry)	Gross Beta (80)	0.05	19	(80/80)	8 - 50
	Sr-89 (81)	0.025	0.2	(33/81)	0.04 - 0.93
	Sr-90 (81)	0.005	0.4	(78/81)	0.02 - 0.81
	Gamma (81)	--	--	--	--
	K-40	1	19	(75/81)	5 - 46
	Cs-137	0.1	0.5	(6/81)	0.2 - 1.6
	Ce-144	0.3	1.5	(5/81)	0.9 - 2.6
	Zr/Nb-95	0.05	0.8	(13/81)	0.2 - 1.8
	Ru-106(a)	0.3	1.4	(12/81)	0.6 - 2.3
Others	--	--	< LLD	--	--
Soil pCi/g (dry) (Template Samples)	Gross Alpha (0)	--	--	--	--
	Gross Beta (64)	1	22	(64/64)	14 - 32
	Sr-89 (64)	0.25	0.4	(1/64)	--
	Sr-90 (64)	0.05	0.3	(48/64)	0.1 - 1.3
	U-234, 235, 238 (0)	--	--	--	--
	Gamma (64)	--	--	--	--
	K-40	1.5	13	(63/64)	5 - 24
	Cs-137	0.1	1.5	(56/64)	0.1 - 6.8
	Ce-144	0.3	1.1	(7/64)	0.2 - 3
	Zr/Nb-95	0.05	0.3	(13/64)	0.1 - 2
	Ru-106(a)	0.3	1.1	(3/64)	0.5 - 2
Others	--	--	< LLD	--	--

(f) Fraction of detectable measurements at specified location.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Table 2-3 (Continued)

Pre-Operational Environmental Radiological Monitoring Program Summary

Name of Facility Beaver Valley Power Station **Docket No.** 50-334

Location of Facility Beaver, Pennsylvania **Reporting Level** CY 1974 - 1975
(County) (State)

Pre-Operational Program Summary (Combined 1974 - 1975)

Medium or Pathway Sampled (Unit of Measurement)	Analysis and Total Number of Analysis Performed	Lower Limit of Detection (LLD)	All Indicator Locations Mean, (f) Range		
Soil pCi/g (dry) (Core Samples)	Gross Alpha (0)	--	--	--	--
	Gross Beta (8)	1	21	(8/8)	16 - 28
	Sr-89 (8)	0.25	< LLD	< LLD	< LLD
	Sr-90 (8)	0.05	0.2	(5/8)	0.08 - 0.5
	Gamma (8)	--	--	--	--
	K-40	1.5	13	(8/8)	7 - 20
	Cs-137	0.1	1.2	(7/8)	0.2 - 2.4
	Co-60	0.1	0.2	(1/8)	--
	Others	--	< LLD	< LLD	< LLD
Surface Water pCi/l	Gross Alpha (40)	0.3	0.75	(5/40)	0.6 - 1.1
	Gross Beta (120)	0.6	4.4	(120/120)	2.5 - 11.4
	Gamma (1)	10 - 60	< LLD	< LLD	< LLD
	Tritium (121)	100	300	(120/121)	180 - 800
	Sr-89 (0)	--	--	--	--
	Sr-90 (0)	--	--	--	--
	C-14 (0)	--	--	--	--
Drinking Water pCi/l	I-131 (0)	--	--	--	--
	Gross Alpha (50)	0.3	0.6	(4/50)	0.4 - 0.8
	Gross Beta (208)	0.6	3.8	(208/208)	2.3 - 6.4
	Gamma (0)	--	--	--	--
	Tritium (211)	100	310	(211/211)	130 - 1000
	C-14 (0)	--	--	--	--
	Sr-89 (0)	--	--	--	--
	Sr-90 (0)	--	--	--	--
Ground Water pCi/l	Gross Alpha (19)	0.3	< LLD	< LLD	< LLD
	Gross Beta (76)	0.6	2.9	(73/75)(b)	1.3 - 8.0
	Tritium (81)	100	440	(77/81)	80 - 800
	Gamma (1)	10 - 60	< LLD	< LLD	< LLD
Air Particulates and Gaseous pCi/m ³	Gross Alpha (188)	0.001	0.003	(35/188)	0.002 - 0.004
	Gross Beta (927)	0.006	0.07	(927/927)	0.02 - 0.32
	Sr-89 (0)	--	--	--	--
	Sr-90 (0)	--	--	--	--
	I-131 (816)	0.04	0.08	(2/816)	0.07 - 0.08
	Gamma (197)	--	--	--	--
	Zr/Nb-95	0.005	0.04	(122/197)	0.01 - 0.16
	Ru-106	0.010	0.04	(50/197)	0.02 - 0.09
	Ce-141	0.010	0.02	(3/197)	0.01 - 0.04
	Ce-144	0.010	0.02	(44/197)	0.01 - 0.04
	Others	--	< LLD	< LLD	< LLD
	(f) Fraction of detectable measurements at specified location.				

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Table 2-3 (Continued)

Pre-Operational Environmental Radiological Monitoring Program Summary

Name of Facility Beaver Valley Power Station **Docket No.** 50-334

Location of Facility Beaver, Pennsylvania **Reporting Level** CY 1974 - 1975
(County) (State)

Pre-Operational Program Summary (Combined 1974 - 1975)

Medium or Pathway Sampled (Unit of Measurement)	Analysis and Total Number of Analysis Performed	Lower Limit of Detection (LLD)	All Indicator Locations Mean, (f) Range		
Milk pCi/l	I-131 (91)	0.25	0.6	(4/91)	0.3 - 0.8
	Sr-89 (134)	5	7	(4/134)	6 - 11
	Sr-90 (134)	1	5.3	(132/134)	1.5 - 12.8
	Gamma (134)	--	--	--	--
	Cs-137 (134)	10	13	(19/134)	11 - 16
	Others			< LLD	
External Radiation mR/day	γ - Monthly (599)	0.5 mR*	0.20	(599/599)	0.08 - 0.51
	γ - Quarterly (195)	0.5 mR*	0.20	(195/195)	0.11 - 0.38
	γ - Annual (48)	0.5 mR*	0.19	(48/48)	0.11 - 0.30
Fish pCi/g (wet)	Gross Beta (17)	0.01	1.9	(15/17)	1.0 - 3.2
	Sr-90 (17)	0.005	0.14	(17/17)	0.02 - 0.50
	Gamma (17)	0.5			
	K-40 (17)	--	2.4	(17/17)	1.0 - 3.7
	Others		--	< LLD	
<p>* LLD in units of mR - Lower end of useful integrated exposure detectability range for a passive radiation detector (TLD).</p> <p>(a) May include Ru-106, Ru-103, Be-7.</p> <p>(b) One outlier not included in mean. (Water taken from dried-up spring with high sediment and potassium content. Not considered typical groundwater sample).</p> <p>(f) Fraction of detectable measurements at specified location.</p>					

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

B. Air Monitoring

1. Characterization of Air and Meteorology

The air in the vicinity of the site contains pollutants typical for an industrial area. Air flow is generally from the southwest in summer and from the northwest in the winter.

2. Air Sampling Program and Analytical Techniques

a. Program

The air is sampled for gaseous radioiodine and radioactive particulates at each of ten (10) offsite air sampling stations. The locations of these stations are listed in Table 2-1 and shown on a map in Figure 2-1.

The air sample stations were upgraded during the year and as a result of the upgrade, sample flow was increased from one to two cubic feet per minute. The charcoal filters were changed in order to maintain collection efficiency at the higher flow rate.

Samples are collected at each of these stations by continuously drawing one to two cubic feet per minute of atmosphere air through a glass fiber filter and through a charcoal cartridge. The former collects airborne particulates; the latter is for radioiodine sampling. Samples are collected for analysis on a weekly basis.

The charcoal is used in the weekly analysis of airborne I-131. The filters are analyzed each week for gross beta, then composited by station for quarterly analysis by gamma spectrometry. In order to reduce interference from natural radon and thoron radioactivities, all filters are allowed to decay for a few days after collection prior to counting for beta in a low background counting system.

b. Procedures

Gross beta analysis is performed by placing the filter paper from the weekly air sample in a 2" planchet and counting it in a low background, gas flow proportional counter.


Gamma emitters are determined by stacking all the filter papers from each monitoring station collected during the quarter and scanning this composite on a high resolution germanium gamma spectrometer.

Radioiodine (I-131) analysis is performed by a gamma scan of the charcoal in a weekly charcoal cartridge.

Beaver Valley Power Station 2001 Annual Radiological Environmental Operating Report

Figure 2-1

Air Sampling Stations



Site No.	Sector	Distance (miles)	Location	Site No.	Sector	Distance (miles)	Location
13	11	1.4	Meyer's Farm	32	15	0.8	Midland (S.S.)
27	7	6.1	Brunton's Farm	46.1	3	2.3	Industry Rt. 68 - Garage
28	1	8.6	Sherman's Farm	47	14	4.9	East Liverpool, Oh. - Water Treatment Plant
29B	3	8.0	Beaver Valley Geriatric Center	48	10	16.3	Weirton, W.Va. - Weirton Water Tower Collier Way
30	4	0.5	Shippingport (S.S.)	51	5	8.0	Aliquippa (S.S.)
30A	4	0.5	Shippingport (S.S.)				

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

3. Results and Conclusions

A summary of data is presented in Table 2-2.

a. Airborne Radioactive Particulates

A total of five hundred thirty (530) weekly samples from ten (10) locations were analyzed for gross beta. Results were comparable to previous years. Figure 2-2 illustrates the weekly average concentration of gross beta in air particulates.

For the week ending 11/19/01, the average for the air particulate gross beta counts were approximately double the results of the yearly average. The Control location, which is considered outside the influence of the Beaver Valley Power Station, also indicated the elevated readings that week. When the quarterly gamma spectroscopy analysis was performed, only naturally occurring isotopes were identified (see below). Three Mile Island, Limerick, Davis Besse, and the Pennsylvania Department of Environmental Protection (Pa. DEP) have also experienced elevated readings in the same range as BVPS. No evidence points to the elevated readings being the result of plant operations.

The weekly air particulate samples were composited to forty (40) quarterly samples which were analyzed by gamma spectrometry. Naturally occurring beryllium-7 (Be-7) was present in all samples. No other radionuclides were detected. Results are listed in the summary Table 2-2.

Based on the analytical results, the operation of Beaver Valley Power Station did not contribute any measurable increase in air particulate radioactivity during 2001.

b. Radioiodine

A total of five hundred thirty (530) weekly charcoal filter samples were analyzed for I-131. No detectable concentrations were present at any locations.

Based on analytical results, the operation of Beaver Valley Power Station did not contribute any measurable increase in airborne radioiodine during 2001.


**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

- c. Deviations from required sampling/analysis schedule
- CR 01-4411 was written because the vendor lost four of the thirteen weekly air particulate samples from site 13 in the first quarter. The weekly gross beta analysis was performed on all the weekly samples from site 13; however, when they were ready to perform the quarterly composite gamma spectroscopy analysis for site 13, only 9 of the 13 weeks could be located. The vendor performed the gamma spectroscopy analysis with the 9 available weekly samples with the results indicating only naturally occurring Be-7 being identified. The DEP has an air sampling station co-located with BVPS at site 13. Results from the DEP first quarter composite was less than (L.T.) $1\text{E-}4$ pCi/m³ for both cesium-134 (Cs-134) and Cs-137. The weekly gross beta analysis results for the four weeks that were later lost were all within normal range with 3 of the 4 being below the Control location. This condition report also documents the vendors failure to meet the sensitivities for barium-140 (Ba-140) as stated in 1/2-ENV-02.01 for all ten air sampling sites during the quarterly gamma spectroscopy analysis. All other sensitivities for air sample analysis were met. It should be noted that Ba-140 does not have an ODCM required LLD to be met. This was the last report from this vendor. Starting on 4/1/02, BVPS began using a new vendor and no other occurrences of this nature have resulted.
 - CR 01-3637 was written to document BVPS response to OE 12361. OE 12361 concerned F&J holders used for air particulate/charcoal cartridge air sampling for a REMP program. The problem concerned the charcoal cartridge being loose in the holder and air being allowed to bypass the charcoal cartridge instead of going through it. BVPS reviewed the holders used for REMP air sampling at BVPS. It was found that BVPS uses Model RVH-35 from Hi-Q Environmental Products Co. not the holders in question. Also, the holder used by BVPS was loaded with the air and charcoal filters and it was found that there was no indication that the charcoal cartridge was loose as described in the OE. In addition, BVPS has vacuum gauges that would indicate a leak (lowered resistance).

Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report

Figure 2-2

Average Concentration of Gross Beta in Air Particulates



**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

C. Monitoring of Sediments and Soils

1. Characterization of Stream Sediments and Soils

The stream sediments consist largely of sand and silt. Soil samples may vary from sand and silt to a heavy clay with variable amounts of organic material.

2. Sampling Program and Analytical Techniques

a. Program

River bottom sediments were collected semi-annually above the Montgomery Dam, in the vicinities of the Beaver Valley discharge and above the New Cumberland Dam. A Ponar or Eckman dredge is used to collect the sample. The sampling locations are also listed in Table 2-1 and are shown in Figure 2-3.

Soil samples were not required in 2001. The next year for sampling is 2003. Sampling locations are listed in Table 2-1 and are shown in Figure 2-3.

Bottom sediments and soils are analyzed for gamma-emitting radionuclides.


b. Analytical Procedures

Gamma analysis of sediment or soil is performed in a 300 ml plastic bottle which is counted by a gamma spectrometer.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Figure 2-3

Environmental Monitoring Locations - Shoreline Sediments and Soil



SOIL SAMPLING LOCATIONS							
Site No.	Sector	Distance (miles)	Location	Site No.	Sector	Distance (miles)	Location
13	11	1.4	Meyer's Farm	32	15	0.8	Midland (S.S.)
22	8	0.3	South of BVPS Transmission Line	46	3	2.5	Industry, Midway Dr.
27	7	6.1	Brunton's Farm	47	14	4.9	East Liverpool, Oh. - Water Treatment Plant
29A	3	8.3	Nicols Farm	48A	10	15.6	Weirton, W.Va. - Weirton Water Tower, E. Belleview Dr.
30	4	0.5	Shippingport (S.S.)	51	5	8.0	Aliquippa (S.S.)

SEDIMENT SAMPLING LOCATIONS							
Site No.	Sector	Distance (miles)	Location	Site No.	Sector	Distance (miles)	Location
2A	13	0.2	BVPS Outfall Discharge	50	12	11.8	Upstream Side of New Cumberland Dam
49	3	5.0	Upstream Side of Montgomery Dam				

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

3. Results and Conclusions

A summary of sediment analysis is presented in Table 2-2.

a. Sediment

A total of six (6) samples were analyzed by gamma spectrometry. Naturally occurring K-40 was detected in all six samples. Ra-226 was detected in six samples. Small amounts of Cs-137 from previous nuclear weapons tests were detected five of the six river sediment samples, including two upstream above Montgomery Dam, which is unaffected by plant effluents. Small amounts of Co-58 and Co-60 were detected in the Beaver Valley Power Station discharge area and are attributable to station releases. The activity detected in the station discharge area is consistent with station data of authorized radioactive discharges which were within limits permitted by the NRC license.

The positive results detected are attributable to authorized releases from the Beaver Valley Power Station and are characteristic of the effluent. These results confirm that the station assessments, prior to authorizing radioactive discharges, are adequate and that the environmental monitoring program is sufficiently sensitive.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

D. Monitoring of Feedcrops and Food Products

1. Characterization of Farm Products

According to the latest data from the 1999 Statistical Summary and Pennsylvania Department of Agriculture Annual Report, there were approximately 650 farms in Beaver County. The cash receipts from the sale of agricultural crops and livestock was \$16,199,000. The principal source of revenue was in dairy products which was estimated at \$7,020,000. Revenues from other farm products were estimated as follows:

Field Crops	\$1,703,000
Fruits	\$291,000
Horticulture and Mushrooms	\$3,894,000
Vegetables and Potatoes	\$372,000
Poultry and Meat Products	\$2,919,000

2. Sampling Program and Analytical Techniques

a. Program


Representative samples of cattle feed are collected monthly from the nearest dairy (Searight). See Figure 2-4. Each sample is analyzed by gamma spectrometry.

Food products (vegetables) were collected at garden locations during the summer of 2001. Leafy vegetables, i.e., cabbage, were obtained from Shippingport, Georgetown, Industry, PA, and Weirton, W.Va. All samples were analyzed for gamma emitters by gamma spectroscopy. Samples were also analyzed by radiochemical analysis for I-131.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Figure 2-4

Environmental Monitoring Program - Feedcrop and Food Product Locations



Sample Type	Site No.	Location
Food	10	Shippingport
Food	15	Georgetown
Food	46	Industry
Food	48	Weirton, W. Va.
Feed	25	Searight's Dairy

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

b. Procedures

Gamma emitters in feed are determined by scanning a dried, homogenized sample with the gamma spectroscopy system. A high resolution germanium detector is utilized with this system. Food samples are loaded into tared 300 or 150 ml plastic bottles or 1-liter Marinelli containers, weighed and the net weight of the sample is determined prior to scanning for gamma emitters.

I-131 in food crops is determined by radiochemistry. Stable iodide carrier is first added to a chopped sample which is then leached with sodium hydroxide solution, evaporated to dryness and fused in a muffle furnace. The melt is dissolved in water, filtered and treated with sodium hypochlorite. The iodate is then reduced to iodine with hydroxylamine hydrochloride and is extracted into toluene. It is then back-extracted as iodide into sodium bisulfite solution and is precipitated as palladium iodide. The precipitate is weighed for chemical yield and is mounted on a nylon planchet for low level beta counting.

3. Results and Conclusions

A summary of data is presented in Table 2-2.

a. Feed

A total of twelve (12) samples were analyzed by gamma spectroscopy. Only naturally occurring nuclides were identified, for example: K-40 in all the samples and Be-7 in seven (7).

CR 01-3132 was written for two monthly feed samples from site 25, January and February, because the vendor failed to achieve the procedurally required LLDs for I-131. Feed sampling is not required by the BVPS ODCM and there are no licensing required LLDs. The other procedurally required LLDs for these samples were met. No positive I-131 results were seen for the entire year from any of the 42 milk sample results obtained from this site. This vendor was replaced starting 4/1/01 and no other LLD occurrences have occurred for feed samples.

b. Food

A total of four (4) samples were analyzed for I-131. No detectable concentrations were present.

A total of four (4) samples were analyzed by gamma spectrometry. Naturally occurring K-40 was present in all samples. No other nuclides were identified.

c. The data from food and feed analyses were consistent with previous data. Based on the analytical results, the operation of the Beaver Valley Power Station did not contribute any measurable increase in radioactivity in the foods and feeds in the vicinity of the site.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

E. Monitoring of Local Cows Milk

1. Description - Milch Animal Locations

Samples of fresh milk are obtained from milch animals at locations and frequencies noted in Table 2-1. This milk is analyzed for its radioiodine content, gamma emitters, and strontium-89 and strontium-90.

Detailed field surveys are performed during the grazing season to locate and enumerate milch animals within a five (5) mile radius of the site. Survey data for the most recent survey conducted is shown in Section 3, Land Use Census.

2. Sampling Program and Analytical Techniques

a. Program

Milk was collected from two (2) reference dairy farms (Searight's and Brunton's) within a 10-mile radius of the site and from one (1) control location (Windsheimer's) outside of the 10-mile radius. Additional dairies, which represent the highest potential milk pathway for radioiodine based on milch animal surveys and meteorological data, were selected and sampled. These dairies are subject to change based upon availability of milk or when more recent data (milch animal census) indicate other locations are more appropriate. The location of each is shown in Figure 2-5 and described below.


Site	Dairy	Approximate Number of Animals being Milked	Direction and Distance from Midpoint of Unit 1 Reactor	Collection Period
25	Searight	51 Cows	2.1 miles SSW	Jan. - Dec.
27	Brunton	94 Cows	6.1 miles SE	Jan. - Dec.
69*	Collins	6 Goats	3.5 miles SE	Apr. - Dec.
96	Windsheimer	75 Cows	10.4 miles SSW	Jan. - Dec.
103*	Halstead	62 Cows	5.2 miles SSW	Jan. - Apr.
105*	Ambrose	32 Cows	3.9 miles WSW	Jan. - Dec.
106*	Conkle	32 Cows	3.7 miles WSW	Jan. - Dec.
* Highest potential pathway dairies				

The sample from Searight Dairy is collected and analyzed weekly for radioiodine using a procedure with a high sensitivity. Samples from each of the other selected dairies are collected monthly when cows are indoors, and bi-weekly when cows are grazing. This monthly or bi-weekly sample is analyzed for Sr-89, Sr-90, gamma emitters including Cs-137 (by high resolution germanium gamma spectroscopy) and I-131 (high sensitivity analysis).

Beaver Valley Power Station 2001 Annual Radiological Environmental Operating Report

Figure 2-5

Environmental Monitoring Locations - Milk



Site No.	Sector	Distance (miles)	Location	Site No.	Sector	Distance (miles)	Location
25	10	2.1	Searight's Farm	103*	10	5.2	Halstead Farm
27	7	6.1	Brunton's Farm	105*	12	3.8	Ambrose Farm
69*	7	3.4	Collins	106*	12	3.7	Conkle Farm
96	10	10.4	Windsheimer's Farm				

* Dairies selected based on highest deposition factors.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

b. Procedure

Radioiodine (I-131) analysis in milk was performed using chemically prepared samples and analyzed with a low-level beta counting system.

Gamma emitters are determined by gamma spectroscopy of a 1 liter Marinelli container of milk.

Strontium milk samples are prepared by adding stable strontium carrier and evaporating to dryness, then ashing in a muffle furnace, followed by precipitating phosphates. Strontium is purified in all samples by the Argonne method using 3 grams of extraction material in a chromatographic column. Stable yttrium carrier is added and the sample is allowed to stand for a minimum of 5 days for the ingrowth of yttrium-90 (Y-90). Yttrium is then precipitated as hydroxide, is dissolved and re-precipitated as oxalate. The yttrium oxalate is mounted on a nylon planchet and is counted in a low-level beta counter to infer Sr-90 activity. Sr-89 activity is determined by precipitating strontium carbonate (SrCO₃) from the sample after yttrium separation. This precipitate is mounted on a nylon planchet and is covered with an 80 mg/cm² aluminum absorber for low level beta counting. Chemical yields of strontium and yttrium are determined gravimetrically.

3. Results and Conclusions

A summary of data is presented in Table 2-2.

- a. A total of one hundred twenty-six (126) samples were analyzed for Sr-89 and Sr-90. No Sr-89 was detected. Sr-90 was detected in one hundred sixteen (116) samples at levels attributable to previous nuclear weapons tests and are within the normally expected range.
- b. A total of one hundred twenty-six (126) samples were analyzed by gamma spectroscopy. Naturally occurring K-40 was present in all samples. No other radionuclides were identified.
- c. A total of one hundred and forty-six (146) samples were analyzed for I-131 during 2001. I-131 activity was detected in four (4) samples below the required LLD. Three (3) were detected at the same location where the dairy farmer had obtained additional water from the Midland Water Plant (site 4) in 2001. This practice was noted to have also taken place in 1999. The fourth positive reading was detected at the Control location and was below the required LLD. Additional information may be found in Section 3-d (CR 02-00428).

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

- d. Five Condition Reports were written concerning milk sample analysis.
- CR 01-3446 was written because one milk sample taken 1/30/01 at site 25 was not analyzed. The vendor did not ship sample to subcontracted vendor for analysis. Once discovered, it was too late to count due to half-life concerns since analysis was for I-131. This vendor has since been replaced.
 - CR 01-2177 was written for one sample from site 25 taken 4/10/01 that was lost in shipment. This sample was for I-131 analysis only. This is the only sample lost in shipment for the year and this is not a recurring problem.
 - CR 01-2591 was written for twelve monthly milk samples taken in January and February because the vendor failed to achieve the procedurally required Lower Limit of Detection for Sr-89 (all 12 samples) and Ba-140 (1 sample). The twelve Sr-89 samples ranged from 3.9 to 4.5 pCi/liter, which is above the procedural requirement of 2 pCi/liter. The Ba-140 sample was 12 pCi/liter, which is above the procedural requirement of 10 pCi/liter. It should be noted that the Ba-140 result was within the required ODCM LLD value of 15 pCi/liter and that Sr-89 does not have a ODCM required LLD. At the time of analysis, the primary vendor was subcontracting out the work and did not effectively communicate the LLD requirements to the subcontracted vendor. Starting 4/1/01, a new primary vendor has been contracted and no LLD problems have been noted.
 - CR 01-0827 was written because seven environmental milk samples analyzed by the vendor failed to meet the required Lower Limit of Detection (LLD) for Sr-89. The required limit is 2 pCi/liter. For these seven samples, the LLDs ranged from 3.0 to 9.1 pCi/liter. Probable cause, as documented by the vendor, is "a longer than anticipated interruption in production" due to move to a new laboratory facility. Starting 4/1/01, a new primary vendor has been confirmed and no LLD problems have been noted.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

- CR 02-00428 was written to document the positive I-131 results found at site 27. Three of the eighteen milk samples from one of the indicator dairies (site 27) indicated positive for I-131 in 2001. All three were below the reporting level of 3 pCi/l and were also below the ODCM required Lower Level of Detection of 1.0 pCi/l (the range of the results were 0.5 to 0.8 pCi/l). This was seen in 1999 when we had seven positive I-131 results at this same dairy. The investigation in 1999 concluded that it was because the dairy had run out of water at the farm and was getting water from the Midland Water Dept. Again this year, the dairy needed to supplement their water with water from the Midland Water Dept. from July to end of December. BVPS has for many years seen positive I-131 results both upstream and downstream of the plant at low levels (including the Midland Water Plant). Evidence indicates that the positive milk results are likely from the cows drinking water from the Midland Water Plant. Brunton's was contacted and they confirmed that they still do not pasture their milk cows and their feed is from storage. This feed is stored from 2 to 10 months. All weekly iodine air samples at site 27 indicated < MDA.
- e. Based on all the analytical results and the above investigation, the operation of the Beaver Valley Power Station did not contribute any measurable increase in radioactivity in the milk in the vicinity of the site.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

F. Environmental Radiation Monitoring

1. Description of Regional Background Radiation and Sources

The terrain in the vicinity of the Beaver Valley Power Station generally consists of rough hills with altitude variations of 300-400 feet. Most of the land is wooded.

The principal geologic features of the region are nearly flat-laying sedimentary beds of the Pennsylvania Age. Beds of limestone alternate with sandstone and shale with abundant interbedded coal layers. Pleistocene glacial deposits partially cover the older sedimentary deposits in the northwest. Most of the region is underlain by shale, sandstone, and some coal beds of the Conemaugh Formation. Outcrops of sandstone, shale, and limestone of the Allegheny Formation exist within the Ohio River Valley and along major tributary streams.

Based on surveys reported in previous annual reports, exposure rates ranged from 6-12 $\mu\text{R/hr}$. Results for 2001 indicated that background radiation continued in this range.

2. Locations and Analytical Procedures

Ambient external radiation levels around the site were measured using thermoluminescent dosimeters (TLDs).

In 2001 there were a total of forty-four (44) offsite environmental TLD locations. The locations of the TLDs are shown in Figure 2-6.

The TLDs were annealed at the Contractor Central Laboratory shortly before placing the TLDs in their field locations. The radiation dose accumulated in-transit between the Central Laboratory, the field location, and the Central Laboratory was corrected by transit controls maintained in lead shields at both the Central Laboratory and the field office. All dosimeters were exposed in the field in a special environmental holder.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

3. Results and Conclusions

Data obtained with the contractor TLD during 2001 are summarized in Table 2-2.


The annual exposure rate of all offsite TLDs averaged 0.190 mR/day in 2001. As in previous years, there was some variation among locations and seasons as would be expected. In 2001, ionizing radiation dose determinations from TLDs averaged 69.4 mR for the year. This is comparable to previous years. There was no evidence of anomalies that could be attributed to the operation of the Beaver Valley Power Station. The TLDs confirm that changes from natural radiation levels, if any, are negligible.

In 2001, two TLD results were lost due to vandalism: [Ref: CR 01-7051 and CR 02-00428]

- Site No. 71 - 1st quarter
- Site No. 86 - 3rd quarter

Beaver Valley Power Station 2001 Annual Radiological Environmental Operating Report

Figure 2-6 TLD Locations



**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Figure 2-6 (Continued)

TLD Locations

SOUTHEAST							
Site No.	Sector	Distance (miles)	Location	Site No.	Sector	Distance (miles)	Location
27	7	6.1	Brunton's Farm	78	7	2.7	Raccoon Municipal Bldg
45.1	6	1.9	Raccoon Twp., Kennedy's Corners	79	8	4.4	Rt. 151 and Pross Ln.
51	5	8.0	Aliquippa (S.S.)	80	9	8.2	Raccoon Park
59	6	1.0	236 Green Hill Rd.	82	9	6.9	Hanover Municipal Building
76	6	3.8	Raccoon Elementary School	94	8	2.2	McCleary Road & Pole Cat Hollow Rd.
77	6	5.6	Raccoon Twp. (Green Garden Road)				

NORTHWEST							
Site No.	Sector	Distance (miles)	Location	Site No.	Sector	Distance (miles)	Location
15	14	3.7	Georgetown Post Office	87	14	7.0	Calcutta, Oh. - Calcutta Smiths Ferry Rd. & Valley Dr.
32	15	0.8	Midland (S.S.)	88	15	2.8	Midland Heights - 110 Summit Rd.
47	14	4.9	E. Liverpool, Oh. - Water Treatment Plant	89	15	4.8	Ohioville, 488 Smith Ferry Rd.
60	13	2.5	444 Hill Rd.	90	16	5.2	Opposite Fairview School
86	13	6.2	E. Liverpool, Oh. - 1090 Ohio Ave.	93	16	1.1	Midland Sunrise Hills

NORTHEAST							
Site No.	Sector	Distance (miles)	Location	Site No.	Sector	Distance (miles)	Location
10	3	1.0	Shippingport Boro	70	1	3.4	North of Western Beaver School - Engle Rd.
28	1	8.6	Sherman's Farm	71	2	6.0	Brighton Twp., First Western Bank
29B	3	8.0	Beaver Valley Geriatric Center	72	3	3.3	Industry, Logan Park
30	4	0.5	Shippingport (S.S.)	73	4	2.5	618 Squirrel Run Rd.
45	5	2.2	Rt. 18 & Anderson St.	74	4	7.0	CCBC, 137 Poplar Ave.
46	3	2.5	Industry Midway Dr.	75	5	4.1	117 Holt Road
46.1	3	2.3	Industry, Rt. 68 & Garage	91	2	3.9	Pine Grove Road & Doyle Road

SOUTHWEST							
Site No.	Sector	Distance (miles)	Location	Site No.	Sector	Distance (miles)	Location
13	11	1.4	Meyer's Farm	84	11	8.3	Hancock Co. Parks & Recreation Complex
14	11	2.5	Hookstown	85	12	5.7	Routes 8 & 30 Intersection
48	10	16.3	Weirton, W.Va. - Weirton Water Tower, Collier Way	92	12	2.8	Georgetown Road (S.S.)
81	9	3.6	Millcreek United Pres. Church	95	10	2.3	832 McCleary Road
83	10	4.2	735 Mill Creek Road				

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

G. Monitoring of Fish

1. Description

During 2001, fish collected for the radiological monitoring program included carp, hybrid bass, sauger, and catfish.

2. Sampling Program and Analytical Techniques

a. Program

Fish samples are collected semi-annually in the New Cumberland pool of the Ohio River at the Beaver Valley effluent discharge point and upstream of the Montgomery Dam. The edible portion of each different species caught is analyzed by gamma spectroscopy. Fish sampling locations are shown in Figure 2-7.

b. Procedure

A sample is prepared in a standard tared 300 ml plastic bottle and scanned for gamma emitting nuclides with gamma spectrometry system which utilizes a high resolution germanium detector.

3. Results and Conclusions

A summary of the results of the fish monitoring data is provided in Table 2-2.


A total of eight (8) samples were analyzed by gamma spectroscopy. No gamma emitting radionuclides were detected.

Based on the analytical results, the operation of the Beaver Valley Power Station did not contribute any measurable increase in radioactivity in the Ohio River fish population.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Figure 2-7

Environmental Monitoring Program - Fish Sampling Locations



Site No.	Sector	Distance (miles)	Location
2A	13	0.2	BVPS Outfall Discharge
49	3	5.0	Upstream side of Montgomery Dam

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

H. Monitoring of Surface, Drinking, Ground Waters and Precipitation

1. Description of Water Sources

The Ohio River is the main body of water in the area. It is used by the Beaver Valley Power Station for plant make-up for the cooling tower and for receiving plant liquid effluents.

Ohio River water is a source of water for some towns both upstream and downstream of the Beaver Valley Power Station site. It is used by several municipalities and industries downstream of the site. The nearest user of the Ohio River as a potable water source is Midland Borough Municipal Water Authority. The intake of the treatment plant is approximately 1.5 miles downstream and on the opposite side of the river. The next downstream user is East Liverpool, Ohio which is approximately 6 miles downstream. The heavy industries in Midland, as well as others downstream use river water for cooling purposes.

Groundwater occurs in large volumes in the gravel terraces which lie along the river, and diminishes considerably in the bedrock underlying the site. Normal well yields in the bedrock are less than 10 gallons per minute (gpm) with occasional wells yielding up to 60 gpm.

In general, the BVPS site experiences cool winters and moderately warm summers with ample annual precipitation evenly distributed throughout the year. The average annual precipitation for the area is 36.23 inches based on 1941 to 1970 data collected at the Pittsburgh International Airport.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

2. Sampling and Analytical Techniques

a. Surface (Raw River) Water

The sampling program of river water includes three (3) sampling points along the Ohio River. Raw water samples are normally collected at the East Liverpool (Ohio) Water Treatment Plant [River Mile 41.2] daily and composited into a weekly sample. One automatic river water sampler is located at J&L Steel's river water intake [River Mile 36.2]. The automatic sampler takes a 20-40 ml sample every 15 minutes and samples are collected on a weekly basis. A weekly grab sample is taken upstream of the Montgomery Dam [River Mile 29.6]. The weekly grab sample and automatic water sample are composited into monthly samples from each location. In addition, a quarterly composite sample is prepared for each sample point.

The weekly grab samples upstream of the Montgomery Dam are analyzed for I-131.

The monthly composites are analyzed for gamma emitters. The quarterly composites are analyzed for H-3.

Locations of each sample point are shown in Figure 2-8.

b. Drinking Water (Public Supplies)

Drinking (treated) water is collected at both Midland (PA) and East Liverpool (OH) Water Treating Plants. An automatic sampler at each location collects 20-40 ml every 20 minutes which is composited into a weekly sample. The weekly sample from each location is analyzed for I-131.

Monthly composites of the weekly samples are analyzed by gamma spectrometry. Quarterly composites are analyzed for H-3. Locations of each sample point are shown in Figure 2-8.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

c. Groundwater

Semi-annual grab samples were collected from three (3) locations (see Figure 2-8) within four (4) miles of the site. These locations are:

One (1) well in Shippingport, PA

One (1) well in Hookstown, PA

One (1) well in Georgetown, PA

Each ground water sample is analyzed for tritium and by gamma spectroscopy.

d. Precipitation

Precipitation is collected at Shippingport, Pa., East Liverpool, Oh. and Weirton, W.Va. Precipitation, when available, is collected each week and then composited into quarterly samples. The quarterly composites are analyzed for H-3 and gamma emitters. Locations of each sample point are shown in Figure 2-8.

e. Procedures

Gamma analysis is performed on water samples by placing one liter of the sample into a Marinelli container and counting the sample on a high resolution germanium gamma spectrometry system.


Tritium is determined in water samples by liquid scintillation counting.

Radioiodine (I-131) analysis in water was normally performed using chemically prepared samples and analyzed with a low-level beta counting system.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Figure 2-8

**Environmental Monitoring Stations Locations -
Ground, Surface Water, Drinking Water and Precipitation**



Sample Type	Site No.	Sector	Distance (miles)	Description	Sample Type	Site No.	Sector	Distance (miles)	Description
Surface	2.1	14	1.5	Downstream Midland - J&L	Ground	14	11	2.5	Hookstown
Surface	5	14	4.9	E. Liverpool, Oh. - Water Treatment Plant	Ground	15	14	3.7	Georgetown
Surface	49	3	5.0	Upstream side of Montgomery Dam	Precipitation	30	4	0.5	Shippingport (S.S.)
Drinking	4	15	1.3	Midland - Water Treatment Plant	Precipitation	47	14	4.9	E. Liverpool, Oh., - Water Treatment Plant
Drinking	5	14	4.9	E. Liverpool, Oh. - Water Treatment Plant	Precipitation	48	10	16.3	Weirton, W.Va. - Weirton Water Tower, Collier Way
Ground	11	3	0.8	Shippingport Boro					

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

3. Results and Conclusions

A summary of results of all analyses of water samples (surface, drinking, ground and precipitation) are provided by sample type and analysis in Table 2-2. These are discussed below.

a. Surface Water

A total of twelve (12) samples were analyzed quarterly for H-3. One of the twelve was positive with a value of 209 pCi/liter. This level is well below the required LLD of 2000 pCi/liter.

A total of thirty-six (36) samples were analyzed by gamma spectrometry. One of thirty-six indicated naturally occurring Ra-226. Another one of the thirty-six (36) samples indicated naturally occurring Th-228. Both samples were from the Control location.

A total of fifty-one (51) samples were analyzed for I-131 using a radiochemical method. Positive levels of I-131 were measured in thirty-two (32) of the weekly samples. The positive results ranged in values from 0.30 to 3.70 pCi/liter. This is similar to previous years. These positive results were detected at a Control location five miles upstream of BVPS and is considered outside the influence of BVPS operation.

b. Drinking Water

A total of eight (8) samples were analyzed for H-3. All results were below the LLD.

A total of twenty-four (24) samples were analyzed by gamma spectrometry. No gamma-emitting radionuclides were detected.

A total of one hundred (100) samples were analyzed for I-131 using a radiochemical method. Positive levels of I-131 were measured in fifty-eight (58) of the weekly samples. Thirty-nine (39) of the positive values were below the required LLD. The nineteen (19) at or above the required LLD were below reportable levels. The positive results were detected at both the Midland and East Liverpool plants at similar concentrations. Also, calculations were performed in the year 2000 to predict the I-131 concentrations at the Midland Water Treatment Plant from liquid effluent releases at the Beaver Valley Power Station during 2000. These calculations show that the predicted concentrations (less than detectable level) at the Midland Water Treatment Plant are well below the values being detected. Releases of I-131 for the year 2001 were at or below those for the year 2000. This calculation and the fact that I-131 is also being detected at the upstream surface water Control station at similar concentrations indicates that the positive results detected at the Midland Water Treatment Plant are not a result of plant releases.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

c. Groundwater

A total of six (6) samples were each analyzed for H-3 and by gamma spectrometry. No gamma-emitting radionuclides were detected. All six tritium results were less than LLD except 1, which was 214 pCi/l, which is slightly above the LLD of 200 pCi/l.

d. Precipitation

A total of twelve (12) samples were analyzed for H-3 and by gamma spectrometry. Four (4) positive tritium results detected were within normal levels. No gamma emitting radionuclides were detected.

e. Deviations from required sampling schedule and analysis

- CR 01-3189 was written for four (4) weekly drinking water, two weekly surface water and two weekly milk samples, that were collected, shipped and received by the vendor analysis lab for I-131 analysis. BVPS was notified by the vendor on 5/30/01 that the samples had not been analyzed. Due to the short half-life of I-131, it was too late to analyze the samples at that time. This vendor analysis lab has been replaced and this problem has not reoccurred.

f. Summary

The data from water analyses demonstrates that the Beaver Valley Power Station did not contribute a significant increase of radioactivity in local river, drinking, well waters or precipitation. The analytical results confirm that the station assessments, prior to authorizing radioactive discharges, are adequate and that the environmental monitoring program is sufficiently sensitive.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

I. Estimates of Radiation Dose to Man

1. Pathways to Man - Calculational Models

The radiation doses to man as a result of Beaver Valley operations were calculated for both gaseous and liquid effluent pathways using codes for the ARERAS/MIDAS computer system equivalent to NRC computer codes XOQDOQ2, GASPARG, and LADTAP. Dose factors listed in the ODCM were used to calculate doses to maximum individuals from radioactive noble gases in discharge plumes. Beaver Valley effluent data, based on sample analysis were used as the radionuclide activity input.

Radionuclides contained in the Annual Radioactive Effluent Release Report (noble gases, particulates, radioiodines and tritium) were included as source terms when they were detected above the LLD values. All LLD values reported by Beaver Valley Power Station are equal to or lower than those required by the ODCM.

All gaseous effluent releases, including Auxiliary Building Ventilation, were included in dose assessments. The release activities are based on laboratory analysis. Meteorological data collected by the Beaver Valley Power Station Meteorology System was used as input to code equivalent to XOQDOQ2 which in turn provided input for the GASPARG equivalent. Except when more recent or specific data was available, all inputs were the same as used in the Beaver Valley Power Station Environmental Statements or in Regulatory Guide 1.109. The airborne pathways evaluated were beta and gamma doses from noble gas plumes inhalation, the "cow-milk-child", and other ingestion pathways.

All potentially radioactive liquid effluents, including steam generator blowdown, are released by batch mode after analysis by gamma spectrometry using intrinsic germanium detectors. Each batch is diluted by cooling tower blowdown water prior to discharge into the Ohio River at the Beaver Valley Power Station outfall (River Mile 35.0). The actual data from these analyses are tabulated and used as the radionuclide activity input term in code equivalent to LADTAP. A hypothetical real individual for liquid pathways is located at Midland. Except when more recent or specific data for the period is available, all other input are obtained from the Beaver Valley Power Station Environmental Statement or Regulatory Guide 1.109. Pathways, which were evaluated, are drinking water, fish consumption, and shoreline recreation.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

2. Results of Calculated Radiation Dose to Man - Liquid Releases

a. Individual Dose

The doses which are calculated by the model described above are to the likely most exposed real individual located at Midland since this is the nearest location where significant exposure of a member of the general population could potentially occur. A breakdown of doses by total body by age group and highest organ by age group is provided in Table 2-4 for the likely most exposed individual. Included in this table is a breakdown of a typical dose to individuals from natural radiation exposure.

b. Population Dose

The 2001 calculated dose to the entire population of almost 4 million people within 50 miles of the plant is presented in Table 2-4.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Table 2-4

**Results of Calculated Individual and Population
Radiation Dose to Man - Liquid Releases**

Organ	Individual Exposure (a) mrem
<u>TOTAL BODY</u>	
Adult	0.0010
Teen	0.0007
Child	0.0010
Infant	0.0010
<u>ANY ORGAN</u>	
Adult	0.0011 (Liver)
Teen	0.0009 (Liver)
Child	0.0013 (Liver)
Infant	0.0010 (Liver)
<u>TYPICAL DOSE TO INDIVIDUALS FROM NATURAL RADIATION EXPOSURE(b)</u>	
Ambient Gamma Radiation	: 58
Radionuclides in Body	: 40
Global Fallout	: < 1
Radon	: 198
TOTAL mRem/year	: 296
(a)	Likely most exposed member of general population - located at Midland drinking water intake.
(b)	National Academy of Sciences, "The Effects on Populations of Exposure to Low Levels of Ionizing Radiation," BEIR Report, 1990

Population		
Organ	Man-Millirems	Largest Isotope Contributor
Total Body	71	H-3 69 Man-Millirems
GI-LLI	73	H-3 69 Man-Millirems

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

3. Results of Calculated Radiation Dose to Man - Atmospheric Releases

The results of calculated radiation dose to the maximum exposed individuals for BVPS airborne radioactive effluents during 2001 are provided in Table 2-5. The doses include the contribution of all pathways. A 50-mile population dose was also calculated and is provided.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Table 2-5

**Results of Calculated Radiation
Dose to Man - Atmospheric Releases**

Organ	Maximum Exposed Individual mrem
TOTAL BODY	0.301
SKIN	0.302
LUNG	0.302
THYROID	0.304

Organ	50-Mile Population Dose man-rem
TOTAL BODY	0.730
THYROID	0.730

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

4. Conclusions

Based upon the estimated dose to individuals from the natural background radiation exposure in Table 2-5, the incremental increase in total body dose to the 50-mile population (approximately 4 million people), from the operation of Beaver Valley Power Station - Unit 1 and 2, is less than 0.0001% of the annual background dose.

The calculated doses to the public from the operation of Beaver Valley Power Station - Unit 1 and 2, are below BVPS annual limits and resulted in only a small incremental dose to that which area residents already received as a result of natural background. The doses constituted no meaningful risk to the public.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

SECTION 3 - LAND USE CENSUS

A land use census was conducted July 30 through August 17, 2001 to comply with BV-1 and BV-2 Technical Specification 6.8.6b Item 2 and the ODCM Appendix C CONTROL 3.12.2. The census results are summarized in Table 3-1.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Table 3-1

Location of Nearest Residence, Garden, and Milch Animal

<u>SECTOR</u>	<u>RESIDENCE (miles)</u>	<u>GARDEN (miles)</u> ⁽¹⁾	<u>MILCH ANIMALS (miles)</u> ⁽²⁾
N	1.58	2.00	None
NNE	1.59	1.62	None
NE	0.39	2.62	None
ENE	0.54	1.01	None
E	0.40	1.93	2.62
ESE	0.89	1.71	None
SE	1.10	2.44	2.31
SSE	1.12	2.35	3.16
S	1.42	2.29	3.83
SSW	0.81	2.10	1.93
SW	1.55	1.55	2.16
WSW	1.44	2.56	3.38
W	2.25	2.25	None
WNW	2.75	None	4.83
NW	0.89	0.92	4.92
NNW	0.91	1.19	2.38

(1) Gardens greater than 500 square feet producing fresh leafy vegetables

(2) Within five miles

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

**SECTION 4 - QUALITY CONTROL PROGRAM / INTERLABORATORY
COMPARISON PROGRAM**

A. Quality Control Program

The Quality Control (QC) Program for the Beaver Valley Radiological Environmental Monitoring Program involves the analysis of split samples at a QC laboratory and the analysis of high quality (NIST traceable) spiked samples (results are discussed in the Interlaboratory Comparison Program section). This testing provides a means to ensure independent checks are performed on the precision and accuracy of the measurements of radioactive materials in environmental sample matrices. It should be noted that the comparisons for split and duplicate samples were at very low levels of radioactivity and consequently, the activities at these levels are difficult to measure.

The NRC criteria listed in NRC Inspection Procedure 84750, 12/4/90, Inspection Guidance 84750-03 is used as the acceptance criteria for comparisons of results of split and spike samples between the Contractor Lab and the QC Lab/Independent Lab. These comparisons are performed by dividing the comparison standard (the QC Lab or Independent Lab result) by its associated uncertainty to obtain the resolution. The comparison standard value is multiplied by the ratio values obtained from the following table to find the acceptance band for the result to be compared. Note that in the case where the counting precision of the standard yields a resolution of less than 4, a valid comparison cannot be made. Values identified with an '*' in Tables 4-1 through 4-10 do not meet acceptance criteria.

Resolution	Ratio
< 4	--
4 - 7	0.5 - 2.0
8 - 15	0.6 - 1.66
16 - 50	0.75 - 1.33
51 - 200	0.8 - 1.25
> 200	0.85 - 1.18

1. Split Sample Program (Contractor Laboratory - QC Laboratory)

Routine environmental samples of surface (river) water, drinking water, milk, sediment, food crops, and feed crops were routinely split and analyzed by the Contractor Laboratory and the QC Laboratory.

A summary of results of split water samples is provided in Table 4-1 and Table 4-2. There were no non-comparisons in all the surface water and drinking water analysis for gamma spec, I-131, and tritium analysis. Three (3) weekly drinking water I-131 results showed positive values for the Contractor Lab and less than values for the QC Lab. Comparison of results could not be made. Review of the Interlaboratory Comparison Program results (Table 4-8) indicates that the Contractor Laboratory performed well with I-131 analysis in water.

Summaries of milk, sediment, and feed/food crop split samples are provided in Table 4-3 and Table 4-4. Good overall agreement was obtained in all samples except for non-comparison for Co-58 and Co-60 in the sediment sample.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

2. Duplicate Sample Program (Contractor Laboratory - QC Laboratory)

Twenty-eight (28) duplicate (co-located) air particulate and charcoal filters samples were collected at Location #30 and compared (gross beta for particulate filters and radioiodine for charcoal filters) during the year. For the first quarter, the particulate filters were composited and analyzed for gamma activity. Results are presented in Table 4-5 and Table 4-6. There was good agreement of both the air particulate (beta) and charcoal cartridge filters. The first quarter composite of the air particulate filters (gamma) showed good comparisons.

For the first quarter, thirteen (13) duplicate (co-located) TLDs from the QC Laboratory were placed with thirteen (13) "routine" TLDs from the contractor laboratory, and the results were compared. The average of the Contractor Laboratory and the average of the QC Laboratory agree within $\pm 4.1\%$ of the mean of all results. This is well within the precision of typical TLD systems. Summary data of the TLD monitoring program is provided in Table 4-7.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

B. Interlaboratory Comparison Program

Participation in an Interlaboratory Comparison Program is required by BV-1 and BV-2 Technical Specification 6.8.6b, Item 3. In the first quarter of 2001 this requirement was fulfilled by the Contractor Lab (Teledyne Brown Engineering Environmental Services - Westwood N.J.) analyzing high quality (NIST traceable) spiked samples supplied by two Beaver Valley Power Station contracted vendors for the first quarter. For the remainder of the year, this requirement was fulfilled by the Contractor Lab (Environmental, Inc. - Northbrook, IL) and the spiked samples provided by one contracted vendor.

1. Contractor Lab

The high quality (NIST traceable) spiked samples include air particulate, charcoal filters water, and milk. The samples were submitted to the Contractor Lab for analysis. The "spiked to" values are used for calculating comparison acceptance criteria. Values identified with an "*" do not meet acceptance criteria explained above.

- Comparison of results of the spiked milk and water samples showed good results. As part of the offsite radiological environmental monitoring program spiked water and milk QC samples are prepared by a vendor and are sent to the vendor lab BVPS uses for sample analysis. The analysis lab does not know the concentration of the radionuclides in the milk and water sample (there are 12 radionuclides in each spike) prior to analysis. For the first quarter, the milk sample results for Sr-89 and Sr-90 did not meet the criteria used at BVPS for acceptable results (they were low by about 35%). For the water, Sr-89 was reported as < 1.5 pCi/l and the vendor supplying the sample reported 74 pCi/l. Also, for I-131 in water the analysis lab reported < 0.32 pCi/l while the vendor supplying the spike reported 90 pCi/l. CR 01-3531 was written in response to these non-comparisons.

The vendor provided BVPS with the documentation of this situation (TBE Nonconformance Report Form 01-35). The vendor concluded that this appears to be an isolated event. Their review of the analytical logbooks and worksheets for these samples did not uncover any abnormalities. No calculational errors were found. Other analyses for these radionuclides and matrix were reviewed for the same time frame and were determined to be acceptable. They conclude that a recurrence is not anticipated. It should be noted that this vendor is no longer used by BVPS effective 4/1/01.

The vendor (Analytics) supplying the spiked samples were contacted to determine if they have any reason to believe that the "spiked to" values provided to BVPS were in error. Analytics believes that the values are accurate.

As noted in last year's report, the new vendor used by BVPS as of 4/1/01 was to be tracked for Fe-59 analysis of spiked samples. No problems have been observed during the last three quarters of 2001.

- Comparison of results of the spiked air particulate filters and charcoal cartridge filters showed good results. Both results are reported in Table 4-10.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

C. Conclusions

Based on all available Quality Control data and Interlaboratory Comparison data the Environmental Monitoring Program for 2001 is acceptable with respect to both accuracy and measurement.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Table 4-1

**Quality Control Data
Contractor/Quality Control Laboratory
Comparison Split Surface Water Samples**

Site 2.1

Media	Analysis	Sampling Period	Contractor Lab (1)	QC Lab (1)	Units
Surface Water (Monthly Composite)	Co-60	January	< 4	< 2.3	pCi/l
		May	< 1.8	< 4.3	pCi/l
		December	< 3.5	< 1.5	pCi/l
Surface Water (Monthly Composite)	Cs-134	January	< 4	< 2.1	pCi/l
		May	< 3.2	< 4.5	pCi/l
		December	< 2.7	< 1.4	pCi/l
Surface Water (Monthly Composite)	Cs-137	January	< 4	< 2.6	pCi/l
		May	< 1.9	< 3.6	pCi/l
		December	< 4.3	< 1.2	pCi/l
Surface Water (Quarterly Composite)	Tritium	2 nd Quarter	< 146	< 200	pCi/l
(1) Uncertainties are based on counting statistics and are specified at the 95% confidence coefficient.					

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Table 4-2

**Quality Control Data
Contractor/Quality Control Laboratory
Comparison Split Drinking Water Samples**

Site 4

Media	Analysis	Sampling Period	Contractor Lab (1)	QC Lab (1)	Units
Drinking Water (Monthly Composite)	Cs-137	February	< 4	< 3.4	pCi/l
		June	< 2.2	< 3.3	pCi/l
		October	< 2.5	< 0.7	pCi/l
		November	< 2.7	< 0.8	pCi/l
Drinking Water (Monthly Composite)	Cs-134	February	< 4	< 2.7	pCi/l
		June	< 3.9	< 3.5	pCi/l
		October	< 2.5	< 0.8	pCi/l
		November	< 3.8	< 1.0	pCi/l
Drinking Water (Monthly Composite)	Co-60	February	< 4	< 1.7	pCi/l
		June	< 1.9	< 2.8	pCi/l
		October	< 3.2	< 0.7	pCi/l
		November	< 2.5	< 0.8	pCi/l
Drinking Water (Weekly Split)	I-131	3/5 to 3/12	1.9 ± 0.06	< 0.4	pCi/l
		8/7 to 8/14	0.6 ± 0.2	< 0.2	pCi/l
		11/6 to 11/13	1.8 ± 0.2	< 0.68	pCi/l
		11/27 to 12/4	< 0.4	< 0.85	pCi/l
Drinking Water (Quarterly Composite)	Tritium	3 rd Quarter	< 162	< 210	pCi/l

(1) Uncertainties are based on counting statistics and are specified at the 95% confidence coefficient.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Table 4-3

**Quality Control Data
Contractor/Quality Control Laboratory
Comparison Split Milk Samples**

Site 25

Media	Sampling Period	Analysis	Contractor Lab (1)	QC Lab (1)	Units
Milk (Weekly Split)	3/27/01	Sr-89	< 0.98	< 0.5	pCi/l
		Sr-90	1.7 ± 0.2	2.5 ± 0.5	pCi/l
		I-131	< 0.23	< 0.3	pCi/l
		Co-60	< 5.6	< 7.4	pCi/l
		Cs-134	< 5.7	< 4.4	pCi/l
		Cs-137	< 5.8	< 5.7	pCi/l
		K-40	1310 ± 82	1394 ± 178	pCi/l
Milk (Weekly Split)	9/18/01	Co-60	< 3.3	< 8.9	pCi/l
		I-131	< 0.3	< 1.5	pCi/l
		Cs-134	< 2.6	< 10	pCi/l
		Cs-137	< 3.0	< 9.1	pCi/l
		Sr-89	< 0.9	< 0.9	pCi/l
		Sr-90	1.6 ± 0.4	1.34 ± 0.24	pCi/l
Milk (Weekly Split)	11/13/01	I-131	< 0.2	< 0.27	pCi/l
		Co-60	< 2.4	< 8.3	pCi/l
		Cs-134	< 2.9	< 9.4	pCi/l
		Cs-137	< 4.0	< 7.6	pCi/l
(1) Uncertainties are based on counting statistics and are at the 95% confidence level.					

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Table 4-4

**Quality Control Data
Contractor/Quality Control Laboratory
Comparison Split Feed, Food, Sediment and Soil Samples**

Media	Sampling Period	Analysis	Contractor Lab (1)	QC Lab (1)	Units
Food Site 10	8/29/01	Co-60	< 0.010	< 0.014	pCi/gm (wet)
		I-131	< 0.011	< 0.059	pCi/gm (wet)
		Cs-134	< 0.007	< 0.013	pCi/gm (wet)
		Cs-137	< 0.008	< 0.012	pCi/gm (wet)
Sediment Site 2A	12/5/01	Co-58	0.20 ± 0.03*	0.11 ± 0.01	pCi/gm (dry)
		Co-60	0.93 ± 0.04*	0.49 ± 0.01	pCi/gm (dry)
		Cs-134	< 0.05	< 0.02	pCi/gm (dry)
		Cs-137	0.14 ± 0.02	0.07 ± 0.01	pCi/gm (dry)
<p>(1) Uncertainties are based on counting statistics and are specified at the 95% confidence coefficient.</p> <p>* See Section 4A.</p>					

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Table 4-5

**Quality Control Data
Contractor/Quality Control Laboratory Comparison
Duplicate (Co-located) Air Particulate and Charcoal Filter Samples**

Sites 30 and 30A

Air Particulates pCi/Cu Meter (Beta)			Air Iodine pCi/Cu Meter		
Collection Date	Contractor Lab (1)	QC Lab (1)	Collection Date	Contractor Lab	QC Lab
1/15	0.035 ± 0.005	0.027 ± 0.003	1/8	< 0.07	< 0.007
1/29	0.038 ± 0.006	0.026 ± 0.003	1/22	< 0.06	< 0.005
2/12	0.027 ± 0.005	0.019 ± 0.003	2/5	< 0.06	< 0.005
2/26	0.029 ± 0.003	0.026 ± 0.003	2/19	< 0.04	< 0.004
3/12	0.011 ± 0.002	0.012 ± 0.003	3/5	< 0.04	< 0.005
3/26	0.015 ± 0.003	0.017 ± 0.003	3/19	< 0.03	< 0.006
4/9	0.021 ± 0.003	0.019 ± 0.003	4/9	< 0.04	< 0.012
5/7	0.024 ± 0.004	0.032 ± 0.004	5/7	< 0.04	< 0.015
6/14	0.016 ± 0.003	0.018 ± 0.002	6/14	< 0.04	< 0.007
7/9	0.017 ± 0.003	0.020 ± 0.002	7/9	< 0.04	< 0.005
8/13	0.030 ± 0.004	0.032 ± 0.003	8/13	< 0.04	< 0.015
9/17	0.025 ± 0.003	0.020 ± 0.002	9/17	< 0.04	< 0.013
10/18	0.033 ± 0.004	0.030 ± 0.002	10/18	< 0.04	< 0.016
11/12	0.023 ± 0.004	0.021 ± 0.003	11/12	< 0.04	< 0.008

(1) Uncertainties are based on counting statistics and are specified at the 95% confidence coefficient.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Table 4-6

**Quality Control Data
Contractor/Quality Control Laboratory
Comparison Duplicate (Co-located) Air Particulate Samples (Gamma) (pCi/Cu Meter)**

Sample Period	Nuclide	Contractor Lab (1) – Site 30	QC Lab (1) – Site 30A
1 st Quarter Composite	Be-7	0.050 ± 0.005	0.066 ± 0.02*
	Co-60	< 0.0003	< 0.0007
	Cs-134	< 0.0003	< 0.0006
	Cs-137	< 0.0003	< 0.0004
	Ba-La-140	< 0.030	< 0.0025
(1)	Uncertainties are based on counting statistics and are specified at the 95% confidence coefficient.		
*	Resolution < 4, see Section 4A.		

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Table 4-7

**Quality Control Data
Contractor/Quality Control Laboratory Comparison
Thermoluminescent Dosimeters - mR/day**

1ST QUARTER		
Location No.	Contractor	QC Lab
10	0.142	0.148
13	0.149	0.151
14	0.142	0.159
15	0.137	0.152
27	0.147	0.148
28	0.126	0.143
29B	0.170	0.167
32	0.160	0.164
45	0.157	0.163
46	0.139	0.144
47	0.147	0.164
48	0.165	0.170
51	0.155	0.158

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Table 4-8

**Interlaboratory Comparison Program
Independent Laboratory/Contractor Laboratory
Comparison Spiked Water Samples (pCi/l)**

Sample Date	Sample Type and Identification No.	Sample Analyses	Independent Lab (1)	Contractor Lab (1)
3/22/01	Water E2583-93	Sr-89	74 ± 4	< LLD *
		Sr-90	69 ± 3	61 ± 1
		I-131	90 ± 5	< LLD *
		Ce-141	94 ± 5	90 ± 5
		Cr-51	242 ± 12	227 ± 24
		Cs-134	129 ± 6	111 ± 4
		Cs-137	102 ± 5	96 ± 5
		Co-58	48 ± 2	49 ± 4
		Mn-54	101 ± 5	98 ± 5
		Fe-59	84 ± 4	87 ± 6
		Zn-65	186 ± 9	193 ± 11
		Co-60	147 ± 7	143 ± 5
3/22/01	Water E2582-93	H-3	3114 ± 156	2700 ± 100
6/14/01	Water E2683-93	Sr-89	70 ± 4	58 ± 2
		Sr-90	37 ± 2	38 ± 1
		I-131	74 ± 4	72 ± 1
		Ce-141	234 ± 12	234 ± 8
		Cr-51	322 ± 16	332 ± 47
		Cs-134	193 ± 7	177 ± 3
		Cs-137	174 ± 9	185 ± 6
		Co-58	139 ± 7	141 ± 6
		Mn-54	216 ± 11	229 ± 6
		Fe-59	126 ± 6	127 ± 7
		Zn-65	261 ± 13	269 ± 9
		Co-60	194 ± 10	198 ± 4
6/14/01	Water E2682-93	H-3	7494 ± 375	7203 ± 243

(1) Uncertainties are based on counting statistics and are specified at the 95% confidence coefficient.
* See Section 4-B.

(Table 4-8 continued on next page)

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Table 4-8 (Continued)

**Interlaboratory Comparison Program
Independent Laboratory/Contractor Laboratory
Comparison Spiked Water Samples (pCi/l)**

Sample Date	Sample Type and Identification No.	Sample Analyses	Independent Lab (1)	Contractor Lab (1)
9/20/01	Water E2797-93	Sr-89	85 ± 4	79 ± 5
		Sr-90	59 ± 3	60 ± 2
		I-131	60 ± 3	66 ± 5
		Ce-141	88 ± 4	90 ± 3
		Cr-51	265 ± 13	277 ± 21
		Cs-134	116 ± 6	107 ± 2
		Cs-137	232 ± 12	236 ± 3
		Co-58	128 ± 6	133 ± 3
		Mn-54	149 ± 7	155 ± 2
		Fe-59	62 ± 3	68 ± 6
		Zn-65	184 ± 9	193 ± 7
		Co-60	193 ± 10	196 ± 3
9/20/01	Water E2796-93	H-3	4580 ± 230	4523 ± 114
12/6/01	Water E2985-93	Sr-89	71 ± 4	63 ± 7
		Sr-90	43 ± 2	44 ± 2
		I-131	93 ± 5	90 ± 2
		Ce-141	224 ± 11	225 ± 2
		Cr-51	293 ± 15	303 ± 9
		Cs-134	117 ± 6	111 ± 1
		Cs-137	188 ± 9	194 ± 5
		Co-58	53 ± 3	56 ± 1
		Mn-54	88 ± 4	93 ± 1
		Fe-59	60 ± 3	67 ± 4
		Zn-65	122 ± 6	136 ± 5
		Co-60	209 ± 10	211 ± 1
12/6/01	Water E2984-93	H-3	14060 ± 703	14664 ± 181

(1) Uncertainties are based on counting statistics and are specified at the 95% confidence coefficient.

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Table 4-9

**Interlaboratory Comparison Program
Independent Laboratory/Contractor Laboratory
Comparison Spiked Milk Samples (pCi/l)**

Sample Date	Sample Type and Identification No.	Sample Analyses	Independent Lab (1)	Contractor Lab (1)
3/22/01	Milk E2584-93	Sr-89	88 ± 4	56 ± 3 *
		Sr-90	51 ± 3	35 ± 1 *
		I-131	77 ± 4	64 ± 1
		Ce-141	162 ± 8	146 ± 7
		Cr-51	418 ± 21	392 ± 31
		Cs-134	223 ± 11	188 ± 6
		Cs-137	176 ± 9	160 ± 9
		Co-58	82 ± 4	77 ± 5
		Mn-54	175 ± 9	168 ± 8
		Fe-59	146 ± 7	144 ± 9
		Zn-65	322 ± 16	323 ± 16
		Co-60	254 ± 13	231 ± 7
6/14/01	Milk E2684-93	Sr-89	79 ± 4	67 ± 2
		Sr-90	30 ± 2	28 ± 1
		I-131	69 ± 3	65 ± 0
		Ce-141	163 ± 8	160 ± 7
		Cr-51	224 ± 11	239 ± 7
		Cs-134	134 ± 7	125 ± 1
		Cs-137	121 ± 6	128 ± 1
		Co-58	96 ± 5	98 ± 4
		Mn-54	150 ± 8	158 ± 3
		Fe-59	88 ± 4	93 ± 6
		Zn-65	182 ± 9	187 ± 1
		Co-60	135 ± 7	137 ± 3

(1) Uncertainties are based on counting statistics and are specified at the 95% confidence coefficient.

* See Section 4-B.

(Table 4-9 continued on next page)

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Table 4-9 (Continued)

**Interlaboratory Comparison Program
Independent Laboratory/Contractor Laboratory
Comparison Spiked Milk Samples (pCi/l)**

Sample Date	Sample Type and Identification No.	Sample Analyses	Independent Lab (1)	Contractor Lab (1)
9/20/01	Milk E2798-93	Sr-89	75 ± 4	62 ± 1
		Sr-90	50 ± 3	49 ± 1
		I-131	91 ± 5	80 ± 1
		Ce-141	121 ± 6	121 ± 3
		Cr-51	366 ± 18	378 ± 10
		Cs-134	160 ± 8	148 ± 3
		Cs-137	319 ± 16	327 ± 2
		Co-58	177 ± 9	181 ± 2
		Mn-54	205 ± 10	213 ± 2
		Fe-59	86 ± 4	91 ± 1
		Zn-65	254 ± 13	270 ± 2
		Co-60	266 ± 13	269 ± 1
12/6/01	Milk E2986-93	Sr-89	85 ± 4	73 ± 9
		Sr-90	59 ± 3	55 ± 4
		I-131	61 ± 3	58 ± 0
		Ce-141	379 ± 19	364 ± 7
		Cr-51	497 ± 25	511 ± 16
		Cs-134	199 ± 10	184 ± 5
		Cs-137	318 ± 16	325 ± 3
		Co-58	90 ± 5	97 ± 1
		Mn-54	149 ± 7	156 ± 2
		Fe-59	102 ± 5	111 ± 3
		Zn-65	206 ± 10	224 ± 9
		Co-60	353 ± 18	351 ± 2
(1) Uncertainties are based on counting statistics and are specified at the 95% confidence coefficient.				
* See Section 4-B.				

**Beaver Valley Power Station
2001 Annual Radiological Environmental Operating Report**

Table 4-10

**Interlaboratory Comparison Program
Contractor/Quality Control Laboratory
Comparison Spiked Air Particulate/Charcoal Filters**

Sample Date	Sample Type and Identification No.	Sample Analyses	Contractor Lab (1)	Independent Lab (1)	Units
4/25/01	Air Particulate Filter DQQC AP-15	Gross Beta	0.78 ± 0.08	0.77 ± 0.02	pCi/m ³
9/20/01	Air Particulate Filter E2799-93	Gross Beta	81 ± 4	81 ± 0.9	pCi/sample
9/20/01	Air Charcoal Filter E2800-93	I-131	68 ± 3	72 ± 3	pCi/sample
12/21/01	Air Charcoal Filter E3002-93	I-131	63.2 ± 1.8	61.0 ± 3.0	pCi/sample
(1) Uncertainties are based on counting statistics and are specified at the 95% confidence coefficient.					