May 20, 2002

MEMORANDUM TO: File

FROM: Omid Tabatabai, Project Manager /RA/

License Renewal Section

License Renewal and Environmental Impacts Program

Division of Regulatory Improvement Programs

Office of Nuclear Reactor Regulation

SUBJECT: DOMINION'S RESPONSE TO DRAFT RAI 2.3.4.4-8

On November 21, 2001, Mike Henig of Virginia Electric and Power Company (VEPCo) transmitted an electronic mail (e-mail) to Robert Prato and provided Dominion's draft response to the staff's request for additional information (RAI) 2.3.4.4-8. The e-mail response from VEPCo is attached.

Attachment: As Stated

cc: PUBLIC

Docket Nos. 50-338, 50-339, 50-280, and 50-281

From: <Michael_Henig@dom.com>

To: <RJP2@nrc.gov> **Date:** 11/21/01 3:18PM

Subject: Response to Draft RAI 2.3.4.4-8

Bob,

Noted below is the revised Dominion response to RAI 2.3.4.4-8.

Bob, have a safe and restful Thanksgiving and I will talk to you on Monday

Michael W. Henig

Phone: 804-273-2237 Fax: 804-273-3554

Email: Michael_Henig@dom.com

---- Forwarded by Michael Henig/NUC/VANCPOWER on 11/21/01 03:10 PM -----

Marc

Hotchkiss To: Michael Henig/NUC/VANCPOWER@VANCPOWER

CC:

11/21/01

Subject: Response to Draft RAI 2.3.4.4-8

03:07 PM

Item 2.3.4.4-8 RESPONSE

The back-up compressed air system components for the Surry turbine-driven auxiliary feedwater pump steam admission valves, 1(2)-MS-PCV-102A/B, are Instrument Air (IA) system components, and are shown on Surry drawings 11448-LRM-075C, sheet 3 and 11548-LRM-075D, sheet 1 listed in LRA section 2.3.3.14. As identified on the LRM drawings, these back-up air system components are within the scope of license renewal.

Attachment